

Generator / ATS Data and Fuel Tank Size

Building and Maintenance =

Public Utilities =

G #	Address	Make/Model/Serial No.	KW	Fuel Cap		Last Inspection	Last Loadbank	Last Insul. Test	EMT	Cat Connect
				Main Tank	Day Tank				Warranty	
G1387 ATS	Garden Ave Garage 28 N Garden Ave. Clearwater	Cat 3208 Ser. 30A01188	80 KW	500 Gal	No label 25 Gal	11/5/2022 295 Hours	12/6/2022 WO H107457	12/20/2022	No ESC Eligible	
	Onan 400 Amp 3 ph. Open transition	OTECC Spec. A I040691050	480 Volt 3 Pole NEMA 1							
G1394 ATS	NE WWTP Admin Bldg 3290 SR 580 Safety Harbor	Cat 3512 Ser. 24Z04114	1000 KW	2000 Gal Con vault	N/A	12/5/2022 1455 Hours	11/9/2022 WO H111699	12/1/2022	No ESC Eligible	
	Asco 1600 amp bypass 3 ph. Service entrance Open transition	Cat. G07ATBA31600N5X0 Ser. 1139307 WE	480 Volt 3 Pole NEMA 1			6/22/2023				
G1395 ATS 1 ATS 2	NE WWTP Screw Lift 3290 SR 580 Safety Harbor	Cat 3508 Ser. 23Z03925	750 KW	2000 Gal Con vault	N/A	5/26/2023 742 Hours	6/14/2023	6/2/2023	No ESC Eligible	
	Zenith 1000 amp 3 ph. Open transition	ZTSH100EC-7-8AC/DEJLLPRTUW Ser. 195015	480 Volt 3 Pole NEMA 1			5/23/2023				
	Zenith 400 amp 3 ph. Open transition	ZTSH Ser. 195013	480 Volt 3 Pole NEMA 1			5/23/2023				
G1396 ATS	NE WWTP Screw Lift 3290 SR 580 Safety Harbor	Cat 3412 Ser. 81Z12308	600 KW	2000 Gal Con vault	N/A	5/26/2023 316 Hours	6/13/2023		No ESC Eligible	
	Asco 1000 amp bypass 3 ph. Open transition	Cat. H07ATBA31000N5XC Ser. 1211805 WE	480 Volt 3 Pole NEMA 1			5/25/2023				
G1397 ATS 1 ATS 2	NE WWTP Sand Filter Bldg 3290 SR 580 Safety Harbor	Cat 3508 Ser. 23Z02868	750 KW	2000 Gal Con vault	N/A	12/5/2022 1463 Hours	12/2/2022		No ESC Eligible	
	Caterpillar/Zenith 1200 amp 3 ph. Open transition	Mod. CTG Ser. TSA16461	480 Volt 4 Pole NEMA 1			6/13/2023				
	Zenith 225 amp 3 ph. Open transition	ZTS22EC-7-8AC/DEJLLPRRTUW 195012	480 Volt 3 Pole NEMA 1			6/14/2023				
G1398 ATS	NE WWTP Belt Press 3290 SR 580 Safety Harbor	Cat 3406 Ser. 4RG00638	350 KW	1000 Gal Con vault	N/A WO H106180	4/14/2022 2800 Hours	11/3/2022		No ESC Eligible	
	Thomson 600 amp 3 ph. Open transition	Mod. TS873A0600A1AY3DKKAA Ser. MW-000289-001	480 Volt 3 Pole NEMA 1			2/16/2023	WO H116567			
G1400	NE WWTP Oxidation Bldg	Cat 3412	600 KW	3000 Gal	Pryco	3/29/2023	4/3/2023	4/3/2023		

ATS	3290 SR 580 Safety Harbor	Ser. 81Z14723		Con vault	75 Gal	1354 Hours			No ESC Eligible	
	Asco 1200 amp 3 ph. Open transition	Cat. G7ADTA31200N5XC Ser. 178922	480 Volt 3 Pole			3/30/2023				
G1697	Municipal Services Bldg 100 S. Myrtle Ave Clearwater	Onan 200DFAA L950595256	200 KW	275 Gal Base tank	N/A	7/29/2020 406 Hours	7/20/2021			
ATS A	Onan 150 Amp 3 ph. Open transition	OT 150 Spec. J K950593356	480 Volt 4 Pole NEMA 1							
ATS B	Onan 150 Amp 3 ph. Open transition	OT 150 Spec. J K95059337	480 Volt 4 Pole NEMA 1							
G1770	Main PD Parallels w/G1771 645 Pierce St Clearwater	Onan 500DFED B960597891	500 KW	5200 Gal Shared		7/9/2020 365 Hours	9/24/2020			
ATS 1	Onan 225 Amp 3 ph. Open transition	OT225 Spec. J K950593359	480 volt 4 pole							
ATS 2	Onan 150 Amp 3 ph. Open transition	OT150 Spec. J K950593358	480 volt 4 pole							
ATS 3	Asco 1200 amp 3 ph. Open transition	H04ATSB31200N50C 319431 RE	480 volt 4 pole							
G1771	Main PD Parallels w/G1770 645 Pierce St Clearwater	Onan 500DFED B960597890	500 KW	5200 Gal Shared		7/29/2020 337 Hours	9/23/2020			
G1772	Solid Waste Facility Fuel Site 1701 N Hercules Ave Clearwater	Spectrum 30DS60 379634	30 KW	Base tank	N/A	No Record	No Record			
ATS	Spectrum 104 Amp 1 ph. Open transition	S-164231-104 K69464	240 Volts 2 Pole NEMA 1							
G2934	Solid Waste Admin 1701 N Belcher Ave Clearwater	Onan DGCB Spec. T C040613726	60KW	125 Gal Base tank	N/A					
ATS	Onan 400 Amp 3 ph. Open transition	OTPCC Spec. A B040608373	240 Volt 3 Pole NEMA 1							
G2952	Marshal St WTP Lab 1605 Harbor Dr Clearwater	Kohler 60ROZJ 712240	60 KW	100 Gal Base tank	6/6/2023 595 Hours	6/6/2023 595 Hours	N/A			
ATS	Kohler									
G2953	Main Library 100 N Osceola Ave Clearwater	Cat 3406 1DZ06346	300 KW	500 Gal Base tank	N/A	1/4/2023 87 Hours	1/19/2023 WO H116669	1/5/2023	No ESC eligible	

ATS	Asco 600 amp 3 ph. Open transition	Cat. H00300030600N10C Ser. 223408-006 FP	480 Volt 3 Pole NEMA 1							
G2954	NEWTP Reclaim Bldg 3290 SR 580 Safety Harbor	Cat 3508 CNB00425	1 Meg	6000 Gal Con vault	Pryco 150 Gal	5/9/2023 1048 Hours	5/2/2023 WO H124215		No ESC Eligible for 5 yrs	
ATS	Asco Main Tie Main open transition									
G2955	RO 1 1657 Palmetto St Clearwater	Onan DFHC Spec. F E030499388	900 KW	4000 Gal Con vault	N/A	2/24/2023 667 Hours	3/15/2023 WO H119103	3/14/2023		
ATS	Onan 1600 amp 3 ph. Open transition	Mod. OTPCF Spec. A Ser. D030493948	480 Volt 3 Pole NEMA 1		3/7/2023 WO H119105					
G3071	Fire Station 44 950 Gulf Blvd Clearwater	Kohler 80ROZJ 729358	80 KW	500 Gal Base tank	N/A	No Record	No Record			
ATS	Kohler 400 Amp 1 Ph. Open transition	K-564233-0400 K0728208	240 Volt 2 Pole NEMA 3R							
G3077	Fire Station 49 565 Sky Harbor Dr Clearwater	Kohler 100RE0ZJB 765734	100 KW	500 Gal Base tank	N/A	No Record	No Record			
ATS	Kohler 400 Amp 3 ph. Open transition	GM17960 227961-001FP	208 Volt 3 Pole NEMA 1							
G3079	Fire Station 51 17 Overbrook Clearwater	DGDB Spec. R L030578552	100 KW	580 Gal Base tank	N/A	No Record	No Record			
ATS	Onan 400 Amp 3ph. Open transistion	OTPCC Spec A. L030575826	208 Volt 3 Pole NEMA 1							
G3217	FS 48 Logistics 1705 N Belcher Rd Clearwater	Onan 60DGCB Spec. J C950571406	60 KW	225 Gal Base tank	N/A	6/24/2022 729 Hours	8/3/2022			
ATS	Thomson 400 Amp 3 ph. Open transition	TS873A0400A1AY1DKKAA W-049717	208 vOLT 3 Pole NEMA1							
G3240	MSB Curbside Unit 100 S. Myrtle Ave Clearwater	Onan DGDK Spec. C H050813172	125 KW	125 Gal Base tank	N/A	8/20/2021 559 Hours	8/26/2021			
ATS	Onan 225 amp 3 ph. Open transition	OTPCB Spec. A F050789180	480 Volt 3 Pole NEMA 1							
G3241	Lift Station 42 2991 McMullen Booth Rd. Safety Harbor	Kohler 150ROZJ71 285619	150 KW	250 Gal Base tank	N/A	4/14/2022 690 Hours	5/12/2022			

ATS	Kohler 225 amp 3 ph. Open transition	Part No. K-166341-225 Ser. K37011	480 Volt 3 Pole NEMA 1		WO H124774	5/2/2023				
G3244	Lift Station 7 205 Jeffords St Clearwater	Onan DGEA Spec. L H990974850	125 KW	200 Gal Base tank	N/A	3/23/2021 244 Hours	11/9/2021			
ATS	Onan 225 amp 3 ph. Open transition	Mod. OTB Spec. K G990947643	480 Volt 3 Pole NEMA 1		WO H120942	5/8/2023				
G3245	Lift Station 45 1371 s. Gulf Blvd Clearwater	Onan DGFC Spec. B A990858231	200 KW	200 Gal Base tank	N/A	4/10/2023 310 Hours	4/10/2023	4/20/2023		
ATS	Onan 600 amp 3 ph. Open transition	Mod. OTC Spec. 01 Ser. A990851624	480 Volt 3 Pole NEMA 1			4/10/2023				
G3246	Countryside PD (Old Library Unit) 2741 SR 580 Clearwater	Onan DGFA Spec. R F0500794615	150 KW	500 Gal Steel tank	N/A	No Record 282 Hours	No Record			
ATS	Onan 400 Amp 3 ph. Open transition	OTPCC Spec. A B050751466	208 Volt 3 Pole NEMA 1							
G3247	Fire Station 46 (Temporary unit) 605 Mandalay Ave Clearwater	Onan DGCB Spec. T H050812731	40 KW	500 Gal Base tank	N/A	4/4/2022 991 Hours	5/5/2022			
ATS	Asco 400 Amp 3 Ph. Open transition	J03ATSA20400FGXF 2294134-003 RE	240 Volt 2 Pole NEMA 3R							
G3248	Fire Station 47 1460 Lakeview Rd Clearwater	Onan DGCB Spec. T F050794618	60 KW	500 Gal Base tank	N/A	No Record	No Record			
ATS	Onan 400 amp 3 ph. Open transition	OTPCC Spec. A F050789076	208 volt 3 pole NEMA 1							
G3249	Fire Station 48 1700 N. Belcher Rd Clearwater	Onan DGDA Spec. R F050794619	80 KW	1000 Gal Con vault	N/A	No Record 765 Hours	2/22/2022			
ATS	Onan 400 Amp 3 ph. Open transition	OTPCC Spec. A F050789224	208 Volt NEMA 1							
G3258	Beach PD (Portable) 700 Bayway Blvd Clearwater	Onan DGDB Spec. R J050840475	100 KW	194 Gal Base tank	N/A	2/26/2021 698 Hours	2/18/2021			
ATS	Onan 400 Amp 3 ph. Open transition	OTECC Spec. A I050833315	208 Volt 3 pole NEMA 1							
G3288	Marshal St WTP Control Bldg 1605 Harbor Dr. Clearwater	Cat 3516 ZAL00116	1750 KW	4000 Gal Con vault	N/A	12/14/2021 1672 Hours	12/15/2021		No ESC/ Is eligible	

SWBD 1	Square D 2000 amp 3 ph. Main Tie Main Open transition	Cat. 19874968-001	480 Volt Breaker NEMA 1			6/28/2023				
SWBD 2	Square D 2000 amp 3 ph. Main Tie Main Open transition	Cat. 27693185-001	480 Volt Breaker NEMA 1			6/28/2023				
G3390	Water Plant #3	Cat 3412	600 KW	4000 Gal	N/A	3/14/2023	3/28/2023	3/14/2023		
ATS	2775 SR 580 Clearwater	9EP03497		Con vault	WO H119877	276 Hours			No ESC/ Is eligible	
	Asco 1000 amp 3 ph. Open transition	Cat. H00300B31000N10C Ser. 335422 RE	480 Volt 4 Pole NEMA 1		WO H119882	3/2/2023				
G3508	Lift Station 58 1308 McMullen Booth Rd Safety Harbor	Onan DFEK K060989813	600 KW	2000 Gal Con vault	N/A	4/22/2022	No Record			
ATS	Onan 800 amp 3 ph. Open transition	Mod. OTPCD Spec. A Ser. I060966720	480 Volt 3 Pole NEMA 1		WO H124929	5/3/2023				
G3513	Traffic	Onan DGCB Spec. U	60 Kw	325 Gal	N/A	No Record	No Record			
ATS	1681 Arcturas Ave	H070096812		Base tank						
	Thomson 400 Amps 3 ph. Open transition	TS873A0400A1AE1DKKAA W-040140	240 Volt 3 Pole NEMA 3R							
G3529	Fleet Maintenance	Cat C9	300 KW	2000 Gal	N/A	No Record	No Record			
ATS UPS	1900 Grand Ave Clearwater			Con vault						
	Zenith 225 Amp 3 ph. Open transition	ZTSD00B0U022E 150385963-10-1	480 Volt 3 Pole NEMA 1							
ATS Main	Asco 1000 Amp 3 ph. Open transition	H04ATSA31000N50C 456771 RE	480 Volt 3 Pole NEMA 1							
G3612	Lift Station 24	Cat C6.6	150 KW	500 Gal	No label	2/22/2023	3/3/2023	2/27/2023		
ATS	1351 Sunset Point Rd Clearwater	N6D00619		Con vault	20 Gal	705 Hours			No ESC/ Is eligible	
	Asco 400 amp 3 ph. Open transition Bypass	Cat. J07ATBA30400N5XC Ser. 2055140 RE	480 Volt 4 Pole NEMA 1		WO H119107	2/22/2023				
G3619	Fire Station 48 Training	Cat C9	242 KW	1400 Gal	N/A	6/24/2022	8/16/2022			
ATS 1	1700 N Belcher Rd Clearwater	C9E00966		Base tank		1271 Hours			No ESC/ Is eligible	Yes
	Asco 600 Amp 3 ph. Open transition Bypass	J7ADTSA30600C5XF 436868 RE	208 Volt 3 Pole NEMA 1							
ATS 2	Asco 260 Amp	J7ADTSA30260C5XF	208 Volt							

ATS 3	3ph. Open transition	435227 RE	3 Pole NEMA 1							
	Onan 225 Amp 3 ph. Open transition	OT 225 B950568085	208 Volt 3 Pole NEMA 1							
G3771	Marshal St WTP Belt Press 1605 Harbor Dr. Clearwater	Cat C27 DWB01552	750 KW	6000 Gal Con vault	Pryco 50 Gal	1/26/2023 1080 Hrs	2/14/2023 WO H090216	2/9/2023 WO H117026		
ATS 1	Onan 800 amp 3 ph. Open transition	Mod. OTPCD Spec. A Ser. F050798694	480 Volt 3 Pole NEMA 1			4/7/2023				
ATS 2	Asco 1000 amp 3 ph. Service entrance Open transition	Cat. H07AUSB31000N5XC Ser. 1711739 WE	480 Volt 4 Pole NEMA 1		WO H118909	2/17/2023				
G3967	Baycare Stadium 601 Old Coachman Rd Clearwater	Cat C9 NBP00375	300 KW	2000 Gal Con vault	N/A	No Record	No Record		No ESC/ Is eligible	
ATS	Thomson 400 Amp 3 ph. Open transition	TS873A0400A1CY3 MW-001725-001	480 Volt 3 Pole NEMA 3R							
G4105	Fire Station 45 1140 Court St Clearwater	Cat C15 NAP00108	400 KW	3215 Gal Base tank	N/A	2/10/2021 421 Hours	2/10/2021		No ESC/ Is eligible	
ATS LS	Asco 260 Amp 3 ph. Open transition	E00300C30260N10C 1002236 RE	480 Volt 4 Pole NEMA 1							
ATS EQ	Asco 800 Amp 3 ph. Open transition	H03AUSB30800N10C 1002237 WE	480 Volt 4 Pole NEMA 1							
G4124	Water Plant #2 21133 US 19 N Clearwater	Onan DQGAB Spec. C D140658400	1.5 Meg	12000 Gal Con vault	N/A	No Record 475 Hours	7/15/2021			
ATS	Onan 3000 amp 3 ph. Open transition	Mod. OTPCH Spec. B Ser. B14M645039	480 Volt 4 Pole NEMA 1							
G4222	East WTP 3141 Gulf to Bay Blvd Clearwater	Cat C27 MJE04162	800 KW	2000 Gal 2 Tanks		1/17/2022 572 Hours	1/20/2022		No ESC/ Is eligible	
ATS 1	Asco 1000 amp 3 ph. Open transition	Cat. H3ADTSA31000NGXC Ser. 1149433	480 Volt 3 Pole NEMA 1			7/12/2023				
ATS 1A	Asco 400 amp 3 ph. Open transition	Cat. J3ADTSA30400NGXC Ser. 1149242 RE	480 Volt 4 Pole NEMA 1			7/12/2023				
ATS 2	Asco 1000 amp 3 ph. Open Transition	Cat. H3ADTSA31000NGXC Ser. 1149241 RE	480 Volt 3 Pole NEMA 1							

ATS 3	Asco 800 amp 3 ph. Open transition	Cat. H7ADTSA30800N5XC Ser. 1149244 RE	480 Volt 3 Pole NEMA 1							
G4501	MSC Garage 640 Pierce St Clearwater	D60-4LC CN400142	60 KW		N/A	1/18/2022 108 Hours	No Record		Yes ESC	Yes
ATS	Asco 70 Amp 3 Pph. Open transition	D03ATSA30070NGXC 2367235-001RE	480 Volt 3 Pole NEMA 1							
G4659	Fire Station 50 2681 Countryside Blvd Clearwater	Cat C7.1 WG300124		500 Gal Con vault	N/A	No Record 189 Hours	No Record		No ESC/ Is eligible	Yes
ATS	Asco 600 Amp 3 ph. Open transition	J7ADTSA30600C5XC 900663	208 Volt 3 Pole NEMA 1							
G4840	Fire Station 48 EOC 1700 N Belcher Rd Clearwater	Cat D200-2 WG300539	200 KW	1351 Gal Base	N/A	6/24/2022 25 Hours	9/2/2022		Yes ESC	Yes
ATS	Asco 800 Amp 3 ph. Open transition	H7ADTBA30800C6XC 125579	208 Volt 3 Pole NEMA 1							
G5009	Gas Admin 777 Maple St Clearwater	Cat 3512 Natural Gas E2P00210	750 KW	Natural Gas	N/A	7/19/2021 390 Hours	7/19/2021		Yes ESC	Yes
ATS	Asco 1600 Amp 3 ph. Bypass Isolation	G07ATBB31600N5XM 1258129	480 Volt 3 Pole NEMA 3R							
G5010	Solid waste transfer station 1005 Old Coachman Rd Clearwater	Generac SG500 3004820759	500 KW	Natural Gas	N/A	No record	No record			
ATS	Asco 1000 Amp 3 ph. Open transition	H3ADTSB31000NGXC 1159707	480 Volt 4 Pole NEMA 1							
G5256	Lift Station 54 2304 Mcmullen Booth Rd. Clearwater	Cat DG50-2 CAT0DG60AT3700727	50 KW	Natural Gas	N/A	No record	No record		Yes ESC	
ATS	Asco 104 Amp 3 ph. Open transition	D03ATSA30104FGXH 2346585-001RE	240 VOLT 3 Pole NEMA 4X							
G5257	Lift Station 65 1881 Virginia Ave Clearwater	Cat DG60-2 CAT0DG60LT3700728	57 KW	Natural Gas	N/A				Yes ESC	
ATS	Asco 150 Amp 3 ph. Open transition	D03ATSA30150FGXH 1118634	240 Volt 3 Pole NEMA 4X							