



December 27, 2023

Jeff Walker, P.E. CBO, LEED AP, PMP  
Sr. Professional Engineer  
City of Clearwater Dept. of Public Works  
1501 N. Belcher Rd.  
Clearwater, FL

RE: The Long Center Natatorium Life Cycle Analysis

Mr. Walker

WJ Architects has completed the Life Cycle Analysis associated with The Long Center Natatorium. Our process and findings are described in the following pages and documents.

Should there be any question regarding this study please don't hesitate to contact Arturo Lopez via email at [Arturo.lopez@wjarc.com](mailto:Arturo.lopez@wjarc.com) or by phone at 727.308.2432. We look forward to working with you again in the future on this project or other projects.

Respectfully Submitted,

WJ Architects

A handwritten signature in black ink, appearing to read 'Arturo', is written over a faint, larger version of the signature.

Arturo D. Lopez AIA  
Studio Director / Project Manager

## **Table of Contents**

<b>Project Summary &amp; Findings</b>	<b>3</b>
---------------------------------------	----------

<b>Appendix</b>	<b>4</b>
-----------------	----------

1. Design Options
2. Cost Estimates
  - a. Construction Consultants & Associates Cost Estimate
  - b. WJ Create Cost Estimate
3. Non Destructive Evaluation testing
4. Energy Model Analysis
5. 30 Yr. HVAC Cost Comparison

### **Project Information & Intent**

The Long Center Natatorium is in the City of Clearwater at 1501 N Belcher Rd. it houses two swimming pools that are used for community events and swim competitions. The building is a single-story structure, composed of an exposed steel and single pane window system envelope along the north,

## **Project Information & Intent**

The Long Center Natatorium is in the City of Clearwater at 1501 N Belcher Rd. it houses two swimming pools that are used for community events and swim competitions. The building is a single-story structure, composed of an exposed steel and single pane window system envelope along the north, west, and east facades. The south wall of the natatorium is an interior wall separating the natatorium from office space and other interior spaces. It's estimated that the natatorium is approximately 30 years old, because of its age, design, and exposure to the chemicals associated with maintaining the pools the natatorium has experienced significant structural decay, is expensive to operate, and is unable to provide a comfortable environment or pleasant experience for the public it serves. The Long Center Natatorium is in need of significant repairs and renovations to all of its major building systems and components.

The City of Clearwater has hired WJ Architects to provide a life cycle cost analysis that includes two design options for renovating the natatorium. The life cycle cost analysis will help the city decide on the most cost effective and energy efficient approach for renovating the natatorium. The goal of the life cycle analysis is to identify the energy use, operating cost, maintenance cost and total budget cost associated with each design option. It's expected that the city will then use this information to select a path forward for renovating the Long Center Natatorium.

## **Process**

WJ Architects designed two renovation options for the natatorium that are described as follows; Option one keeps the intent of the original design by maintaining the "Glass Box" concept, meaning the amount of glazing is maximized along the exterior perimeter of the natatorium. Option two, looks to improve the energy efficiency of the natatorium by reducing the amount of glazing along the perimeter of the building. Both design options included replacement and upgrades to building systems and components including HVAC systems, photovoltaic panels, roofing, structural repairs, and pool equipment. Each design option was modeled in 3D and organized into a set of documents that was presented to our team of estimators for pricing. Our 3D models we're also used to create energy analysis models that revealed the impact of reducing the glazing and the efficiency of the natatoriums . We finalized our analysis by performing a non-destructive evaluation (NDE) of steel the structure of the building via a specialty scanner that can determine the thickness of each steel member. Through comparative analysis, a determination was made on whether each steel member required repair or replacement. A report is provided herein that identifies said structural members.

## **Findings**

Upon completion of our energy analysis, and cost estimates it was determined that option two, "the less glazing option" would be more cost effective to build and ten to fifteen percent more energy efficient than option one, the "Glass Box Option". This conclusion is based on the following factors:

1. Design
  - a. The difference between the two design options is limited to the area of glazing and exterior wall surface area, with option one having a larger surface area of glazing and less wall surface area of wall, and option two having a smaller surface area of glazing and larger exterior wall surface area.

- b. The HVAC system in both design options is the same size and configuration. This is because the HVAC load for the building is determined by the latent heat created by maintaining the pool temperature not the heat gained through the fenestration.

2. Cost

- a. The 30yr cost associated with the mechanical system in option two is 10% - 15% less expensive. This analysis factors installation cost, energy use, maintenance, and replacement cost. Energy use is the driving factor in this analysis with option two being more energy efficient.
- b. The overall estimated construction cost for the project is identified as less expensive for option two by both cost estimators estimating the cost of the project.
- c. Here are the total sums provided by each estimator

- i. CC&A – Price Estimate for Renovation Option Two

1. Renovation Cost:	\$12,882,358
a. Includes pool equipment UV system upgrade.	
b. Includes \$300,000 Allowance for PV panels.	
2. Sun Deck Addition:	\$ 479,379
<b>3. Total</b>	<b>\$ 13,361,737</b>
a. Pool equipment replacement not included.	

- ii. WJ Create – Price Estimate for Renovation Option Two

1. Renovation Cost:	\$ 9,242,362
a. Includes pool equipment UV System upgrade.	
b. Includes \$468,000 allowance for PV panels.	
2. Sun Deck Addition:	\$ 759,939
<b>3. Total</b>	<b>\$ 10,002,301</b>
a. Pool equipment replacement not included	

- iii. Pool Equipment Total Replacement: \$ 1,092,520

3. Performance

- a. The energy model revealed that option 2 uses about 10% - 15% less energy than option one.

## Appendix

# LONG CENTER NATATORIUM OPTION 1

1501 N BELCHER RD. CLEARWATER FL, 33765



Wannemacher Jensen  
**Architects, Inc.**

132 Mirror Lake Drive N. Unit 301, St. Petersburg,  
Florida 33701-3214  
AA0002277

STRUCTURAL ENGINEER  
**McKim & Creed**

1365 Hamlet Ave. Clearwater, FL. 33756

MEP & FP ENGINEER  
**Emerald Engineering**

9942 Currie Davis Dr. Ste H. Tampa, FL. 33619

SWIMMING POOL ENGINEER  
**Councilman Hunsaker**

3636 Geyer Rd, Suite 100, St. Louis, MO. 63127

## MILESTONE HERE

No.	Description	Date
	SCHEMATIC BID SET	10.23.23


PREPARED FOR:  
**City of Clearwater**

**X** \_\_\_\_\_  
CLIENT SIGNATURE AUTHORIZING PRODUCTION DOCUMENTS TO PROCEED INTO NEXT PHASE      DATE










1 DEMOLITION ROOF PLAN  
3/32" = 1'-0"

**DEMOLITION KEY NOTES**

TAG	NOTE
D003	DEMOLISH ROOF SYSTEM DOWN TO DECK.
D004	DEMOLISH EXISTING ROOF CURB ENTIRELY.
D005	REFER TO MECHANICAL ENGINEERS' DWGS. FOR DEMOLITION OF MECHANICAL EQUIPMENT & COMPONENTS.
D018	EXISTING METAL DECK TO BE CUT OUT TO PROVIDE ACCESS FOR DUCTWORK.



THE ARCHITECTS SHALL BE RESPONSIBLE FOR THE PROTECTION OF ALL UTILITIES AND OTHER PROPERTY RIGHTS AND ARE NOT RESPONSIBLE FOR THE PROTECTION OF ANY UTILITIES OR OTHER PROPERTY RIGHTS NOT SHOWN ON THE RECORD DRAWINGS. THE ARCHITECTS SHALL NOT BE RESPONSIBLE FOR THE PROTECTION OF ANY UTILITIES OR OTHER PROPERTY RIGHTS NOT SHOWN ON THE RECORD DRAWINGS. THE ARCHITECTS SHALL NOT BE RESPONSIBLE FOR THE PROTECTION OF ANY UTILITIES OR OTHER PROPERTY RIGHTS NOT SHOWN ON THE RECORD DRAWINGS. THE ARCHITECTS SHALL NOT BE RESPONSIBLE FOR THE PROTECTION OF ANY UTILITIES OR OTHER PROPERTY RIGHTS NOT SHOWN ON THE RECORD DRAWINGS.

PRELIMINARY NOT FOR CONSTRUCTION

**LONG CENTER NATATORIUM**

CITY OF CLEARWATER  
 1501 N BELCHER RD. CLEARWATER FL. 33765


Project number	0000
DISTRIBUTION	
MILESTONE	DATE
SCHEMATIC BID SET	10.23.23

DEMO ROOF PLAN


AD-302

**DEMOLITION KEY NOTES**


TAG	NOTE
D011	DEMOLISH GLAZING SYSTEM ENTIRELY, STEEL STRUCTURE TO REMAIN.



**1 DEMOLITION ELEVATION - EAST**  
1/8" = 1'-0"



**2 DEMOLITION ELEVATION - NORTH**  
1/8" = 1'-0"



THE ARCHITECTS AND ENGINEERS HEREBY DISCLAIM ANY LIABILITY FOR ANY AND ALL DAMAGES, INCLUDING REASONABLE ATTORNEY'S FEES, THAT MAY BE INCURRED BY ANY PARTY AS A RESULT OF THE USE OF THESE DRAWINGS. THE ARCHITECTS AND ENGINEERS SHALL NOT BE RESPONSIBLE FOR ANY CONSTRUCTION DEFECTS OR OMISSIONS THAT MAY BE THE RESULT OF THE USE OF THESE DRAWINGS WITHOUT FIRST OBTAINING THE ARCHITECTS AND ENGINEERS' WRITTEN CONSENT. THE ARCHITECTS AND ENGINEERS SHALL NOT BE RESPONSIBLE FOR ANY CONSTRUCTION DEFECTS OR OMISSIONS THAT MAY BE THE RESULT OF THE USE OF THESE DRAWINGS WITHOUT FIRST OBTAINING THE ARCHITECTS AND ENGINEERS' WRITTEN CONSENT. THE ARCHITECTS AND ENGINEERS SHALL NOT BE RESPONSIBLE FOR ANY CONSTRUCTION DEFECTS OR OMISSIONS THAT MAY BE THE RESULT OF THE USE OF THESE DRAWINGS WITHOUT FIRST OBTAINING THE ARCHITECTS AND ENGINEERS' WRITTEN CONSENT.

**PRELIMINARY NOT FOR CONSTRUCTION**

**LONG CENTER NATATORIUM**

CITY OF CLEARWATER  
1501 N BELCHER RD. CLEARWATER FL. 33765


Project number  
**0000**

DISTRIBUTION


MILESTONE	DATE
SCHEMATIC BID SET	10.23.23

DEMO EXTERIOR ELEVATIONS

**AD-303**



1 DEMOLITION ELEVATION - WEST  
1/8" = 1'-0"



PRELIMINARY NOT FOR CONSTRUCTION

LONG CENTER NATATORIUM

CITY OF CLEARWATER  
1501 N BELCHER RD. CLEARWATER FL. 33765

Project number  
0000

DISTRIBUTION  
MILESTONE DATE  
SCHEMATIC BID SET 10.23.23

DEMO EXTERIOR  
ELEVATIONS

AD-304

THE ARCHITECTS AND ENGINEERS HEREBY DISCLAIM ANY LIABILITY FOR ANY AND ALL DAMAGES, INCLUDING BUT NOT LIMITED TO, SPECIAL DAMAGES, CONSEQUENTIAL DAMAGES, AND PUNITIVE DAMAGES, ARISING FROM OR OUT OF THE USE OF ANY INFORMATION CONTAINED HEREIN, WHETHER SUCH DAMAGES ARE FORESEEN OR NOT, AND WHETHER SUCH DAMAGES ARE CAUSED IN WHOLE OR IN PART BY THE NEGLIGENCE OF THE ARCHITECTS AND ENGINEERS OR BY THE NEGLIGENCE OF ANY OTHER PARTY WITHOUT FIRST OBTAINING THE WRITTEN CONSENT OF THE ARCHITECTS AND ENGINEERS. THE ARCHITECTS AND ENGINEERS SHALL NOT BE RESPONSIBLE FOR ANY DAMAGES, INCLUDING BUT NOT LIMITED TO, SPECIAL DAMAGES, CONSEQUENTIAL DAMAGES, AND PUNITIVE DAMAGES, ARISING FROM OR OUT OF THE USE OF ANY INFORMATION CONTAINED HEREIN, WHETHER SUCH DAMAGES ARE FORESEEN OR NOT, AND WHETHER SUCH DAMAGES ARE CAUSED IN WHOLE OR IN PART BY THE NEGLIGENCE OF THE ARCHITECTS AND ENGINEERS OR BY THE NEGLIGENCE OF ANY OTHER PARTY WITHOUT FIRST OBTAINING THE WRITTEN CONSENT OF THE ARCHITECTS AND ENGINEERS. THE ARCHITECTS AND ENGINEERS SHALL NOT BE RESPONSIBLE FOR ANY DAMAGES, INCLUDING BUT NOT LIMITED TO, SPECIAL DAMAGES, CONSEQUENTIAL DAMAGES, AND PUNITIVE DAMAGES, ARISING FROM OR OUT OF THE USE OF ANY INFORMATION CONTAINED HEREIN, WHETHER SUCH DAMAGES ARE FORESEEN OR NOT, AND WHETHER SUCH DAMAGES ARE CAUSED IN WHOLE OR IN PART BY THE NEGLIGENCE OF THE ARCHITECTS AND ENGINEERS OR BY THE NEGLIGENCE OF ANY OTHER PARTY WITHOUT FIRST OBTAINING THE WRITTEN CONSENT OF THE ARCHITECTS AND ENGINEERS.



**Wannemacher Jensen Architects, Inc.**  
132 Mirror Lake Drive N, Unit 301  
St. Petersburg, Florida 33701-3214  
www.wjarc.com  
(727) 822-5566  
AF9424  
©Wannemacher Jensen Architects, Inc.

DESIGN CRITERIA


ROOF: 60 MIL TPO SINGLE PLY MEMBRANE  
 INSULATION: ROOF IS R-20 MIN POLYISO RIGID INSULATION  
 CURTAIN WALL: YKK - YHC 300 OG IMPACT RESISTANT SYSTEM  
 GLAZING: 1-1/4" INSULATED LOW E GLAZING, IMPACT RESISTANT  
 OPAQUE WALLS: METAL STUD WALLS  
 FIBERGLASS BATT INSULATION R-19 + 1" RIGID INSULATION  
 5/8" MOISTURE RESISTANT GYPSUM BOARD  
 EXISTING STRUCTURE: REPAIRED AS NEEDED, PER STRUCTURAL.  
 SAND AND PAINT  
 PAINT COLOR BY ARCHITECT.  
 POOL TRENCH DRAIN: NATURE CORPORATION GMP GRATING  
 POOL DECK COATING: ARMORTRAK FLEXIBLE MILITARY GRADE URETHANE COATING

**Wannemacher Jensen Architects, Inc.**  
 132 Mirror Lake Drive N, Unit 301  
 St. Petersburg, Florida 33701-3214  
 (727) 822-5566  
 www.wjarc.com  
 AF94244  
 ©Wannemacher Jensen Architects, Inc.

THE ARCHITECTS SHALL BE RESPONSIBLE FOR THE PRELIMINARY DESIGN AND CONSTRUCTION OF THE PROJECT. THE ARCHITECTS SHALL NOT BE RESPONSIBLE FOR THE PERFORMANCE OF THE PROJECT OR THE RESULTS THEREOF. THE ARCHITECTS SHALL NOT BE RESPONSIBLE FOR THE PERFORMANCE OF THE PROJECT OR THE RESULTS THEREOF. THE ARCHITECTS SHALL NOT BE RESPONSIBLE FOR THE PERFORMANCE OF THE PROJECT OR THE RESULTS THEREOF.



1 OPT - 1 3D VIEW -1



2 OPT - 1 3D VIEW -2

PRELIMINARY NOT FOR CONSTRUCTION

LONG CENTER NATATORIUM

CITY OF CLEARWATER  
 1501 N BELCHER RD, CLEARWATER FL, 33765

Project number	0000
DISTRIBUTION	
MILESTONE	DATE
SCHEMATIC BID SET	10.23.23

3D VIEWS\_OPT 1

A-002



EXTERIOR RENDER - WEST - NORTH



EXTERIOR RENDER - EAST



INTERIOR RENDER - VIEW 1




INTERIOR RENDER - VIEW 2




EXTERIOR RENDER - NORTH

THE ARCHITECTS AND ENGINEERS HAVE PREPARED THESE PRELIMINARY ARCHITECTURAL RENDERINGS AND SPECIFICATIONS FOR THE ARCHITECT'S INFORMATION ONLY. THE ARCHITECTS AND ENGINEERS MAKE NO WARRANTY, EXPRESS OR IMPLIED, AS TO THE ACCURACY, COMPLETENESS, OR RELIABILITY OF THE INFORMATION PROVIDED HEREIN. THE ARCHITECTS AND ENGINEERS SHALL NOT BE RESPONSIBLE FOR ANY ERRORS OR OMISSIONS IN THESE PRELIMINARY ARCHITECTURAL RENDERINGS AND SPECIFICATIONS. THE ARCHITECTS AND ENGINEERS SHALL NOT BE RESPONSIBLE FOR ANY CONSTRUCTION DEFECTS OR OMISSIONS IN THESE PRELIMINARY ARCHITECTURAL RENDERINGS AND SPECIFICATIONS. THE ARCHITECTS AND ENGINEERS SHALL NOT BE RESPONSIBLE FOR ANY DELAYS OR DISRUPTIONS IN THE CONSTRUCTION OF THE PROJECT. THE ARCHITECTS AND ENGINEERS SHALL NOT BE RESPONSIBLE FOR ANY INJURY OR DAMAGE TO PERSONS OR PROPERTY. THE ARCHITECTS AND ENGINEERS SHALL NOT BE RESPONSIBLE FOR ANY VIOLATION OF ANY APPLICABLE LAWS OR REGULATIONS. THE ARCHITECTS AND ENGINEERS SHALL NOT BE RESPONSIBLE FOR ANY OTHER MATTERS NOT EXPRESSLY STATED HEREIN.






2 OPT 1 - DETAIL - TYPICAL TPO ROOF ASSEMBLY  
1 1/2" = 1'-0"



3 OPT 1 - TYP. NORTH ROOF EDGE  
1" = 1'-0"




1 OPT 1 - ROOF PLAN  
3/32" = 1'-0"

GENERAL NOTES

- ROOFING PRODUCT BASIS-OF-DESIGN: 60 MIL TPO SINGLE PLY MEMBRANE ROOF OR APPROVED EQUAL (COLOR WHITE) RIGID INSULATION BOARD MECHANICALLY FASTENED TO STEEL ROOF DECK. INSULATION TO HAVE AN AVERAGE R-20 @ ALL ROOFS OVER CONDITIONED SPACES. PROVIDE ROOFING COMPONENTS AND MATERIALS APPROVED BY THE ROOFING PRODUCT MANUFACTURER. ASSEMBLE ROOFING COMPONENTS INCLUDING FLASHING, ROOF DRAINS, ETC. PER THE ROOFING PRODUCT MANUFACTURER'S DETAILS AND INSTRUCTIONS SO AS TO QUALIFY FOR, AND RECEIVE A SPECIAL 20-YEAR WEATHER-TIGHTNESS WARRANTY FROM THE MANUFACTURER AS WELL AS A SPECIAL 2-YEAR PROJECT WARRANTY FROM THE ROOFING INSTALLER COVERING ALL COMPONENTS OF THE ROOFING SYSTEM SUCH AS ROOFING, BASE FLASHING, ROOF INSULATION, FASTENERS, COVER BOARDS, ETC. PROVIDE ROOFING FROM A QUALIFIED MANUFACTURER THAT IS FM GLOBAL APPROVED FOR ROOFING SYSTEM IDENTICAL TO THAT USED FOR THIS PROJECT.
- PROVIDE METAL ROOF COPINGS AND PARAPET FASCIAS FABRICATED OF ASTM B209 0.050-INCH ALUMINUM SHEET, COMPLY WITH "THE NRCA ROOFING MANUAL" AND THE SMACNA "ARCHITECTURAL SHEET METAL MANUAL REQUIREMENTS FOR DIMENSIONS AND PROFILES SHOWN UNLESS MORE STRINGENT REQUIREMENTS ARE INDICATED. PROVIDE MANUFACTURER'S 20-YEAR FINISH WARRANTY. SECURE COPINGS TO PARAPETS WITH CONT ALUMINUM CLEATS.
- PROVIDE GALVANIZED STEEL INTERNALLY REINFORCED ROOF-CURB UNITS CAPABLE OF SUPPORTING SUPERIMPOSED LIVE AND DEAD LOADS, INCLUDING EQUIPMENT LOADS, WITH WELDED OR MECHANICALLY FASTENED, NON-SAG SEALED JOINTS AND INTEGRALLY FORMED DECK-MOUNTING FLANGE AT PERIMETER BOTTOM. COORDINATE DIMENSIONS WITH ROUGHING-IN INFORMATION ON SHOP DRAWINGS OF EQUIPMENT TO BE SUPPORTED.
- ROOF DRAIN BASIS-OF-DESIGN: Z125 8 3/8" DIAMETER ROOF DRAIN WITH LOW SILHOUETTE DOME MANUFACTURED BY ZURN INDUSTRIES.
- GENERAL - IT IS THE INTENT OF THE CONTRACT DOCUMENTS TO PROVIDE FOR A COMPLETE AND WEATHERTIGHT INSTALLATION OF ALL ROOF ITEMS, PENETRATIONS, ETC. THE CONTRACTOR SHALL PROVIDE ALL ROOF ACCESSORIES, FLASHING, SEALANT, SCUPPERS, DRAINS, LABOR, MATERIALS, EQUIPMENT, ETC. REQUIRED FOR COMPLETION OF A WEATHERTIGHT ROOF INSTALLATION. FOLLOW ALL RECOMMENDATIONS OF THE NRCA REGARDING INSTALLATION PROCEDURES, UNLESS MORE STRINGENT REQUIREMENTS ARE INDICATED.
- SLOPE - ROOF SURFACE SHALL HAVE A MINIMUM SLOPE OF 1/4" PER FOOT IN A PERPENDICULAR DIRECTION FROM THE ROOF EDGE DOWN TOWARD THE ROOF DRAINS AS INDICATED BY THE ARROWS DRAWN ON THE ROOF PLAN. WHERE REQUIRED TO FACILITATE DRAINAGE, PROVIDE VALLEYS, CRICKETS, RIDGES, ETC. OF REQUIRED SLOPE TO PROPERLY DRAIN ALL ROOF SURFACES.
- ROOF DRAINS - COORDINATE LOCATION OF ALL ROOF DRAINS TO AVOID RATED WALLS, BEAMS, COLUMNS, JOISTS, ETC. BELOW.
- PENETRATIONS - PROPERLY FLASH, WATERPROOF, SECURE AND SEAL ALL ITEMS THAT PENETRATE THE ROOF MEMBRANE. DO NOT INSTALL ANY PITCH POCKETS. FOLLOW GUIDELINES OF NRCA CONCERNING FLASHING AND WATERPROOFING ALL ROOF PENETRATIONS. SEE ROOF DETAILS.
- ROOF EQUIPMENT - MOUNT ALL ROOF EQUIPMENT ON PREFABRICATED EQUIPMENT SUPPORT CURBS WITH INTEGRAL INSULATION. WHERE EQUIPMENT IS RAISED ABOVE ROOF SURFACE, ALIGN SUPPORTS PARALLEL TO DIRECTION OF WATERFLOW TO FACILITATE DRAINAGE. VERIFY ALL REQUIREMENTS WITH EQUIPMENT AND CURB MANUFACTURERS. WHERE ROOF MEMBRANE EXTENDS BENEATH EQUIPMENT, MOUNT EQUIPMENT ABOVE THE ROOF SURFACE IN ACCORDANCE WITH BUILDING CODE AND NRCA REQUIREMENTS TO ALLOW FOR INSTALLATION OF ALL REQUIRED ROOFING COMPONENTS AND TO ALLOW FOR FUTURE OWNER MAINTENANCE.
- LIGHTNING PROTECTION - REFER TO ELECTRICAL DRAWINGS PROTECTION FOR ALL LIGHTNING PROTECTION. GROUNDING RODS, CABLES, CONNECTIONS, ETC. SHALL BE INSTALLED IN SUCH A MANNER TO PREVENT ANY DAMAGE TO INSTALLED ROOF MEMBRANE. GROUNDING RODS SHALL BE FASTENED TO THE SUBSTRATE ON WHICH THEY ARE MOUNTED. PROVIDE ALL REQUIRED FLASHING, SEALANT, WATERPROOFING, NON-CORROSIVE FASTENERS, ETC. AT EACH LOCATION AND AT MEMBRANE PENETRATION POINTS.

SPECIFIC NOTES

TAG	NOTE
EL12	LOUVERED ROOF EQUIPMENT SCREEN WALL, HEIGHT TO BE DETERMINED.
RN01	60 MIL SINGLE PLY TPO ROOF MEMBRANE.
RN02	12" ROOF EXTENSION, REFER TO SECTION DETAIL.
RN03	TOP OF TRUSS BELOW.
RN05	PHOTOVOLTAIC ARRAY.
RN06	ALUMINUM SUNSHADES BY CURTAIN WALL MANUFACTURER.
RN07	PROVIDE STEEL SUPPORT FRAMES FOR DUCT WORK @ 48" O.C.
RN08	LOUVERED ROOF EQUIPMENT SCREEN WALL, HEIGHT TO BE DETERMINED.



THESE DOCUMENTS ARE PRELIMINARY AND NOT TO BE USED FOR CONSTRUCTION. ANY CHANGES TO THESE DOCUMENTS SHALL BE MADE BY THE ARCHITECT. THE ARCHITECT SHALL NOT BE RESPONSIBLE FOR ANY ERRORS OR OMISSIONS IN THESE DOCUMENTS. THE ARCHITECT'S LIABILITY IS LIMITED TO THE DESIGN AND CONSTRUCTION OF THE PROJECT. THE ARCHITECT'S LIABILITY SHALL NOT BE EXTENDED TO ANY OTHER MATTER. THE ARCHITECT'S LIABILITY SHALL NOT BE EXTENDED TO ANY OTHER MATTER. THE ARCHITECT'S LIABILITY SHALL NOT BE EXTENDED TO ANY OTHER MATTER.

PRELIMINARY NOT FOR CONSTRUCTION

**LONG CENTER NATATORIUM**  
CITY OF CLEARWATER  
1501 N BELCHER RD. CLEARWATER FL. 33765

Project number  
**0000**  
DISTRIBUTION

MILESTONE	DATE
SCHEMATIC BID SET	10.23.23

ROOF PLAN\_OPT 1

**GENERAL NOTES:**

1. EXISTING STEEL STRUCTURE TO BE REPAIRED PER STRUCTURAL DRAWINGS.
2. EXISTING STEEL STRUCTURE TO BE SANDED AND PAINTED ENTIRELY.
3. EXISTING INTERIOR LIGHTING TO REMAIN.
4. LIGHTING SCOPE LIMITED TO EXTERIOR LIGHT FIXTURES MOUNTED TO FACE OF TRUSS FRAMES.
5. VERIFY LOCATIONS OF ALL LIGHT FIXTURES, AIR SLOTS, AIR SUPPLY AND RETURN GRILLES WITH PLANS AND COORDINATE INSTALLATION WITH MECHANICAL AND ELECTRICAL CONTRACTORS. NOTIFY ARCHITECT OF ANY CONFLICTS PRIOR TO INSTALLATION.
6. PAINT ALL MECHANICAL SLOTS, GRILLES, OR ACCESS PANELS TO MATCH SURFACE ON WHICH THEY OCCUR, UNLESS OTHERWISE NOTED.
7. CONTRACTOR IS TO PROVIDE ALL MISCELLANEOUS MTL STUD FRAMING REQUIRED FOR SOFFITS AND BULKHEADS AS GRAPHICALLY DEPICTED ON THE REFLECTED CEILING PLAN, SECTIONS AND ELEVATIONS.
8. PAINT ALL EXPOSED STEEL STRUCTURE AND ALL OTHER EXPOSED SURFACES THAT ARE NOT PREFINISHED OR INTEGRALLY COLORED EXCEPT IN CONCEALED SPACES INCLUDING MECHANICAL ROOMS, JANITOR CLOSETS, AND ELECTRICAL ROOMS.
9. PROVIDE CARE AND COORDINATION TO CONCEAL ALL CONDUIT, FIRE PROTECTION PIPING, AND PLUMBING.
10. ALL LIGHTING IS DEPICTED TO INDICATE LOCATION ONLY, SEE ELECTRICAL FOR FIXTURE SPECIFICATIONS, NOTIFY ARCHITECT OF ANY DISCREPANCIES.
11. AT ALL EXPOSED METAL DECK LOCATIONS UTILIZE WEDGE BOLT/NET SYSTEM TO HANG ALL SYSTEMS.


**CEILING FIXTURE LEGEND**

**CEILING MATERIAL LEGEND**


■ EXPOSED DECK TO BE REPAINTED, STRUCTURAL STEEL TO BE REPAIRED, SAND BLASTED AND PAINTED. SEE STRUCTURAL FOR REPAIRS

**SPECIFIC NOTES**

TAG	NOTE
A201	SIDEWALL MOUNTED BIG ASS FAN, ADJUSTABLE PIVOT FAN*
A205	SAND AND PAINT ALL EXISTING STEEL*
A206	EXISTING CEILING LIGHTING AND FIXTURES TO REMAIN. COVER AND PROTECT WHILE PERFORMING NEW WORK.



**1 LEVEL 1 - REFLECTED CEILING PLAN**  
3/32" = 1'-0"



THE ARCHITECT'S DRAWINGS AND SPECIFICATIONS ARE PREPARED BY THE ARCHITECT AND ARE TO BE USED ONLY FOR THE PROJECT AND SPECIFICATIONS INDICATED THEREON. THE ARCHITECT DOES NOT WARRANT OR GUARANTEE THE ACCURACY OF ANY INFORMATION PROVIDED BY ANY OTHER PARTY WITHOUT FIRST OBTAINING THE ARCHITECT'S CONSENT TO THEIR SERVICE TO THE PROJECT. THE ARCHITECT'S LIABILITY IS LIMITED TO THE OBLIGATION TO PROVIDE PROFESSIONAL SERVICES IN ACCORDANCE WITH THE PROFESSIONAL STANDARDS OF CARE AND THE ETHICS OF THE ARCHITECTURAL PROFESSION. THE ARCHITECT SHALL NOT BE RESPONSIBLE FOR ANY CONSTRUCTION DEFECTS OR OMISSIONS THAT MAY BE CAUSED BY THE CONTRACTOR OR OTHER PARTY. THE ARCHITECT'S LIABILITY IS LIMITED TO THE OBLIGATION TO PROVIDE PROFESSIONAL SERVICES IN ACCORDANCE WITH THE PROFESSIONAL STANDARDS OF CARE AND THE ETHICS OF THE ARCHITECTURAL PROFESSION.

PRELIMINARY NOT FOR CONSTRUCTION

LONG CENTER NATATORIUM


CITY OF CLEARWATER  
1501 N BELCHER RD. CLEARWATER FL. 33765

Project number	0000
DISTRIBUTION	
MILESTONE	DATE
SCHEMATIC BID SET	10.23.23

REFLECTED CEILING PLAN

**A-201**





1 OPT 1 - WEST ELEVATION  
1/8" = 1'-0"


SPECIFIC KEYNOTES - ELEVATIONS	
NUMBER	TEXT

**SPECIFIC NOTES**


- |      |   |
|------|---|
| TAG  | NOTE  |
| EL02 | TWO PIECE PRE FINISHED ALUMINUM ROOF FASCIA.                  |
| EL06 | EXTERIOR LIGHT FIXTURE  |
| EL07 | ALUMINUM SUNSHADES BY CURTAIN WALL MANUFACTURER               |
| EL08 | CROWN SST-II HYDRAULIC BI-FOLD DOOR SYSTEM.                   |
| EL10 | VENTS FOR NATURAL VENTILATION.                                |
| EL12 | LOUVERED ROOF EQUIPMENT SCREEN WALL, HEIGHT TO BE DETERMINED. |
| G01  | 1-1/4" INSULATED, IMPACT RESISTANT SAFETY GLAZING.            |

THESE DRAWINGS ARE PRELIMINARY AND NOT TO BE USED FOR CONSTRUCTION. ANY CHANGES TO THESE DRAWINGS SHALL BE APPROVED BY THE ARCHITECT. THE ARCHITECT SHALL NOT BE RESPONSIBLE FOR THE ACCURACY OF THE INFORMATION PROVIDED HEREIN. THE ARCHITECT'S LIABILITY IS LIMITED TO THE DESIGN AND CONSTRUCTION OF THE PROJECT. THE ARCHITECT'S LIABILITY IS LIMITED TO THE DESIGN AND CONSTRUCTION OF THE PROJECT. THE ARCHITECT'S LIABILITY IS LIMITED TO THE DESIGN AND CONSTRUCTION OF THE PROJECT.


**Wannemacher Jensen Architects, Inc.**  
132 Mirror Lake Drive N, Unit 301  
St. Petersburg, Florida 33701-3214  
www.wjarc.com  
(727) 822-5566  
AR94244  
©Wannemacher Jensen Architects, Inc.




2 OPT 1 - CURTAIN WALL ELEVATION - WEST  
1/8" = 1'-0"



3 OPT 1 - CURTAIN WALL ELEVATIONS - EAST  
1/8" = 1'-0"



4 OPT 1 - CURTAIN WALL ELEVATIONS - NORTH  
1/8" = 1'-0"



PRELIMINARY NOT FOR CONSTRUCTION

**LONG CENTER NATATORIUM**

CITY OF CLEARWATER  
1501 N BELCHER RD. CLEARWATER FL. 33765

Project number  
**0000**  
DISTRIBUTION


MILESTONE DATE  
SCHEMATIC BID SET 10.23.23

EXTERIOR  
ELEVATIONS\_OPT 1


**A-304**

**SPECIFIC NOTES**


- |      |  |
|------|--|
| TAG  | NOTE   |
| EL01 | THREE PART STUCCO SYSTEM OVER LATH & WEATHERPROOFING                     |
| EL02 | TWO PIECE PRE FINISHED ALUMINUM ROOF FASCIA.                             |
| EL06 | EXTERIOR LIGHT FIXTURE   |
| EL10 | VENTS FOR NATURAL VENTILATION.   |
| EL11 | EXISTING MASONRY BASE TO BE CLEANED AND REPOINTED AS NEEDED.             |
| PN10 | EXISTING BEAM ABOVE.   |
| WS01 | 3 5/8" METAL STUDS FASTENED TO EXISTING TRUSS FRAME @ 16" O.C.           |
| WS04 | FRAMING CLIP @ EVERY HORIZONTAL HSS MEMBER OR 24" O.C. VERTICALLY.       |
| WS05 | THREE PART STUCCO SYSTEM OVER LATH & WEATHERPROOFING, SAND FINISH - PTD. |
| WS06 | EXISTING MASONRY WALL BASE TO REMAIN.                                    |
| WS07 | FILL CAVITY WITH R-19 INSULATION, TYP.                                   |
| WS24 | VENTS FOR NATURAL VENTILATION.   |
| WS26 | STEEL FRAME TRUSS TO BE SANDBLASTED & REPAINTED, TYP.                    |
| WS31 | 5/8" THK WATER RESISTANT GYPSUM BOARD.                                   |




1 OPT 1 - ENLARGED PLAN @ TRUSS  
1/4" = 1'-0"



2 OPT 1 - SECTION @ TRUSS FRAME  
1/2" = 1'-0"



3 OPT 1 - TRUSS NORTH ELEVATION  
1/2" = 1'-0"







4 OPT 1 - TRUSS SIDE ELEVATION  
1/2" = 1'-0"

THE ARCHITECTS SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND OTHER AGENCIES APPROVALS AND FOR VERIFYING ALL REGULATORY REQUIREMENTS AND SPECIFICATIONS. THE ARCHITECTS SHALL NOT BE RESPONSIBLE FOR ANY DELAYS OR COSTS INCURRED BY THE CLIENT OR CONTRACTOR WITHOUT FIRST OBTAINING THE ARCHITECTS' WRITTEN CONSENT. THE ARCHITECTS SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND OTHER AGENCIES APPROVALS AND FOR VERIFYING ALL REGULATORY REQUIREMENTS AND SPECIFICATIONS. THE ARCHITECTS SHALL NOT BE RESPONSIBLE FOR ANY DELAYS OR COSTS INCURRED BY THE CLIENT OR CONTRACTOR WITHOUT FIRST OBTAINING THE ARCHITECTS' WRITTEN CONSENT.

**SPECIFIC NOTES**

- |      |  |
|------|--|
| TAG  | NOTE   |
| EL02 | TWO PIECE PRE FINISHED ALUMINUM ROOF FASCIA.                                   |
| EL03 | FIBER CEMENT SIDING, PTD.  |
| EL07 | TWO PIECE ROOF EDGE FASCIA, PRE-FINISHED.                                      |
| EL09 | ALUMINUM SUNSHADES BY CURTAIN WALL MANUFACTURER                                |
| PN01 | CNC CUT ALUMINUM STANDOFF BUILDING SIGNAGE, BACKLIT.                           |
| PN03 | FACE OF WALL BELOW.  |
| PN04 | HVAC LOUVER  |
| WS03 | EXISTING STEEL TO BE REPAIRED AS NEEDED, SAND & REPAINT SPECIFIED REPAIRS.     |
| WS06 | EXISTING MASONRY WALL BASE TO REMAIN.  |
| WS07 | FILL CAVITY WITH R-19 INSULATION, TYP.   |
| WS08 | CONCRETE FDN BY STRUCTURAL.  |
| WS09 | HVAC LOUVER BY HVAC.   |
| WS10 | METAL STUD FRAMING, REFER TO STRUCTURAL.                                       |
| WS12 | COMPACTED FILL.  |
| WS13 | VAPOR BARRIER.   |
| WS14 | EXISTING STEEL TO BE REPAIRED AS NEEDED, REFER TO STRUCTURAL, SANDED & PAINTED |
| WS15 | ROOF CRICKET.  |
| WS16 | REFER TO ROOF PLAN FOR TYPICAL ROOF ASSEMBLY.                                  |
| WS27 | 8" TUBE STEEL BOX FRAME.   |
| WS28 | FILL CAVITY WITH BATT INSULATION R-19.   |
| WS32 | CNC CUT ALUMINUM STANDOFF BUILDING SIGNAGE, BACKLIT.                           |
| WS35 | 1/2" SHEATHING, 1" RIGID INSULATION, STUCCO FINISH.                            |



1 OPT 1 - ENLARGED PLAN @ MECHANICAL CHASE TOWER  
1/4" = 1'-0"

2 OPT 1 - WALL SECTION @ HVAC CHASE  
3/8" = 1'-0"

3 OPT 1 - HVAC CHASE EAST ELEVATION  
3/8" = 1'-0"

4 OPT 1 - HVAC CHASE SOUTH ELEVATION  
3/8" = 1'-0"

THESE DOCUMENTS ARE PRELIMINARY AND NOT BE USED FOR CONSTRUCTION. ANY CHANGES TO THESE DOCUMENTS SHALL BE THE RESPONSIBILITY OF THE ARCHITECT. THE ARCHITECT SHALL NOT BE RESPONSIBLE FOR THE ACCURACY OF ANY INFORMATION NOT PROVIDED BY THE ARCHITECT. THE ARCHITECT'S LIABILITY IS LIMITED TO THE DESIGN AND CONSTRUCTION OF THE PROJECT. THE ARCHITECT SHALL NOT BE RESPONSIBLE FOR THE ACCURACY OF ANY INFORMATION NOT PROVIDED BY THE ARCHITECT. THE ARCHITECT'S LIABILITY IS LIMITED TO THE DESIGN AND CONSTRUCTION OF THE PROJECT.



# LONG CENTER NATATORIUM OPTION 2

1501 N BELCHER RD. CLEARWATER FL, 33765





DESIGN CRITERIA


ROOF: 60 MIL TPO SINGLE PLY MEMBRANE  
 INSULATION: ROOF IS R-20 MIN POLYISO RIGID INSULATION  
 CURTAIN WALL: YKK - YHC 300 OG IMPACT RESISTANT SYSTEM  
 GLAZING: 1-1/4" INSULATED LOW E GLAZING, IMPACT RESISTANT  
 OPAQUE WALLS: METAL STUD WALLS  
 FIBERGLASS BATT INSULATION R-19 + 1" RIGID INSULATION  
 5/8" MOISTURE RESISTANT GYPSUM BOARD  
 EXISTING STRUCTURE: REPAIRED AS NEEDED, PER STRUCTURAL.  
 SAND AND PAINT  
 PAINT: COLOR BY ARCHITECT.  
 POOL TRENCH DRAIN: NATURE CORPORATION GMP GRATING  
 POOL DECK COATING: ARMORTRAK FLEXIBLE MILITARY GRADE URETHANE COATING

**Wannemacher Jensen Architects, Inc.**  
 132 Mirror Lake Drive N, Unit 301  
 St. Petersburg, Florida 33701-3214  
 (727) 822-5566  
 www.wjarc.com  
 AF94244  
 ©Wannemacher Jensen Architects, Inc.

THESE DRAWINGS ARE PRELIMINARY AND NOT TO BE USED FOR CONSTRUCTION. ANY CHANGES TO THESE DRAWINGS SHALL BE THE RESPONSIBILITY OF THE ARCHITECT. THE ARCHITECT DOES NOT WARRANT THE ACCURACY OF THE INFORMATION PROVIDED HEREIN. THE ARCHITECT'S LIABILITY IS LIMITED TO THE DESIGN SERVICES PROVIDED. THE ARCHITECT SHALL NOT BE RESPONSIBLE FOR ANY DELAYS OR DAMAGES TO THE PROJECT OR TO ANY OTHER PARTY WITHOUT FIRST OBTAINING THE WRITTEN CONSENT OF THE ARCHITECT. THE ARCHITECT'S LIABILITY IS LIMITED TO THE DESIGN SERVICES PROVIDED. THE ARCHITECT SHALL NOT BE RESPONSIBLE FOR ANY DELAYS OR DAMAGES TO THE PROJECT OR TO ANY OTHER PARTY WITHOUT FIRST OBTAINING THE WRITTEN CONSENT OF THE ARCHITECT. THE ARCHITECT'S LIABILITY IS LIMITED TO THE DESIGN SERVICES PROVIDED. THE ARCHITECT SHALL NOT BE RESPONSIBLE FOR ANY DELAYS OR DAMAGES TO THE PROJECT OR TO ANY OTHER PARTY WITHOUT FIRST OBTAINING THE WRITTEN CONSENT OF THE ARCHITECT.



1 OPT - 2 3D VIEW -1



2 OPT - 2 3D VIEW -2

PRELIMINARY NOT FOR CONSTRUCTION

LONG CENTER NATATORIUM

CITY OF CLEARWATER

1501 N BELCHER RD. CLEARWATER FL. 33765

Project number	0000
DISTRIBUTION	
MILESTONE	DATE
SCHEMATIC BID SET	10.23.23

3D VIEWS\_OPT 2


A-502



EXTERIOR RENDER - WEST - NORTH



EXTERIOR RENDER - EAST



INTERIOR RENDER - VIEW 1



INTERIOR RENDER - VIEW 2



EXTERIOR RENDER - NORTH

THESE RENDERINGS ARE PRELIMINARY AND NOT TO BE USED FOR CONSTRUCTION. THE ARCHITECT MAKES NO WARRANTY, REPRESENTATION OR GUARANTEE AS TO THE ACCURACY OF THE INFORMATION PROVIDED IN THESE RENDERINGS. THE ARCHITECT SHALL NOT BE RESPONSIBLE FOR ANY ERRORS OR OMISSIONS IN THESE RENDERINGS. THE ARCHITECT'S LIABILITY IS LIMITED TO THE ARCHITECT'S OBLIGATION TO THE CLIENT UNDER THE ARCHITECTURAL AGREEMENT. THE ARCHITECT'S LIABILITY IS LIMITED TO THE ARCHITECT'S OBLIGATION TO THE CLIENT UNDER THE ARCHITECTURAL AGREEMENT. THE ARCHITECT'S LIABILITY IS LIMITED TO THE ARCHITECT'S OBLIGATION TO THE CLIENT UNDER THE ARCHITECTURAL AGREEMENT.


PRELIMINARY NOT FOR CONSTRUCTION

**LONG CENTER NATATORIUM**


CITY OF CLEARWATER  
 1501 N BELCHER RD, CLEARWATER FL, 33765

Project number	0000
DISTRIBUTION	
MILESTONE	DATE
SCHEMATIC BID SET	10.23.23

RENDERINGS OPT\_2



1 OPT 2 - LEVEL 1 - FLOOR PLAN  
3/32" = 1'-0"



**GENERAL NOTES**


- HATCHED AREA NOT INCLUDED IN SCOPE OF WORK UNLESS OTHERWISE NOTED.
- PROVIDE SUPPORT FOR WALL MOUNTED CABINETS AND PLUMBING FIXTURES. STEEL STUDS SUPPORTING WALL MOUNTED FIXTURES TO BE DOUBLED AT 16 O.C. OR NOT LESS THAN 20 GAUGE PER FBC 2517.5.1.1.
- COMBUSTIBLE MATERIALS IN TYPES I & II CONSTRUCTION TO COMPLY WITH FBC 603.1 (FIRE RETARDANT - TREATED WOOD) AND 805.1 & 806.1
- PROVIDE CEMENTITIOUS BACKER BOARD IN PLACE OF GWB AT ALL LOCATIONS SHOWING CERAMIC OR PORCELAIN TILE FINISH.
- SEE SHEET ID100 - ID10X FOR FINISH PLANS.
- SEE SHEET AX.X FOR PLAN DETAIL CALLOUTS.
- SEE SHEET AX.X FOR PARTITION TYPE DETAILS. PROVIDE ACOUSTICAL BATT INSULATION WHERE INDICATED.
- SEE SHEET AX.X FOR DIMENSION PLANS.
- SEE SHEET AX.X FOR DOOR SCHEDULE.
- SEE ENLARGED PLANS FOR ADDITIONAL WALL TAG INFORMATION.

**TAG LEGEND**


<b>ELEMENT TAGS</b>		<b>VIEW TAGS</b>	
Room name	ROOM TAG	Ref	EXTERIOR ELEVATION
101	ROOM TAG	1 Ref	
1001X	DOOR TAG	1 Ref	
<ST-X>	STOREFRONT TAG	1 Ref	
X 6 X 6	WALL TAG	1 Ref	INTERIOR ELEVATION
XXX	SPECIALTY EQUIPMENT TAG	1 Ref	
11	FLOOR TAG	1 Ref	
<b>ANNOTATION TAGS</b>			
ALIGNMENT TAG	ALIGN	1 Ref	SECTION MARK
		1 Ref	
SPECIFIC NOTE TAG	XXX	1 Ref	VIEW CALLOUT
		1 Ref	
		Name	LEVEL HEAD
		Elevation	
		1'-0" A.F.F.	SPOT ELEVATION MARK

**SPECIFIC NOTES**


- | TAG  | NOTE  |
|------|---|
| PN06 | SIDEKICK BIG ASS FAN, PLUG-IN TYPE, PROPELLER STYLE ON WHEELS.          |
| PN07 | PROVIDE NEW POOL EDGE AND TRENCH DRAIN ASSEMBLY TO MATCH TRAINING POOL. |
| PN10 | EXISTING BEAM ABOVE.  |
| PN11 | SAND AND PAINT DOOR FRAMES.   |
| PN12 | REMOVE AND REPLACE POOL ACCESSORIES TO REPLACE POOL EDGE.               |
| PN14 | CROWN SST-II HYDRAULIC BI-FOLD DOOR SYSTEM.                             |
| PN16 | EPOXY DECK COATING THROUGHOUT POOL DECK.                                |




THIS DOCUMENT IS THE PROPERTY OF WANNEMACHER JENSEN ARCHITECTS, INC. AND IS NOT TO BE REPRODUCED OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, INCLUDING PHOTOCOPYING, RECORDING, OR BY ANY INFORMATION STORAGE AND RETRIEVAL SYSTEM, WITHOUT THE WRITTEN PERMISSION OF WANNEMACHER JENSEN ARCHITECTS, INC. ANY UNAUTHORIZED REPRODUCTION OR TRANSMISSION OF THIS DOCUMENT IS STRICTLY PROHIBITED. THE ARCHITECT ASSUMES NO LIABILITY FOR CONSTRUCTION ERRORS OR OMISSIONS IN THIS DOCUMENT. THE ARCHITECT'S LIABILITY IS LIMITED TO THE PROFESSIONAL SERVICES PROVIDED BY THE ARCHITECT. THE ARCHITECT IS NOT RESPONSIBLE FOR THE ACTIONS OF ANY OTHER PROFESSIONALS OR FOR THE ACTIONS OF ANY CONTRACTORS OR SUBCONTRACTORS. THE ARCHITECT'S LIABILITY IS LIMITED TO THE PROFESSIONAL SERVICES PROVIDED BY THE ARCHITECT.



**2 DETAIL - TYPICAL TPO ROOF ASSEMBLY**  
1 1/2" = 1'-0"



**3 TYP. NORTH ROOF EDGE**  
1" = 1'-0"




**1 OPT 2 - ROOF PLAN**  
3/32\"/>

**GENERAL NOTES**

- ROOFING PRODUCT BASIS-OF-DESIGN: 60 MIL TPO SINGLE PLY MEMBRANE ROOF OR APPROVED EQUAL (COLOR WHITE) RIGID INSULATION BOARD MECHANICALLY FASTENED TO STEEL ROOF DECK. INSULATION TO HAVE AN AVERAGE R-20 @ ALL ROOFS OVER CONDITIONED SPACES. PROVIDE ROOFING COMPONENTS AND MATERIALS APPROVED BY THE ROOFING PRODUCT MANUFACTURER ASSEMBLER ROOFING COMPONENTS INCLUDING FLASHING, ROOF DRAINS, ETC. PER THE ROOFING PRODUCT MANUFACTURER'S DETAILS AND INSTRUCTIONS SO AS TO QUALIFY FOR, AND RECEIVE A SPECIAL 20-YEAR WEATHER-TIGHTNESS WARRANTY FROM THE MANUFACTURER AS WELL AS A SPECIAL 2-YEAR PROJECT WARRANTY FROM THE ROOFING INSTALLER COVERING ALL COMPONENTS OF THE ROOFING SYSTEM SUCH AS ROOFING BASE FLASHING, ROOF INSULATION, FASTENERS, COVER BOARDS, ETC. PROVIDE ROOFING FROM A QUALIFIED MANUFACTURER THAT IS FM GLOBAL APPROVED FOR ROOFING SYSTEM IDENTICAL TO THAT USED FOR THIS PROJECT.
- PROVIDE METAL ROOF COPINGS AND PARAPET FASCIAS FABRICATED OF ASTM B209 0.050-INCH ALUMINUM SHEET, COMPLY WITH "THE NRCA ROOFING MANUAL" AND THE SMACNA "ARCHITECTURAL SHEET METAL MANUAL REQUIREMENTS FOR DIMENSIONS AND PROFILES SHOWN UNLESS MORE STRINGENT REQUIREMENTS ARE INDICATED. PROVIDE MANUFACTURER'S 20-YEAR FINISH WARRANTY. SECURE COPINGS TO PARAPETS WITH CONT ALUMINUM CLEATS.
- PROVIDE GALVANIZED STEEL INTERNALLY REINFORCED ROOF-CURB UNITS CAPABLE OF SUPPORTING SUPERIMPOSED LIVE AND DEAD LOADS, INCLUDING EQUIPMENT LOADS, WITH WELDED OR MECHANICALLY FASTENED, NON-SAG SEALED JOINTS AND INTEGRALLY FORMED DECK-MOUNTING FLANGE AT PERIMETER BOTTOM. COORDINATE DIMENSIONS WITH ROUGHING-IN INFORMATION ON SHOP DRAWINGS OF EQUIPMENT TO BE SUPPORTED.
- ROOF DRAIN BASIS-OF-DESIGN: Z125 8 3/8" DIAMETER ROOF DRAIN WITH LOW SILHOUETTE DOME MANUFACTURED BY ZURN INDUSTRIES.
- GENERAL - IT IS THE INTENT OF THE CONTRACT DOCUMENTS TO PROVIDE FOR A COMPLETE AND WEATHERTIGHT INSTALLATION OF ALL ROOF ITEMS, PENETRATIONS, ETC. THE CONTRACTOR SHALL PROVIDE ALL ROOF ACCESSORIES, FLASHING, SEALANT, SCUPPERS, DRAINS, LABOR, MATERIALS, EQUIPMENT, ETC. REQUIRED FOR COMPLETION OF A WEATHERTIGHT ROOF INSTALLATION. FOLLOW ALL RECOMMENDATIONS OF THE NRCA REGARDING INSTALLATION PROCEDURES, UNLESS MORE STRINGENT REQUIREMENTS ARE INDICATED.
- SLOPE - ROOF SURFACE SHALL HAVE A MINIMUM SLOPE OF 1/4" PER FOOT IN A PERPENDICULAR DIRECTION FROM THE ROOF EDGE DOWN TOWARD THE ROOF DRAINS AS INDICATED BY THE ARROWS DRAWN ON THE ROOF PLAN. WHERE REQUIRED TO FACILITATE DRAINAGE, PROVIDE VALLEYS, CRICKETS, RIDGES, ETC. OF REQUIRED SLOPE TO PROPERLY DRAIN ALL ROOF SURFACES.
- ROOF DRAINS - COORDINATE LOCATION OF ALL ROOF DRAINS TO AVOID RATED WALLS, BEAMS, COLUMNS, JOISTS, ETC. BELOW.
- PENETRATIONS - PROPERLY FLASH, WATERPROOF, SECURE AND SEAL ALL ITEMS THAT PENETRATE THE ROOF MEMBRANE. DO NOT INSTALL ANY PITCH POCKETS. FOLLOW GUIDELINES OF NRCA CONCERNING FLASHING AND WATERPROOFING ALL ROOF PENETRATIONS. SEE ROOF DETAILS.
- ROOF EQUIPMENT - MOUNT ALL ROOF EQUIPMENT ON PREFABRICATED EQUIPMENT SUPPORT CURBS WITH INTEGRAL INSULATION. WHERE EQUIPMENT IS RAISED ABOVE ROOF SURFACE, ALIGN SUPPORTS PARALLEL TO DIRECTION OF WATERFLOW TO FACILITATE DRAINAGE. VERIFY ALL REQUIREMENTS WITH EQUIPMENT AND CURB MANUFACTURERS. WHERE ROOF MEMBRANE EXTENDS BENEATH EQUIPMENT, MOUNT EQUIPMENT ABOVE THE ROOF SURFACE IN ACCORDANCE WITH BUILDING CODE AND NRCA REQUIREMENTS TO ALLOW FOR INSTALLATION OF ALL REQUIRED ROOFING COMPONENTS AND TO ALLOW FOR FUTURE OWNER MAINTENANCE.
- LIGHTNING PROTECTION - REFER TO ELECTRICAL DRAWINGS PROTECTION FOR ALL LIGHTNING PROTECTION. GROUNDING RODS, CABLES, CONNECTIONS, ETC. SHALL BE INSTALLED IN SUCH A MANNER TO PREVENT ANY DAMAGE TO INSTALLED ROOF MEMBRANE. GROUNDING RODS SHALL BE FASTENED TO THE SUBSTRATE ON WHICH THEY ARE MOUNTED. PROVIDE ALL REQUIRED FLASHING, SEALANT, WATERPROOFING, NON-CORROSIVE FASTENERS, ETC. AT EACH LOCATION AND AT MEMBRANE PENETRATION POINTS.

**SPECIFIC NOTES**

TAG	NOTE
EL12	LOUVERED ROOF EQUIPMENT SCREEN WALL, HEIGHT TO BE DETERMINED.
RN01	60 MIL SINGLE PLY TPO ROOF MEMBRANE.
RN02	12" ROOF EXTENSION, REFER TO SECTION DETAIL.
RN03	TOP OF TRUSS BELOW.
RN05	PHOTOVOLTAIC ARRAY.
RN07	PROVIDE STEEL SUPPORT FRAMES FOR DUCT WORK @ 48" O.C.
RN08	LOUVERED ROOF EQUIPMENT SCREEN WALL, HEIGHT TO BE DETERMINED.



THE PROJECT ARCHITECT HAS REVIEWED THE PROJECT DRAWINGS AND HAS PREPARED THESE SPECIFICATIONS IN ACCORDANCE WITH THE PROFESSIONAL STANDARDS AND ETHICS OF THE ARCHITECTURAL PROFESSION. THE ARCHITECT HAS NOT CONDUCTED A VISUAL CHECK OF THE PROJECT DRAWINGS FOR CONFORMANCE WITH THE PROFESSIONAL STANDARDS AND ETHICS OF THE ARCHITECTURAL PROFESSION. THE ARCHITECT HAS NOT CONDUCTED A VISUAL CHECK OF THE PROJECT DRAWINGS FOR CONFORMANCE WITH THE PROFESSIONAL STANDARDS AND ETHICS OF THE ARCHITECTURAL PROFESSION.

PRELIMINARY NOT FOR CONSTRUCTION


**LONG CENTER NATATORIUM**  
CITY OF CLEARWATER  
1501 N BELCHER RD. CLEARWATER FL. 33765

Project number  
**0000**  
DISTRIBUTION  
MILESTONE DATE  
SCHEMATIC BID SET 10.23.23


ROOF PLAN\_OPT 2

**A-505**






**1 OPT 2 - WEST ELEVATION**  
1/8" = 1'-0"




**2 OPT 2 - CURTAIN WALL ELEVATION - WEST**  
1/8" = 1'-0"

**3 OPT 2 - CURTAIN WALL ELEVATIONS - EAST**  
1/8" = 1'-0"



**4 OPT 2 - CURTAIN WALL ELEVATIONS - NORTH**  
1/8" = 1'-0"


- SPECIFIC NOTES**
- |      |   |
|------|---|
| TAG  | NOTE  |
| EL02 | TWO PIECE PRE FINISHED ALUMINUM ROOF FASCIA.                  |
| EL06 | EXTERIOR LIGHT FIXTURE.                                       |
| EL09 | CNC CUT ALUMINUM STANDOFF BUILDING SIGNAGE, BACKLIT.          |
| EL10 | VENTS FOR NATURAL VENTILATION.                                |
| EL12 | LOUVERED ROOF EQUIPMENT SCREEN WALL, HEIGHT TO BE DETERMINED. |
| G01  | 1-1/4" INSULATED, IMPACT RESISTANT SAFETY GLAZING.            |




THESE DRAWINGS ARE PRELIMINARY AND NOT TO BE USED FOR CONSTRUCTION. ANY CHANGES TO THESE DRAWINGS SHALL BE THE RESPONSIBILITY OF THE ARCHITECT. THE ARCHITECT SHALL NOT BE RESPONSIBLE FOR THE ACCURACY OF ANY INFORMATION PROVIDED BY OTHERS. THE ARCHITECT'S LIABILITY IS LIMITED TO THE DESIGN AND CONSTRUCTION SERVICES PROVIDED BY THE ARCHITECT. THE ARCHITECT'S LIABILITY DOES NOT EXTEND TO THE DESIGN OR CONSTRUCTION OF ANY OTHER WORK. THE ARCHITECT'S LIABILITY IS LIMITED TO THE DESIGN AND CONSTRUCTION SERVICES PROVIDED BY THE ARCHITECT. THE ARCHITECT'S LIABILITY DOES NOT EXTEND TO THE DESIGN OR CONSTRUCTION OF ANY OTHER WORK.

**SPECIFIC NOTES**


- |      |  |
|------|--|
| TAG  | NOTE   |
| EL01 | THREE PART STUCCO SYSTEM OVER LATH & WEATHERPROOFING                     |
| EL02 | TWO PIECE PRE FINISHED ALUMINUM ROOF FASCIA.                             |
| EL06 | EXTERIOR LIGHT FIXTURE   |
| EL10 | VENTS FOR NATURAL VENTILATION.   |
| EL11 | EXISTING MASONRY BASE TO BE CLEANED AND REPOINTED AS NEEDED.             |
| PN10 | EXISTING BEAM ABOVE.   |
| WS01 | 3 5/8" METAL STUDS FASTENED TO EXISTING TRUSS FRAME @ 16" O.C.           |
| WS04 | FRAMING CLIP @ EVERY HORIZONTAL HSS MEMBER OR 24" O.C. VERTICALLY.       |
| WS05 | THREE PART STUCCO SYSTEM OVER LATH & WEATHERPROOFING, SAND FINISH - PTD. |
| WS06 | EXISTING MASONRY WALL BASE TO REMAIN.                                    |
| WS07 | FILL CAVITY WITH R-19 INSULATION, TYP.                                   |
| WS24 | VENTS FOR NATURAL VENTILATION.   |
| WS26 | STEEL FRAME TRUSS TO BE SANDBLASTED & REPAINTED, TYP.                    |
| WS31 | 5/8" THK WATER RESISTANT GYPSUM BOARD.                                   |




1 OPT 2 - ENLARGED PLAN @ TRUSS  
1/4" = 1'-0"



2 OPT 2 - SECTION @ TRUSS FRAME  
1/2" = 1'-0"



3 OPT 2 - TRUSS NORTH ELEVATION  
1/2" = 1'-0"






4 OPT 2 - TRUSS SIDE ELEVATION  
1/2" = 1'-0"

THE ARCHITECTS SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND OTHER PROJECT REQUIREMENTS AND FOR VERIFYING ALL REGULATORY AGENCIES' REQUIREMENTS AND SPECIFICATIONS. THE ARCHITECTS SHALL NOT BE RESPONSIBLE FOR ANY CHANGES TO THE PROJECT OR ANY OTHER PARTY WITHOUT THEIR EXPRESS WRITTEN CONSENT. THE ARCHITECTS SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND OTHER PROJECT REQUIREMENTS AND FOR VERIFYING ALL REGULATORY AGENCIES' REQUIREMENTS AND SPECIFICATIONS. THE ARCHITECTS SHALL NOT BE RESPONSIBLE FOR ANY CHANGES TO THE PROJECT OR ANY OTHER PARTY WITHOUT THEIR EXPRESS WRITTEN CONSENT.

**SPECIFIC NOTES**

TAG	NOTE
EL01	THREE PART STUCCO SYSTEM OVER LATH & WEATHERPROOFING
EL02	TWO PIECE PRE FINISHED ALUMINUM ROOF FASCIA.
EL04	TWO PIECE ROOF EDGE FASCIA, PRE-FINISHED.
EL09	CNC CUT ALUMINUM STANDOFF BUILDING SIGNAGE, BACKLIT.
PN01	FACE OF WALL BELOW.
PN03	HVAC LOUVER
PN04	EXISTING STEEL TO BE REPAIRED AS NEEDED, SAND & REPAINT
WS03	EXISTING STEEL TRUSS TO REMAIN, SEE STRUCTURAL FOR SPECIFIED REPAIRS.
WS06	EXISTING MASONRY WALL BASE TO REMAIN.
WS07	FILL CAVITY WITH R-19 INSULATION, TYP.
WS08	CONCRETE FDN BY STRUCTURAL.
WS09	HVAC LOUVER BY HVAC.
WS10	METAL STUD FRAMING, REFER TO STRUCTURAL.
WS12	COMPACTED FILL
WS13	VAPOR BARRIER.
WS14	EXISTING STEEL TO BE REPAIRED AS NEEDED, REFER TO STRUCTURAL, SANDED & PAINTED
WS15	ROOF CRICKET.
WS16	REFER TO ROOF PLAN FOR TYPICAL ROOF ASSEMBLY.
WS27	8" TUBE STEEL BOX FRAME.
WS28	FILL CAVITY WITH BATT INSULATION R-19.
WS32	CNC CUT ALUMINUM STANDOFF BUILDING SIGNAGE, BACKLIT.
WS35	1/2" SHEATHING, 1" RIGID INSULATION, STUCCO FINISH.



1 OPT 2 - ENLARGED PLAN @ MECHANICAL CHASE TOWER  
1/4" = 1'-0"

2 OPT 2 - WALL SECTION @ HVAC CHASE  
3/8" = 1'-0"

3 OPT 2 - HVAC CHASE EAST ELEVATION  
3/8" = 1'-0"


4 OPT 2 - HVAC CHASE SOUTH ELEVATION  
3/8" = 1'-0"

THESE DOCUMENTS ARE PRELIMINARY AND OTHER PROJECTS MAY BE AFFECTED BY CHANGES TO THE DESIGN. THE ARCHITECT ASSUMES NO LIABILITY FOR THE ACCURACY OF THE INFORMATION PROVIDED IN THESE DOCUMENTS. THE ARCHITECT'S RESPONSIBILITY IS LIMITED TO THE DESIGN AND CONSTRUCTION OF THE PROJECT AS SHOWN ON THESE DOCUMENTS. THE ARCHITECT DOES NOT WARRANT THE ACCURACY OF ANY INFORMATION PROVIDED BY OTHERS. THE ARCHITECT'S LIABILITY IS LIMITED TO THE DESIGN AND CONSTRUCTION OF THE PROJECT AS SHOWN ON THESE DOCUMENTS. THE ARCHITECT ASSUMES NO LIABILITY FOR THE ACCURACY OF THE INFORMATION PROVIDED IN THESE DOCUMENTS. THE ARCHITECT'S RESPONSIBILITY IS LIMITED TO THE DESIGN AND CONSTRUCTION OF THE PROJECT AS SHOWN ON THESE DOCUMENTS.


PRELIMINARY NOT FOR CONSTRUCTION

**LONG CENTER NATATORIUM**  
 CITY OF CLEARWATER  
 1501 N BELCHER RD, CLEARWATER FL, 33765

Project number	0000
DISTRIBUTION	
MILESTONE	DATE
SCHEMATIC BID SET	10.23.23



1 OPT 2 - TYP NORTH WALL SECTION  
1/2" = 1'-0"



2 OPT 2 - TYPICAL WEST WALL SECTION  
1/2" = 1'-0"

**SPECIFIC NOTES**

- | TAG  | NOTE  |
|------|---|
| WS22 | EXISTING STEEL TO BE REPAIRED AS NEEDED. REFER TO STRUCTURAL, SAND AND PAINT. |
| WS28 | FILL CAVITY WITH BATT INSULATION R-19.  |
| WS29 | METAL STUD BRACING.   |
| WS30 | METAL STUD FRAMING @ 16" O.C.   |
| WS31 | 5/8" THK WATER RESISTANT GYPSUM BOARD.  |
| WS32 | CNC CUT ALUMINUM STANDOFF BUILDING SIGNAGE, BACKLIT.                          |
| WS34 | REFER TO FLOOR PLAN FOR POOL DECK COATING.                                    |
| WS35 | 1/2" SHEATHING, 1" RIGID INSULATION, STUCCO FINISH.                           |

THE ARCHITECTS SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND OTHER PROJECTS AND SHALL BE RESPONSIBLE FOR THE PROTECTION OF ALL UTILITIES AND ADJACENT PROPERTIES. THE ARCHITECTS SHALL NOT BE RESPONSIBLE FOR THE PROTECTION OF ANY UTILITIES OR ADJACENT PROPERTIES. THE ARCHITECTS SHALL NOT BE RESPONSIBLE FOR THE PROTECTION OF ANY UTILITIES OR ADJACENT PROPERTIES. THE ARCHITECTS SHALL NOT BE RESPONSIBLE FOR THE PROTECTION OF ANY UTILITIES OR ADJACENT PROPERTIES. THE ARCHITECTS SHALL NOT BE RESPONSIBLE FOR THE PROTECTION OF ANY UTILITIES OR ADJACENT PROPERTIES.

PRELIMINARY NOT FOR CONSTRUCTION

**LONG CENTER NATATORIUM**

CITY OF CLEARWATER  
 1501 N BELCHER RD, CLEARWATER FL, 33765

Project number  
0000

DISTRIBUTION

MILESTONE DATE

SCHEMATIC BID SET 10.23.23

WALL SECTIONS\_OPT  
2


# LONG CENTER NATATORIUM ENCLOSED SUN-DECK

1501 N BELCHER RD. CLEARWATER FL, 33765












1 WEST ELEVATION - ENCLOSED SUN-DECK  
1/8" = 1'-0"



2 NORTH ELEVATION - ENCLOSED SUN-DECK  
1/8" = 1'-0"




3 CURTAIN WALL ELEVATIONS - WEST  
1/8" = 1'-0"



4 CURTAIN WALL ELEVATIONS - WEST CW-02  
1/8" = 1'-0"

**SPECIFIC NOTES**

TAG	NOTE
EL01	THREE PART STUCCO SYSTEM OVER LATH & WEATHERPROOFING
EL02	TWO PIECE PRE FINISHED ALUMINUM ROOF FASCIA.
EL07	ALUMINUM SUNSHADES BY CURTAIN WALL MANUFACTURER
EL08	CROWN SST-II HYDRAULIC BI-FOLD DOOR SYSTEM.
EL10	VENTS FOR NATURAL VENTILATION.
EL12	LOUVERED ROOF EQUIPMENT SCREEN WALL. HEIGHT TO BE DETERMINED.



THESE DOCUMENTS ARE PRELIMINARY AND NOT TO BE USED FOR CONSTRUCTION. ANY REVISIONS TO THESE DOCUMENTS SHALL BE INDICATED BY A REVISION TABLE. THE ARCHITECT ASSUMES NO LIABILITY FOR ANY ERRORS OR OMISSIONS IN THESE DOCUMENTS. THE ARCHITECT'S LIABILITY IS LIMITED TO THE DESIGN AND CONSTRUCTION OF THE PROJECT. THE ARCHITECT'S LIABILITY DOES NOT EXTEND TO ANY OTHER MATTER. THE ARCHITECT'S LIABILITY IS LIMITED TO THE DESIGN AND CONSTRUCTION OF THE PROJECT. THE ARCHITECT'S LIABILITY DOES NOT EXTEND TO ANY OTHER MATTER.

PRELIMINARY NOT FOR CONSTRUCTION

**LONG CENTER NATATORIUM**  
CITY OF CLEARWATER  
1501 N BELCHER RD. CLEARWATER FL. 33765

Project number  
**0000**  
DISTRIBUTION


MILESTONE DATE  
SCHEMATIC BID SET 10.23.23

ENCLOSED SUN-DECK  
WEST ELEVATION\_2B

**A-515**







**SPECIFIC NOTES**

- |      |   |
|------|---|
| TAG  | NOTE  |
| WS20 | IMPACT RATED, INSULATED GLAZING CURTAIN WALL SYSTEM.                          |
| WS22 | EXISTING STEEL TO BE REPAIRED AS NEEDED, REFER TO STRUCTURAL, SAND AND PAINT. |
| WS23 | CURTAIN WALL FASTENED TO EXISTING HSS BEAMS, PER CURTAIN WALL MANUFACTURER.   |
| WS25 | SIDEWALL MOUNTED BIG ASS FAN, ADJUSTABLE PIVOT FAN.                           |
| WS28 | FILL CAVITY WITH BATT INSULATION R-19.  |
| WS35 | 1/2\" SHEATHING, 1\" RIGID INSULATION, STUCCO FINISH.                         |

THIS DOCUMENT IS THE PROPERTY OF WANNEMACHER JENSEN ARCHITECTS, INC. AND IS NOT TO BE REPRODUCED OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, INCLUDING PHOTOCOPYING, RECORDING, OR BY ANY INFORMATION STORAGE AND RETRIEVAL SYSTEM. ANY REPRODUCTION OR TRANSMISSION OF THIS DOCUMENT WITHOUT THE WRITTEN PERMISSION OF WANNEMACHER JENSEN ARCHITECTS, INC. IS STRICTLY PROHIBITED. THE ARCHITECTS ASSUME NO LIABILITY FOR CONSTRUCTION ERRORS OR OMISSIONS. THE ARCHITECTS MAKE NO WARRANTY, EXPRESS OR IMPLIED, AS TO THE ACCURACY, COMPLETENESS, OR QUALITY OF ANY INFORMATION PROVIDED. THE ARCHITECTS SHALL NOT BE RESPONSIBLE FOR ANY ERRORS OR OMISSIONS IN THIS DOCUMENT. THE ARCHITECTS SHALL NOT BE RESPONSIBLE FOR ANY ERRORS OR OMISSIONS IN THIS DOCUMENT. THE ARCHITECTS SHALL NOT BE RESPONSIBLE FOR ANY ERRORS OR OMISSIONS IN THIS DOCUMENT.

**Wannemacher Jensen Architects, Inc.**  
 132 Mirror Lake Drive N, Unit 301  
 St. Petersburg, Florida 33701-3214  
 www.wjarc.com  
 (727) 822-5566  
 AF94244  
 ©Wannemacher Jensen Architects, Inc.

PRELIMINARY NOT FOR CONSTRUCTION

**LONG CENTER NATATORIUM**  
 CITY OF CLEARWATER  
 1501 N BELCHER RD, CLEARWATER FL, 33765

Project number  
**0000**  
 DISTRIBUTION

MILESTONE	DATE
SCHEMATIC BID SET	10.23.23

ENCLOSED SUN-DECK  
 ENLARGED PLAN &  
 SECTION\_2B  
**A-518**

**1** ENCLOSED SUN DECK SECTION  
 1/2" = 1'-0"

# Appendix #2a - Cost Estimate



Project: Long Center Renovations  
 Location: Clearwater, FL  
 Date: 12/19/2023  
 File Name: Long Center Budget  
 Project #: 2023.116

Work Description	Qty	Unit	Lab unit \$	Lab Tot	Mat unit \$	Mat Tot	Sub unit \$	Sub Tot	Total	Area Sub Total
<b>BUILDING CONSTRUCTION - SCHEMATIC DESIGN BUDGET</b>										
<b>01 General Requirements</b>										4,384,486
Contractor General Conditions	1	ls	15.0%			0	1324208.4	1324208	1,324,209	
Contractor General Liability Insurance	1	ls	2.0%			0	203045.3	203045	203,045	
Builder's Risk Insurance - By Owner							0			
Sub-Contractor Bonds	1	ls	2.5%			0	258882.7	258883	258,883	
Public Art Allowance - N.I.C.										
Estimate Contingency	1	ls	5.0%			0	1072033.5	1072033	1,072,034	
Escalation	1	ls	5.0%			0	589618.4	589618	589,618	
Permits Allowance	1	ls	1.0%			0	123819.9	123820	123,820	
Contractor General OH&P	1	ls	6.5%			0	812877.4	812877	812,877	
<b>02 Existing Conditions</b>										425,369
Asbestos Remediation - N.I.C.										
Selective Building Demolition										
Demo storefront 3070dr/hdw	2	ea		0		0	750.0	1500	1,500	
Demo storefront 6070dr/hdw	3	ea		0		0	1000.0	3000	3,000	
Demo glazing sys	16,071	sf		0		0	15.0	241062	241,062	
Demo pool trench drain	500	lf		0		0	100.0	50000	50,000	
Pool protection during demo	500	lf		0		0	25.0	12500	12,500	
Rem pool accessories	8	ea		0		0	1000.0	8000	8,000	
Demo SOG	240	sf		0		0	10.0	2400	2,400	
Demo CMU wall	120	sf		0		0	7.5	900	900	
Demo roof sys	27,383	sf		0		0	2.5	68457	68,457	
Demo roof curb	13	ea		0		0	250.0	3250	3,250	
Demo Mech equip	1	ls		0		0	25000.0	25000	25,000	
Demo Mech piping	300	lf		0		0	15.0	4500	4,500	
Cut-out metal deck	320	sf		0		0	15.0	4800	4,800	
<b>03 Concrete</b>										175,000
New pool gutter drain	500	lf		0		0	300.0	150000	150,000	
Slab on Grade with mesh - HVAC Chase	10	cy		0		0	2500.0	25000	25,000	
<b>04 Masonry</b>										10,000
Patch cmu walls	1	ls		0		0	10000.0	10000	10,000	
<b>05 Metals</b>										1,173,053

Work Description	Qty	Unit	Lab unit \$	Lab Tot	Mat unit \$	Mat Tot	Sub unit \$	Sub Tot	Total	Area Sub Total
Sandblast steel structure	37,914	sf		0		0	5.5	208527	208,527	
Pool int floor area prot. during sandblastin	26,760	sf		0		0	2.5	66900	66,900	
Pool int clg area prot. during sandblasting	26,760	sf		0		0	3.5	93660	93,660	
Bldg ext area protection during sandblastir	15,279	sf		0		0	4.5	68756	68,756	
Roof extension stl plate/deck	446	lf		0		0	125.0	55750	55,750	
Tube steel framing - stl boxes	12	tn		0		0	6500.0	78000	78,000	
Tube steel framing - deck openings	5	tn		0		0	6500.0	32500	32,500	
Tube steel framing - mech equip	9	tn		0		0	6500.0	60938	60,938	
Tube steel posts - roof screen	7	tn		0		0	6500.0	42656	42,656	
Tube steel framing - OH door fr	0.67	tn		0		0	6500.0	4367	4,367	
Curtainwall attachment to stl fr	1.00	ls		0		0	25000.0	25000	25,000	
Structural steel repairs	1	ls		0		0	436000.0	436000	436,000	
<b>06 Wood / Plastic / Composites</b>										27,808
Rough Carpentry Work										
Roof Edge 2x Blocking	3,476	lf		0		0	8.0	27808	27,808	
<b>07 Thermal &amp; Moisture Protection</b>										776,850
Insulation walls - Fiberglass 6" R19	10,030	sf		0		0	1.5	15045	15,045	
Roof Deck Insulation - Polyiso R20 min	31,050	sf		0		0	6.0	186300	186,300	
Gypsum cover bd 1/2"	31,050	sf		0		0	2.5	77625	77,625	
Tapered insulation bd	31,050	sf		0		0	2.5	77625	77,625	
Roofing - Single-ply TPO	31,050	sf		0		0	12.0	372600	372,600	
Walkway Pads	600	sf		0		0	5.0	3000	3,000	
Metal Flashings										
Pre-fin 2 piece metal fascia	983	lf		0		0	25.0	24585	24,585	
Sealants	26,760	sf		0		0	0.75	20070	20,070	
<b>08 Openings</b>										1,701,942
<b>Entrances/Storefronts</b>										
Alum Storefront doors - 6070	2	ea		0		0	7000.0	14000	14,000	
Alum Storefront doors - 3070	2	ea		0		0	5000.0	10000	10,000	
Al/GI Curtainwall - impact rated	11,365	sf		0		0	145.0	1647942	1,647,942	
<b>Special Doors</b>										
Overhead Doors										
Hydraulic Bi-Fold Door	1	ea		0		0	25000.0	25000	25,000	
<b>Access Doors/Panels</b>										
Louver vents	20	ea		0		0	250.0	5000	5,000	
<b>09 Finishes</b>										1,010,808

Work Description	Qty	Unit	Lab unit \$	Lab Tot	Mat unit \$	Mat Tot	Sub unit \$	Sub Tot	Total	Area Sub Total
<b>Exterior Wall Finishes</b>										
Stucco on framing, Painted	11,372	sf		0		0	18.0	204692	204,692	
Ext MS framing at stucco walls	11,372	sf		0		0	15.0	170577	170,577	
<b>Interior Finishes</b>										
<b>Walls</b>										
Ms 3 5/8"/MR gyp bd 1s	6,452	sf		0		0	12.0	77418	77,418	
<b>Floors</b>										
Porcelain Tile at pool edge 16"	771	sf		0		0	15.0	11558	11,558	
Epoxy Floor Coating - Pool Deck	11,615	sf		0		0	17.5	203263	203,263	
<b>Wall Finishes</b>										
Porcelain Tile at pool edge 8"	369	sf		0		0	15.0	5528	5,528	
Paint gyp bd, epoxy	6,452	sf		0		0	2.0	12903	12,903	
<b>Ceiling Finishes</b>										
Epxoy Paint steel framing/metal deck	64,974	sf		0		0	5.0	324870	324,870	
<b>10 Specialties</b>										457,650
Exterior Signs										
Letters - 12" Alum	10	ea		0		0	175.0	1750	1,750	
Letters - 18" Alum	10	ea		0		0	250.0	2500	2,500	
Misc.										
Bigass Fans - side mtd.	6	ea		0		0	12000.0	72000	72,000	
Sun Shades - Alum	1,000	lf		0		0	150.0	150000	150,000	
Equip. Screen wall	3,560	sf		0		0	65.0	231400	231,400	
<b>11 Equipment</b>										298,000
Pool Equip. - Replace UV system	1	ls		0		0	286000.0	286000	286,000	
Pool Equip. - Reinstall accessories	8	ea		0		0	1500.0	12000	12,000	
<b>12 Furnishings</b>										-
By Owner										
<b>13 Special Construction</b>										479,375
Enclosed Sundeck Addition	1,625	sf		0		0	295.0	479375	479,375	
<b>14 Conveying Systems</b>										-
None										
<b>21 Fire Suppression System</b>										-
None										

Work Description	Qty	Unit	Lab unit \$	Lab Tot	Mat unit \$	Mat Tot	Sub unit \$	Sub Tot	Total	Area Sub Total
<b>22 Plumbing</b>										9,000
Replace roof drains - same location	3	ea		0		0	3000.0	9000	9,000	
<b>23 HVAC</b>										1,942,200
Pool Dehumidifier & Fan	2	ea	258600	517,200.0	646500	1,293,000	25000	50,000	1,860,200	
Ductwork & support frames	1	ls	2000	2,000.0	5000	5,000	25000	25,000	32,000	
Test & Balance	1	ls		0		0	15000	15,000	15,000	
Controls	1	ls		0		0	25000	25,000	25,000	
HVAC Commissioning	1	ls		0		0	10000	10,000	10,000	
<b>26 Electrical</b>										341,000
Photovoltaic System - Allowance	1	ls		0		0	300000	300,000	300,000	
HVAC power	1	ls		0		0	10000	10,000	10,000	
Building sigange power	1	ls		0		0	5000	5,000	5,000	
Ext wall lighting	10	ea		0		0	1850	18,500	18,500	
Tie into ex panel	1	ls		0		0	7500	7,500	7,500	
<b>TOTAL BUILDING CONSTRUCTION PROBABLE COST - Option #1</b>									<b>13,212,542</b>	<b>13,212,542</b>

The above budget does not include the following;  
 Site Work, Civil Work, Utilities  
 Pool Equipment  
 Equipment not specifically listed in the budget  
 Impact Fees  
 Testing & 3rd Party Inspections  
 Design Fees  
 Owner Contingency  
 Builder's Risk Insurance  
 Public Art

**ALTERNATES**

Option #2 - (less AI/GI more soild wall)	DEDUCT	(330,184)
Pool Equipment - New High Rate Sand Filter sys	ADD	998,140
Pool Equipment - New Defender Filter sys	ADD	1,092,520

## Appendix #2b - Cost Estimate

CONSTRUCTION COST ESTIMATE

# Long Center Renovations

## Schematic Bid Set

Estimate Prepared: 12/15/2023



PREPARED BY:



132 MIRROR LAKE DR N, # 301  
SAINT PETERSBURG, FL 33701  
727.767.9509  
WWW.WJCREATE.COM

# CONTENTS

<b>01</b>	<b>BASIS</b>
<b>02</b>	<b>DOCUMENTS</b>
<b>03</b>	<b>NARRATIVE</b>
<b>04</b>	<b>ESTIMATE</b>

# 01 BASIS

## ESTIMATORS APPROACH

### PRELIMINARY ESTIMATE:

When approaching the task of developing a construction cost estimate WJCreate utilizes a variety of industry leading methods, tools, and technologies. We employ a combination of parametric data, assembly and systems costs, along with unit price and square foot calculations to develop a realistic probable cost model for the project's construction. Due to the limited detail of design documentation, which is typical of a project at this stage, numerous assumptions were made to develop an estimation that would reflect a complete project in line with what is understood to be the design intent.

For this estimate our estimating team collaborated with the project design team to provide technical input and fill in gaps where details were lacking or yet to be incorporated into the design documents. In parts of the estimate scopes were fairly well defined and measured to specific details in drawings while others may have been conceptualized by our estimating team. Costs assigned to items are estimated utilizing a combination of our experience with similar work and figures from our internal libraries of historical cost data, and values provided by industry leading resources like R.S. Means and BNI.

Supplemental information was obtained by consultants hired by the Architect and their information is included in part of this estimate.

### ESTIMATOR'S CONTINGENCY

While our estimating team takes numerous steps to fill in the gaps in the design documents it is not always possible to foresee every detail. The "Estimators Contingency" included within this estimate is intended to provide safeguard from costs associated with design-related uncertainties that exist at the time the estimate is being provided. The Estimator's Contingency is based on the level of detail provided by the design documents and the number of assumptions taken by the estimating team.

### QUALIFICATION:

This opinion of probable costs of construction is provided based on company staff experience, qualifications, and best judgment. WJCreate has prepared this estimate in accordance with generally accepted cost estimating practices and standards. WJCreate reserves the right to amend our opinions based upon new and/or differing information discovered.

## 02 DOCUMENTS

The listed documents below were utilized in the development of the cost estimate provided herein.

SHEET #	SHEET NAME	SD BID PACKAGE
01 GENERAL		
G-100	COVER_OPT 1	•
G-101	DRAWING LEGEND AND BUILDING DATA	•
G-103	SHEET INDEX_OPT 1	
06 DEMO		
AD-301	DEMO FLOOR PLAN	•
AD-302	DEMO ROOF PLAN	•
AD-303	DEMO EXTERIOR ELEVATIONS	•
AD-304	DEMO EXTERIOR ELEVATIONS	•
07 ARCHITECTURAL		
A-002	3D VIEWS_OPT 1	•
A-003	RENDERINGS OPT_1	•
A-101	LEVEL 1 - FLOOR PLAN_OPT 1	•
A-102	ROOF PLAN_OPT 1	•
A-201	REFLECTED CEILING PLAN	•
A-303	EXTERIOR ELEVATIONS_OPT 1	•
A-304	EXTERIOR ELEVATIONS_OPT 1	•
A-410	EXTERIOR TRUSS PLANS, ELEVATIONS & SECTION_OPT 1	•
A-412	VENTILATION TOWERS_OPT 1	•
A-413	WALL SECTIONS_OPT 1	•
A-501	COVER_OPT 2	•
A-502	3D VIEWS_OPT 2	•
A-503	RENDERINGS OPT_2	•
A-504	LEVEL 1 - FLOOR PLAN_OPT 2	•
A-505	ROOF PLAN_OPT 2	•
A-506	EXTERIOR ELEVATIONS_OPT 2	•
A-507	EXTERIOR ELEVATIONS_OPT 2	•
A-508	EXTERIOR TRUSS PLANS, ELEVATIONS & SECTION_OPT 2	•
A-509	VENTILATION TOWERS_OPT 2	•
A-510	WALL SECTIONS_OPT 2	•

**SUNDECK**

<b>SHEET #</b>	<b>SHEET NAME</b>	<b>SD BID PACKAGE</b>
01 GENERAL		
G-105	COVER_ENCLOSURE SUN-DECK_2B	•
G-106	SHEET INDEX_ENCLOSURE SUN-DECK_2B	
06 DEMO		
AD-101	DEMO FLOOR PLAN_ENCLOSURE SUN-DECK	•
07 ARCHITECTURAL		
A-515	ENCLOSURE SUN-DECK WEST ELEVATION_2B	•
A-516	RENDERINGS ENCLOSURE SUN-DECK_2B	•
A-517	LEVEL 1 - FLOOR PLAN_ENCLOSURE SUN-DECK_2B	•
A-518	ENCLOSURE SUN-DECK ENLARGED PLAN & SECTION_2B	•

## 03 NARRATIVE

The following narrative is intended to provide additional information and clarification for the line items listed within the estimate.

### GENERAL ITEMS

1. The estimate includes two potential renovations schemes.
2. Cost Model is based upon design documents listed herein.
3. No Structural, Mechanical, Electrical or Plumbing drawings provided. All costs are conceptualized figures based on assembly systems typical of the scope of work.
4. The estimate is based on current market costs at the time the estimate was prepared and work being performed during normal business hours at a typical pace.
5. Estimate does not include amounts associated with the replacement of Pool Equipment.

### GENERAL EXCLUSIONS

The items below are not included in this estimate unless specifically called out as included:

1. Permitting costs or any other municipal fees.
2. Professional design services and engineering service fees.

### OPTION ONE

#### 01 – GENERAL CONDITIONS:

- All general conditions assume an overall 8-month construction timeline.
- Project Management assumes (1) Full-time Superintendent and (1) Part-time Project Manager.
- All other items typical of a project of this nature.

#### 02 – EXISTING CONDITIONS

- Estimate includes all demolition as noted on drawings.
- Amount allocated for protection for Pool
- Conceptualized demolition items include:
  - Landscape Demolition.
  - Demolition of slab for Duct Chase.
  - Pool Edge demolition for Drain Replacement.
  - Demolition and removal of existing HVAC equipment.
  - Demolition and removal of pool equipment.

#### 03 – CONCRETE

- Includes cost for foundation of the duct chase and an allowance for misc. concrete and masonry repair.

#### 05 – METALS

- No Structural Drawings provided. All amounts provided are conceptualized amounts.
- Estimate for Structural Steel Modification components provided by Architect's Structural Consultant.

#### 07 – THERMAL AND MOISTURE PROTECTIONS

- Roof system to be replaced from deck up per drawing specifications.
- Insulation and weather barrier systems included is wall assembly costs.
- A misc. caulking/waterproofing line item included.

#### 08 – OPENINGS

- New Curtain wall system priced as specified by Architect.
  - Includes YKK (YHC 300 OG) system and 1-5/16" VNE1-53 Insulating Laminated Glazing.
  - Therma Shade System Included where indicated.

**09 – FINISHES**

- Metal Truss framing system assembly priced as specified in the drawings.
- Allowance included for preparation of existing floors
- Sandblasting of existing ceilings included.

**22 – PLUMBING**

- No plumbing drawings provided. All amounts provided are conceptualized amounts.

**23 – HVAC**

- No HVAC drawings provided. All amounts provided are conceptualized amounts.
- HVAC Systems costs included per Engineer's quote.
- An Additional line item included for installation of equipment and other necessities.

**26 – ELECTRICAL**

- No Electrical drawings provided. All amounts provided are conceptualized amounts.

**35 – WATERWAY & MARINE**

- Estimate includes pool equipment per Counsilman – Hunsaker Estimate.
- An allowance included for miscellaneous pool repair.

**48 – ELECTRICAL POWER GENERATION**

- A conceptualized amount is provided for a photovoltaic array system. These systems vary drastically in cost depending on the system specified. The amount assigned is based on a 171 kW System to occupy the areas indicated on the roof drawings.

# LONG CENTER RENOVATIONS

ESTIMATE OF PROBABLE CONSTRUCTION COST

## SCHEMATIC BID SET (10/23/23)

ESTIMATE PREPARED: 12/15/2023

DIVISION / DESCRIPTION	OPTION ONE			OPTION TWO			SUN DECK		
	\$	% OF TOTAL	\$/SF	\$	% OF TOTAL	\$/SF	\$	% OF TOTAL	\$/SF
01 GENERAL REQUIREMENTS	789,527	8%	\$31	751,546	9%	\$30	143,138	20%	\$84
02 EXISTING CONDITIONS	271,997	3%	\$11	271,997	3%	\$11	20,825	3%	\$12
03 CONCRETE	25,400	0%	\$1	25,400	0%	\$1	45,048	6%	\$26
04 MASONRY	-	0%	\$0	-	0%	\$0	47,824	7%	\$28
05 METALS	1,015,846	10%	\$40	1,015,846	12%	\$40	66,671	9%	\$39
07 THERMAL AND MOISTURE PROTECTIONS	550,122	5%	\$22	550,122	6%	\$22	53,488	8%	\$31
08 OPENINGS	3,408,110	33%	\$134	1,507,750	18%	\$60	114,432	16%	\$67
09 FINISHES	769,192	7%	\$30	1,053,363	12%	\$42	89,147	13%	\$52
10 SPECIALTIES	32,000	0%	\$1	32,000	0%	\$1	-	0%	\$0
22 PLUMBING	55,179	1%	\$2	55,179	1%	\$2	-	0%	\$0
23 HVAC	1,603,415	16%	\$63	1,603,415	19%	\$63	-	0%	\$0
26 ELECTRICAL	156,100	2%	\$6	156,100	2%	\$6	35,100	5%	\$21
31 EARTHWORK	-	0%	\$0	-	0%	\$0	11,260	2%	\$7
32 EXTERIOR IMPROVEMENTS	20,000	0%	\$1	20,000	0%	\$1	8,000	1%	\$5
35 WATERWAY & MARINE	370,852	4%	\$15	370,852	4%	\$15	-	0%	\$0
48 ELECTRICAL POWER GENERATION	468,000	5%	\$18	468,000	5%	\$18	-	0%	\$0
00 PROCUREMENT & CONTRACTING	808,506	8%	\$32	676,172	8%	\$27	68,714	10%	\$40
<b>SUBTOTAL</b>	<b>\$ 10,344,246</b>		<b>\$408</b>	<b>\$ 8,557,743</b>		<b>\$338</b>	<b>\$ 703,647</b>		<b>\$414</b>
Estimator's Contingency	827,540	8%	\$33	684,619	8%	\$27	56,292	8%	\$33
<b>GRAND TOTAL:</b>	<b>\$ 11,171,785</b>		<b>\$441</b>	<b>\$ 9,242,362</b>		<b>\$365</b>	<b>\$ 759,939</b>		<b>\$447</b>

### Pool Equipment Alternatives

UV System Replacements	Included in Base Estimate
Recirculation Systems Replacement - High Rate Sand Filters (Add)	+ 714,820
Recirculation Systems Replacement - Defeinder Filter System (Add)	+ 829,330

# OPTION 1

## LONG CENTER RENOVATIONS

MAS_ITEM	DESCRIPTION	UOM	COST	TOTAL
<b>02. EXISTING CONDITIONS</b>				
<b>Selective Demolition</b>				
Doors & Openings	D002	3 EA x	\$198.00 =	\$594
Glazing Systems	D011	15,458 SF x	\$4.75 =	\$73,426
Pool Edge Trench Drain	D012	494 LF x	\$22.45 =	\$11,090
Pool Equipment		1 LSUM x	\$6,250.00 =	\$6,250
Pool Specialties	D017	1 LSUM x	\$1,250.00 =	\$1,250
Roofing Systems Demolition	To Deck, Including Curbs & Edge	27,250 SF x	\$1.48 =	\$40,194
<b>Minor Site Demolition</b>				
Exterior Hardscape Selective Demolition	D021	1 SF x	\$2,650.00 =	\$2,650
Landscaping Demolition		1 LSUM x	\$4,800.00 =	\$4,800
<b>Service System Demolition</b>				
HVAC Systems & Components Demolition	All Existing Mechanical Equipment	1 LSUM x	\$28,250.00 =	\$28,250
<b>Protection &amp; Controls</b>				
Scaffolding	False Deck in Pool to Ceiling	1 LSUM x	\$80,000.00 =	\$80,000
Temporary Protection	Misc. Protection for Existing to Remain and WIP	1 LSUM x	\$8,750.00 =	\$8,750
Pool Cover	Temporary Pool Cover - Poly Tarp	12,820 SF x	\$1.15 =	\$14,743
<b>02 SUBTOTAL - EXISTING CONDITIONS</b>				<b>\$271,997</b>
<b>03. CONCRETE</b>				
<b>Foundation Systems</b>				
Concrete Foundations	Foundations @ Duct Chase	320 SF x	\$32.50 =	\$10,400
<b>Concrete Patching</b>				
Concrete & Masonry Patching	Allowance - Misc. repair of existing walls as needed	1 LSUM x	\$15,000.00 =	\$15,000
<b>03 SUBTOTAL - CONCRETE</b>				<b>\$25,400</b>
<b>05. METALS</b>				
<b>Structural Steel Systems</b>				
Existing Systems Modifications				
Metal Truss Modifications	Estimate Provided by Structural Consultants	1 LSUM x	\$453,440.00 =	\$453,440
HVAC RTU Equipment Supports	Estimate Provided by Structural Consultants	1 LSUM x	\$241,620.00 =	\$241,620
Roofing Modifications	Estimate Provided by Structural Consultants	1 LSUM x	\$51,510.00 =	\$51,510
HVAC Chase(s)	Estimate Provided by Structural Consultants	1 LSUM x	\$87,326.00 =	\$87,326
<b>Other Metals</b>				
Roof Screen	Louvered metal screens @ Mech	3,600 SF x	\$42.50 =	\$153,000
Metal Louvers	Ventilation louvers on truss walls	30 EA x	\$965.00 =	\$28,950
<b>05 SUBTOTAL - METALS</b>				<b>\$1,015,846</b>
<b>07. THERMAL AND MOISTURE PROTECTIONS</b>				
<b>Roofing Systems</b>				
Rigid Insulation	Polyiso Rigid Insulation	27,690 SF x	\$8.15 =	\$225,674
Coverboard	1/2"	27,690 SF x	\$1.45 =	\$40,151
Membrane	60 Mil Single Ply TPO	27,690 SF x	\$7.36 =	\$203,798
Roof Edge	Blocking & Metal Flashing	720 LF x	\$81.25 =	\$58,500
Waterproofing & Caulking	Misc. Waterproofing & Caulking	1 LSUM x	\$22,000.00 =	\$22,000
<b>07 SUBTOTAL - WOODS &amp; PLASTICS</b>				<b>\$550,122</b>
<b>08. OPENINGS</b>				
<b>Doors</b>				
Storefront Door System		2 EA x	\$9,250.00 =	\$18,500
Bi-Fold Door System		1 EA x	\$19,250.00 =	\$19,250
<b>Exterior Glazing Systems</b>				
Curtain Wall system				
YKK Curtain Wall System	YKK System	11,018 SF x	\$300.00 =	\$3,305,400
Awning Systems	Therma Shade System @ Curtain Wall	580 LF x	\$112.00 =	\$64,960
<b>08 SUBTOTAL - OPENINGS</b>				<b>\$3,408,110</b>

# OPTION 1

## LONG CENTER RENOVATIONS

MAS	ITEM	DESCRIPTION	UOM	COST	TOTAL
<b>09. FINISHES</b>					
<b>Wall Assembly Systems</b>					
	Framing	Metal Studs & Clips	10,935 SF x	\$8.28 =	\$90,542
	Sheathing	Exterior Gyp Board	10,935 SF x	\$6.74 =	\$73,702
	Insulation	Batt & Rigid Insulation	4,830 SF x	\$3.25 =	\$15,698
	Stucco Systems	3 Coat Stucco only Ply inc. VB	10,935 SF x	\$9.15 =	\$100,055
	Paint	Paint on Stucco & Gyp	15,765 SF x	\$2.15 =	\$33,895
	Gypsum Board	5/8 Moisture Resistant Gyp	4,830 SF x	\$3.10 =	\$14,973
<b>Wall Finishes</b>					
	Paint / Epoxy Painting	Existing Structural Steel Systems	1 LSUM x	\$18,748.75 =	\$18,749
<b>Floor Finishes</b>					
	Floor Preparation	Prepare Pool Deck for Epoxy	11,040 SF x	\$2.15 =	\$23,736
	Epoxy Flooring Systems	Pool Deck	11,040 SF x	\$12.48 =	\$137,779
<b>Ceiling Finishes</b>					
	Sand Blasting	Interior Ceiling	25,200 SF x	\$4.32 =	\$108,864
	Paint / Epoxy Painting	Structural Beams & Deck	25,200 SF x	\$6.00 =	\$151,200
09	<b>SUBTOTAL - FINISHES</b>				<b>\$769,192</b>
<b>10. SPECIALTIES</b>					
<b>Signage</b>					
	Backlight Marquee Signage	Wall Mounted	1 LSUM x	\$32,000.00 =	\$32,000
10	<b>SUBTOTAL - SPECIALTIES</b>				<b>\$32,000</b>
<b>22. PLUMBING</b>					
<b>Sanitary Specialties</b>					
	Roof Drain Pipe	Replace Existing Systems	480 LF x	\$108.80 = \$	52,224.00
	Roof Drain		3 EA x	\$985.00 = \$	2,955.00
22	<b>SUBTOTAL - PLUMBING</b>				<b>\$55,179</b>
<b>23. HVAC</b>					
<b>HVAC Systems</b>					
	HVAC Equipment	Per Engineer's Quote	1 lsum x	\$1,293,000.00 =	\$1,293,000
	HVAC Installation & Other Materials		1 lsum x	\$310,415.00 =	\$310,415
23	<b>SUBTOTAL - HVAC SYSTEMS</b>				<b>\$1,603,415</b>
<b>26. ELECTRICAL</b>					
<b>Electrical Service &amp; Distribution</b>					
	Electrical Systems	Fixtures & Signage Connection - Wiring, Conduit, Etc.	1 LSUM x	\$124,250.00 =	\$124,250
<b>Lighting &amp; Fixtures</b>					
	Exterior Light Fixtures		10 EA x	\$1,850.00 =	\$18,500
	Pivot Fans		6 EA x	\$2,225.00 =	\$13,350
26	<b>SUBTOTAL - ELECTRICAL SYSTEMS</b>				<b>\$156,100</b>
<b>32. EXTERIOR IMPROVEMENTS</b>					
<b>Landscaping &amp; Irrigation</b>					
	Landscaping	Landscaping Allowance	1 LSUM x	\$20,000.00 =	\$20,000
32	<b>SUBTOTAL - EXTERIOR IMPROVEMENTS</b>				<b>\$20,000</b>
<b>35. WATERWAY &amp; MARINE</b>					
<b>Pool Equipment &amp; Specialties</b>					
	Pool Equipment	Cost Provided by Pool Consultant	1 LSUM x	\$286,000.00 =	\$286,000

# OPTION 1

## LONG CENTER RENOVATIONS

MAS	ITEM	DESCRIPTION	UOM	COST	TOTAL
	Pool Edge - Trench Drain Curb	Natare Grating	494 LF x	\$131.28 =	\$64,852
	Pool Repair	Pool Repair Allowance	1 LSUM x	\$20,000.00 =	\$20,000
35	<b>SUBTOTAL - WATERWAY &amp; MARINE</b>				<b>\$370,852</b>
<b>48. ELECTRICAL POWER GENERATION</b>					
	<b>Solar Power Generating Systems</b>				
	Photovoltaic Array System	171 kW System	1 LSUM x	\$468,000.00 =	\$468,000
48	<b>SUBTOTAL - ELECTRICAL POWER GENERATION</b>				<b>\$468,000</b>
<b>01. GENERAL REQUIREMENTS</b>					
	<b>Project Management</b>				
	<b>Project Supervision</b>				
	Project Manager(s) Time	(1) Project Manager(s)	8 MTH x	\$11,088.00 =	\$88,704
	Assistant Project Manager(s) Time	(1) Assistant Project Manager(s)	8 MTH x	\$14,300.00 =	\$114,400
	Project Accountant(s)	(1) Project Accountant	8 MTH x	\$600.00 =	\$4,800
	Software	Project Management Software & Cloud Services	8 MTH x	\$1,850.00 =	\$14,800
	<b>Field Supervision</b>				
	Project Site Superintendent	(1) Site Superintendent(s)	8 MTH x	\$16,800.00 =	\$134,400
	Assistant Superintendent	(1) Site Assistant Superintendent(s)	8 MTH x	\$14,800.00 =	\$118,400
	<b>Field Office &amp; Supplies</b>				
	Site Office & Equipment	Jobsite Trailer & Office Supplies	8 MTH x	\$2,845.00 =	\$22,760
	Temporary Toilets		8 MTH x	\$750.00 =	\$6,000
	Field Office Supplies		8 MTH x	\$215.00 =	\$1,720
	<b>Maintenance &amp; Housekeeping</b>				
	Jobsite Clean-up	Temp Labor / Clean-up	8 MTH x	\$1,750.00 =	\$14,000
	<b>Temporary Controls &amp; Safety</b>				
	Safety Supplies		1 LSUM x	\$1,200.00 =	\$1,200
	Site Signage		1 LSUM x	\$2,000.00 =	\$2,000
	<b>Construction Aids, Equipment, &amp; Tools</b>				
	Equipment Rentals		1 LSUM x	\$10,000.00 =	\$10,000
	Punchlist Allowance		1 LSUM x	\$3,500.00 =	\$3,500
	<b>Trash and Dump Charges</b>				
	Dumpster & Trash Removal Charges		25,340 SF x	\$0.95 =	\$24,073
	<b>Testing and Quality Control</b>				
	Quality Control	Quality Control Manager	1 LSUM x	\$9,825.00 =	\$9,825
	<b>SUBTOTAL - COST OF WORK</b>				<b>\$9,316,795</b>
	<b>Cascading Costs</b>				
	General Liability Insurance		Cost of Work x	1.00% =	\$93,168
	Builder's Risk Insurance		Cost of Work x	0.35% =	\$32,609
	Bonds		Cost of Work x	1.00% =	\$93,168
01	<b>SUBTOTAL - GENERAL REQUIREMENTS</b>				<b>\$789,527</b>
<b>00. PROCUREMENT &amp; CONTRACTING</b>					
	<b>Fees &amp; Overhead</b>				
	Contractor's Fee		Cost of Work x	5.00% =	\$505,316
	Construction Contingency		Cost of Work x	3.00% =	\$303,190
00	<b>SUBTOTAL - CONTRACTOR'S FEE &amp; CONTINGENCY</b>				<b>\$808,506</b>
<b>PROJECT TOTAL</b>					<b>\$10,344,246</b>

# OPTION 2

## LONG CENTER RENOVATIONS

MAS_ITEM	DESCRIPTION	UOM	COST	TOTAL
<b>02. EXISTING CONDITIONS</b>				
<b>Selective Demolition</b>				
Doors & Openings	D002	3 EA x	\$198.00 =	\$594
Glazing Systems	D011	15,458 SF x	\$4.75 =	\$73,426
Pool Edge Trench Drain	D012	494 LF x	\$22.45 =	\$11,090
Pool Equipment		1 LSUM x	\$6,250.00 =	\$6,250
Pool Specialties	D017	1 LSUM x	\$1,250.00 =	\$1,250
Roofing Systems Demolition	To Deck, Including Curbs & Edge	27,250 SF x	\$1.48 =	\$40,194
<b>Minor Site Demolition</b>				
Exterior Hardscape Selective Demolition	D021	1 SF x	\$2,650.00 =	\$2,650
Landscaping Demolition		1 LSUM x	\$4,800.00 =	\$4,800
<b>Service System Demolition</b>				
HVAC Systems & Components Demolition	All Existing Mechanical Equipment	1 LSUM x	\$28,250.00 =	\$28,250
<b>Protection &amp; Controls</b>				
Scaffolding	False Deck in Pool to Ceiling	1 LSUM x	\$80,000.00 =	\$80,000
Temporary Protection	Misc. Protection for Existing to Remain and WIP	1 LSUM x	\$8,750.00 =	\$8,750
Pool Cover	Temporary Pool Cover - Poly Tarp	12,820 SF x	\$1.15 =	\$14,743
<b>02 SUBTOTAL - EXISTING CONDITIONS</b>				<b>\$271,997</b>
<b>03. CONCRETE</b>				
<b>Foundation Systems</b>				
Concrete Foundations	Foundations @ Duct Chase	320 SF x	\$32.50 =	\$10,400
<b>Concrete Patching</b>				
Concrete & Masonry Patching	Misc. repair of existing walls as needed	1 LSUM x	\$15,000.00 =	\$15,000
<b>03 SUBTOTAL - CONCRETE</b>				<b>\$25,400</b>
<b>05. METALS</b>				
<b>Structural Steel Systems</b>				
Existing Systems Modifications				
Metal Truss Modifications	Estimate Provided by Structural Consultants	1 LSUM x	\$453,440.00 =	\$453,440
HVAC RTU Equipment Supports	Estimate Provided by Structural Consultants	1 LSUM x	\$241,620.00 =	\$241,620
Roofing Modifications	Estimate Provided by Structural Consultants	1 LSUM x	\$51,510.00 =	\$51,510
HVAC Chase(s)	Estimate Provided by Structural Consultants	1 LSUM x	\$87,326.00 =	\$87,326
<b>Other Metals</b>				
Roof Screen	Louvered metal screens @ Mech	3,600 SF x	\$42.50 =	\$153,000
Metal Louvers	Ventilation louvers on truss walls	30 EA x	\$965.00 =	\$28,950
<b>05 SUBTOTAL - METALS</b>				<b>\$1,015,846</b>
<b>07. THERMAL AND MOISTURE PROTECTIONS</b>				
<b>Roofing Systems</b>				
Rigid Insulation	Polyiso Rigid Insulation	27,690 SF x	\$8.15 =	\$225,674
Coverboard	1/2"	27,690 SF x	\$1.45 =	\$40,151
Membrane	60 Mil Single Ply TPO	27,690 SF x	\$7.36 =	\$203,798
Roof Edge	Blocking & Metal Flashing	720 LF x	\$81.25 =	\$58,500
Waterproofing & Caulking	Misc. Waterproofing & Caulking	1 LSUM x	\$22,000.00 =	\$22,000
<b>07 SUBTOTAL - WOODS &amp; PLASTICS</b>				<b>\$550,122</b>
<b>08. OPENINGS</b>				
<b>Doors</b>				
Storefront Door System		2 EA x	\$9,250.00 =	\$18,500
Bi-Fold Door System		1 EA x	\$19,250.00 =	\$19,250
<b>Exterior Glazing Systems</b>				
Curtain Wall system				
YKK Curtain Wall System	YKK System	4,900 SF x	\$300.00 =	\$1,470,000
<b>08 SUBTOTAL - OPENINGS</b>				<b>\$1,507,750</b>

# OPTION 2

## LONG CENTER RENOVATIONS

MAS	ITEM	DESCRIPTION		UOM		COST	TOTAL	
<b>09. FINISHES</b>								
<b>Wall Assembly Systems</b>								
	Framing	Metal Studs & Clips	17,595	SF	x	\$8.28 =	\$145,687	
	Sheathing	Exterior Gyp Board	17,595	SF	x	\$6.74 =	\$118,590	
	Insulation	Batt & Rigid Insulation	11,710	SF	x	\$3.25 =	\$38,058	
	Stucco Systems	3 Coat Stucco only Ply inc. VB	17,595	SF	x	\$9.15 =	\$160,994	
	Paint	Paint on Stucco & Gyp	29,305	SF	x	\$2.15 =	\$63,006	
	Gypsum Board	5/8 Moisture Resistant Gyp	11,710	SF	x	\$3.10 =	\$36,301	
<b>Wall Finishes</b>								
	Paint / Epoxy Painting	Existing Structural Steel Systems	1	LSUM	x	\$18,748.75 =	\$18,749	
<b>Floor Finishes</b>								
	Floor Preparation	Prepare Pool Deck for Epoxy	11,040	SF	x	\$2.15 =	\$23,736	
	Epoxy Flooring Systems	Pool Deck	11,040	SF	x	\$12.48 =	\$137,779	
<b>Ceiling Finishes</b>								
	Sand Blasting	Interior Ceiling	25,200	SF	x	\$4.32 =	\$108,864	
	Paint / Epoxy Painting	Structural Beams & Deck	25,200	SF	x	\$8.00 =	\$201,600	
09	<b>SUBTOTAL - FINISHES</b>							<b>\$1,053,363</b>
<b>10. SPECIALTIES</b>								
<b>Signage</b>								
	Backlight Marquee Signage	Wall Mounted	1	LSUM	x	\$32,000.00 =	\$32,000	
10	<b>SUBTOTAL - SPECIALTIES</b>							<b>\$32,000</b>
<b>22. PLUMBING</b>								
<b>Sanitary Specialties</b>								
	Roof Drain Pipe	Replace Existing Systems	480	LF	x	\$108.80 = \$	52,224.00	
	Roof Drain		3	EA	x	\$985.00 = \$	2,955.00	
22	<b>SUBTOTAL - PLUMBING</b>							<b>\$55,179</b>
<b>23. HVAC</b>								
<b>HVAC Systems</b>								
	HVAC Equipment	Per Engineer's Quote	1	lsum	x	\$1,293,000.00 =	\$1,293,000	
	HVAC Installation & Other Materials		1	lsum	x	\$310,415.00 =	\$310,415	
23	<b>SUBTOTAL - HVAC SYSTEMS</b>							<b>\$1,603,415</b>
<b>26. ELECTRICAL</b>								
<b>Electrical Service &amp; Distribution</b>								
	Electrical Systems	Fixtures & Signage Connection - Wiring, Breakers, Etc.	1	LSUM	x	\$124,250.00 =	\$124,250	
<b>Lighting &amp; Fixtures</b>								
	Exterior Light Fixtures		10	EA	x	\$1,850.00 =	\$18,500	
	Pivot Fans		6	EA	x	\$2,225.00 =	\$13,350	
26	<b>SUBTOTAL - ELECTRICAL SYSTEMS</b>							<b>\$156,100</b>
<b>32. EXTERIOR IMPROVEMENTS</b>								
<b>Landscaping &amp; Irrigation</b>								
	Landscaping	Landscaping Allowance	1	LSUM	x	\$20,000.00 =	\$20,000	
32	<b>SUBTOTAL - EXTERIOR IMPROVEMENTS</b>							<b>\$20,000</b>
<b>35. WATERWAY &amp; MARINE</b>								
<b>Pool Equipment &amp; Specialties</b>								
	Pool Equipment	Cost Provided by Pool Consultant	1	LSUM	x	\$286,000.00 =	\$286,000	
	Pool Edge - Trench Drain Curb	Natare Grating - Includes Install	494	LF	x	\$131.28 =	\$64,852	

# OPTION 2

## LONG CENTER RENOVATIONS

MAS ITEM	DESCRIPTION	UOM	COST	TOTAL
	Pool Repair	Pool Repair Allowance	1 LSUM x \$20,000.00 =	\$20,000
<b>35 SUBTOTAL - WATERWAY &amp; MARINE</b>				<b>\$370,852</b>
<b>48. ELECTRICAL POWER GENERATION</b>				
	<b>Solar Power Generating Systems</b>			
	Photovoltaic Array System	171 kW System	1 LSUM x \$468,000.00 =	\$468,000
<b>48 SUBTOTAL - ELECTRICAL POWER GENERATION</b>				<b>\$468,000</b>
<b>01. GENERAL REQUIREMENTS</b>				
<b>Project Management</b>				
<b>Project Supervision</b>				
	Project Manager(s) Time	(1) Project Manager(s)	8 MTH x \$11,088.00 =	\$88,704
	Assistant Project Manager(s) Time	(1) Assistant Project Manager(s)	8 MTH x \$14,300.00 =	\$114,400
	Project Accountant(s)	(1) Project Accountant	8 MTH x \$600.00 =	\$4,800
	Software	Project Management Software & Cloud Services	8 MTH x \$1,850.00 =	\$14,800
<b>Field Supervision</b>				
	Project Site Superintendent	(1) Site Superintendent(s)	8 MTH x \$16,800.00 =	\$134,400
	Assistant Superintendent	(1) Site Assistant Superintendent(s)	8 MTH x \$14,800.00 =	\$118,400
<b>Field Office &amp; Supplies</b>				
	Site Office & Equipment	Jobsite Trailer & Office Supplies	8 MTH x \$2,845.00 =	\$22,760
	Temporary Toilets		8 MTH x \$750.00 =	\$6,000
	Field Office Supplies		8 MTH x \$215.00 =	\$1,720
<b>Maintenance &amp; Housekeeping</b>				
	Jobsite Clean-up	Temp Labor / Clean-up	8 MTH x \$1,750.00 =	\$14,000
<b>Temporary Controls &amp; Safety</b>				
	Safety Supplies		1 LSUM x \$1,200.00 =	\$1,200
	Site Signage		1 LSUM x \$2,000.00 =	\$2,000
<b>Construction Aids, Equipment, &amp; Tools</b>				
	Equipment Rentals		1 LSUM x \$10,000.00 =	\$10,000
	Punchlist Allowance		1 LSUM x \$3,500.00 =	\$3,500
<b>Trash and Dump Charges</b>				
	Dumpster & Trash Removal Charges		25,340 SF x \$0.95 =	\$24,073
<b>Testing and Quality Control</b>				
	Quality Control	Quality Control Manager	1 LSUM x \$9,825.00 =	\$9,825
<b>SUBTOTAL - COST OF WORK</b>				<b>\$7,700,606</b>
<b>Cascading Costs</b>				
	General Liability Insurance	Cost of Work	x 1.00% =	\$77,006
	Builder's Risk Insurance	Cost of Work	x 0.35% =	\$26,952
	Bonds	Cost of Work	x 1.00% =	\$77,006
<b>01 SUBTOTAL - GENERAL REQUIREMENTS</b>				<b>\$751,546</b>
<b>00. PROCUREMENT &amp; CONTRACTING</b>				
<b>Fees &amp; Overhead</b>				
	Contractor's Fee	Cost of Work	x 5.00% =	\$422,608
	Construction Contingency	Cost of Work	x 3.00% =	\$253,565
<b>00 SUBTOTAL - CONTRACTOR'S FEE &amp; CONTINGENCY</b>				<b>\$676,172</b>
<b>PROJECT TOTAL</b>				<b>\$8,557,743</b>

# SUN DECK

## LONG CENTER RENOVATIONS

MAS	ITEM	DESCRIPTION	UOM	COST	TOTAL	
<b>02. EXISTING CONDITIONS</b>						
	<b>Selective Demolition</b>					
	Foundations		1,700 SF x	\$6.15 =	\$10,455	
	Steel Demolition		1 LSUM x	\$3,200.00 =	\$3,200	
	Fence Demolition		145 LF x	\$6.00 =	\$870	
	<b>Minor Site Demolition</b>					
	Landscaping Demolition		1 LSUM x	\$1,800.00 =	\$1,800	
	<b>Protection &amp; Controls</b>					
	Temporary Protection	Misc. Protection for Existing to Remain and WIP	1 LSUM x	\$4,500.00 =	\$4,500	
02	<b>SUBTOTAL - EXISTING CONDITIONS</b>					<b>\$20,825</b>
<b>03. CONCRETE</b>						
	<b>Foundation Systems</b>					
	Concrete Foundations	Foundations	205 LF x	\$78.50 =	\$16,093	
	Slab on Grade		1,700 SF x	\$11.15 =	\$18,955	
	<b>Concrete Patching</b>					
	Concrete & Masonry Patching	Misc. repair of existing walls as needed	1 LSUM x	\$10,000.00 =	\$10,000	
03	<b>SUBTOTAL - CONCRETE</b>					<b>\$45,048</b>
<b>04. MASONRY</b>						
	<b>Wall Assembly</b>					
	CMU		1,952 SF x	\$24.50 =	\$47,824	
04	<b>SUBTOTAL - MASONRY</b>					<b>\$47,824</b>
<b>05. METALS</b>						
	<b>Structural Steel Systems</b>					
	Steel Joists & Metal Decking		1,700 SF x	\$21.50 =	\$36,550	
	Structural Components	Columns & Beams	182 LF x	\$165.50 =	\$30,121	
05	<b>SUBTOTAL - METALS</b>					<b>\$66,671</b>
<b>07. THERMAL AND MOISTURE PROTECTIONS</b>						
	<b>Roofing Systems</b>					
	Rigid Insulation	Polyiso Rigid Insulation	1,700 SF x	\$8.15 =	\$13,855	
	Coverboard	1/2"	1,700 SF x	\$1.45 =	\$2,465	
	Membrane	60 Mil Single Ply TPO	1,700 SF x	\$7.36 =	\$12,512	
	Roof Edge	Blocking & Metal Flashing	205 LF x	\$81.25 =	\$16,656	
	Waterproofing & Caulking	Misc. Waterproofing & Caulking	1 LSUM x	\$8,000.00 =	\$8,000	
07	<b>SUBTOTAL - WOODS &amp; PLASTICS</b>					<b>\$53,488</b>
<b>08. OPENINGS</b>						
	<b>Exterior Glazing Systems</b>					
	Operable Glazing		596 SF x	\$192.00 =	\$114,432	
08	<b>SUBTOTAL - OPENINGS</b>					<b>\$114,432</b>
<b>09. FINISHES</b>						
	<b>Wall Assembly Systems</b>					
	Framing	Metal Studs & Clips	650 SF x	\$8.28 =	\$5,382	
	Sheathing	Exterior Gyp Board	650 SF x	\$6.74 =	\$4,381	
	Insulation	Batt & Rigid Insulation	650 SF x	\$3.25 =	\$2,113	
	Stucco Systems	3 Coat Stucco only Ply inc. VB	650 SF x	\$9.15 =	\$5,948	
	Paint	Paint on Stucco & Gyp	650 SF x	\$2.15 =	\$1,398	
	Gypsum Board	5/8 Moisture Resistant Gyp	650 SF x	\$3.10 =	\$2,015	

<b>Wall Finishes</b>								
Stucco	Direct Applied to CMU	2,006	SF	x	\$8.50	=		\$17,051
Paint		4,012	SF	x	\$2.10	=		\$8,425
<b>Floor Finishes</b>								
Epoxy Flooring Systems	Continuation of Pool Deck	1,624	SF	x	\$12.48	=		\$20,268
<b>Ceiling Finishes</b>								
Acoustical Ceiling System		1,624	SF	x	\$11.50	=		\$18,676
Paint		1,624	SF	x	\$2.15	=		\$3,492
<b>09 SUBTOTAL - FINISHES</b>								<b>\$89,147</b>
<b>26. ELECTRICAL</b>								
<b>Electrical Service &amp; Distribution</b>								
Electrical Systems	Wiring, Recepticles, Etc.	1,624	SF	x	\$12.50	=		\$20,300
<b>Electrical Fixtures</b>								
Lighting Fixtures		8	EA	x	\$1,850.00	=		\$14,800
<b>26 SUBTOTAL - ELECTRICAL SYSTEMS</b>								<b>\$35,100</b>
<b>31. EARTHWORK</b>								
<b>Sitework General</b>								
Building Pad & Grade		1	LSUM	x	\$11,260.00	=		\$11,260
<b>31 SUBTOTAL - EARTHWORK</b>								<b>\$11,260</b>
<b>32. EXTERIOR IMPROVEMENTS</b>								
<b>Landscaping &amp; Irrigation</b>								
Landscaping	Landscaping Allowance	1	LSUM	x	\$8,000.00	=		\$8,000
<b>32 SUBTOTAL - EXTERIOR IMPROVEMENTS</b>								<b>\$8,000</b>
<b>01. GENERAL REQUIREMENTS</b>								
<b>Project Management</b>								
<b>Project Supervision</b>								
Project Manager(s) Time	(1) Project Manager(s)	4	MTH	x	\$8,400.00	=		\$33,600
Software	Project Management Software & Cloud Services	4	MTH	x	\$1,850.00	=		\$7,400
<b>Field Supervision</b>								
Project Site Superintendent	(1) Site Superintendent(s)	4	MTH	x	\$16,800.00	=		\$67,200
<b>Field Office &amp; Supplies</b>								
Temporary Toilets		4	MTH	x	\$750.00	=		\$3,000
Field Office Supplies		4	MTH	x	\$215.00	=		\$860
<b>Maintenance &amp; Housekeeping</b>								
Jobsite Clean-up	Temp Labor / Clean-up	4	MTH	x	\$1,750.00	=		\$7,000
<b>Temporary Controls &amp; Safety</b>								
Safety Supplies		1	LSUM	x	\$1,200.00	=		\$1,200
Site Signage		1	LSUM	x	\$2,000.00	=		\$2,000
<b>Construction Aids, Equipment, &amp; Tools</b>								
Equipment Rentals		1	LSUM	x	\$2,500.00	=		\$2,500
Punchlist Allowance		1	LSUM	x	\$1,250.00	=		\$1,250
<b>Trash and Dump Charges</b>								
Dumpster & Trash Removal Charges		3	EA	x	\$850.00	=		\$2,550
<b>SUBTOTAL - COST OF WORK</b>								<b>\$620,355</b>
<b>Cascading Costs</b>								
General Liability Insurance	Cost of Work	x	1.00%	=				\$6,204
Builder's Risk Insurance	Cost of Work	x	0.35%	=				\$2,171
Bonds	Cost of Work	x	1.00%	=				\$6,204
<b>01 SUBTOTAL - GENERAL REQUIREMENTS</b>								<b>\$143,138</b>
<b>00. PROCUREMENT &amp; CONTRACTING</b>								
<b>Fees &amp; Overhead</b>								
Contractor's Fee	Cost of Work	x	6.00%	=				\$45,810
Construction Contingency	Cost of Work	x	3.00%	=				\$22,905
<b>00 SUBTOTAL - CONTRACTOR'S FEE &amp; CONTINGENCY</b>								<b>\$68,714</b>
<b>PROJECT TOTAL</b>								<b>\$703,647</b>



# **CITY OF CLEARWATER LONG CENTER NATATORIUM**

## **Technical Memorandum Draft Long Center Structure Repairs Phase II**

---

Date: December 07, 2023

**Prepared for:**

Wannemacher Jensen Architects, Inc.  
1559 Fruitville Road  
Sarasota, FL 34236

**Prepared by:**

McKim & Creed, Inc.  
1365 Hamlet Avenue  
Clearwater, FL 33756  
Firm License No. 29588

**McKim & Creed Project No. 09692-0001**

## Contents

1. INTRODUCTION .....	1
1.1 Background .....	1
1.2 Project Goals and Objectives .....	3
2. NON-DESTRUCTIVE EVALUATION DATA COLLECTION .....	5
2.1 Testing .....	5
2.2 Report .....	5
3. CONCLUSIONS .....	8
APPENDIX A – ULTRASONIC THICKNESS TESTING REPORT .....	A

## TABLES

Table 2.1– Minimum Measured Thickness and Member Thickness Net Section Loss .....	6
---	---

## FIGURES

Figure 1.1 - Existing Long Center Site & Complex Layout .....	3
---	---

# 1. INTRODUCTION

---

## 1.1 Background

The City of Clearwater's Long Center Natatorium (LCN) was originally constructed in 1988 as part of a four building complex providing education, training, and athletic facilities to the local community. The complex consists of an approximate 15.8 acre property located in central Pinellas County on the east side of North Belcher Road, almost midway between NE Coachman Road (Florida state road (SR 590)) and Sunset Point Road (county road 576). The street address is 1501 North Belcher Road in Clearwater, Florida.

The record drawings reviewed indicated the LCN as "Building A" for the complex. The four building complex is "L"-shaped with Building A and Building B comprising the north / south oriented leg and Building B, Building C and Building D comprising the east / west oriented leg. Building A is north of Building B. The site and building complex layout is shown below in **Figure 1.1**.

The LCN is primarily a structural steel framed building. Record drawings reviewed indicated the building frames are supported by cast-in-place (c.i.p.) reinforced concrete shallow foundations. The shallow foundations consist of spread footings at the columns and continuous strip footings supporting wall assemblies.

The structural steel framing at the LCN consists of roof truss assemblies spanning north / south direction over the approximate 120 foot distance over the Main and Therapeutic pools and their surrounding c.i.p. reinforced concrete pool deck areas. The trusses are comprised of square tube hollow shaped sections (HSS) of various thickness. Steel columns for the LCN consist of wide flange sections at the east and west side walls and vertical truss space frames below the roof trusses, along the north and south walls. These vertical space frame trusses consist of HSS members similar to the roof trusses. The steel framing in the pool area is exposed structural steel with a paint coating system finish. Horizontal beams and girts, in addition to diagonal bracing between the various trusses, consists of HSS square or rectangular members, similar in appearance to the trusses.

In November of 2021 McKim & Creed (M&C) contracted with the City of Clearwater to review and recommend specific repairs to interior portions of the existing approximately 33 year old LCN steel structure around the pool area. The city reported to M&C their personnel have observed multiple locations where the existing structural steel and anchor bolts appeared to be exhibiting loss of section due to corrosion. The interior of the pool area is enclosed by the existing roof and glass panels between the steel HSS sections at the north, east and west walls. The interior of this enclosed area of the LCN experiences humidity, thermal differences with the exterior environment and chemical off-gassing from the chlorine in

the pool. To determine the specific repairs M&C conducted a visual review of the facility to document the existing conditions, utilizing lift equipment to achieve an up-close observation of the steel assemblies, from pool deck elevation to the roof. Upon completion of documenting these existing conditions, M&C provided the city construction drawings detailing recommended repairs. Existing conditions where M&C recommended repairs, in general included the following:

1. Repair areas where the existing coating has peeled, flaked, bubbled, or other and no longer adheres to the surface of the steel.
2. Repair areas where coating exhibited conditions noted in Item No. 1 and surface rust observed.
3. Repair areas where coating exhibited conditions noted in Item No. 1 and rust observed, appeared to extend beyond the surface, into the steel sections and potentially reducing the thickness of the steel.
4. Repair areas where coating exhibited conditions noted in Item No. 1 and rust observed, extended through the surface, leaving a hole in the steel sections.

Recommended repairs in general included the following:

1. Remove existing areas of no and /or loose coating system top and base coats. Provide the required surface preparation and install the new repair coating system.
2. Remove existing surface rusted areas observed and provide the required surface preparation cleaning and install the new repair coating system.
3. Remove existing rusted areas observed, weld new plates and / or angles to the existing steel and provide the required surface preparation cleaning and install the new repair coating system.
4. Remove existing surface rust from areas around holes, weld new plates and / or angles to the existing steel and provide the required surface preparation cleaning and install the new repair coating system.

After completing the construction drawings M&C worked with the city to prioritize locations requiring immediate repairs and opting to repair remaining areas in a future project.

Figure 1.1 - Existing Long Center Site & Complex Layout



## 1.2 Project Goals and Objectives

The City of Clearwater has contracted with Wannemacher Jensen Architects (WJA), to provide architectural services to improve the LCN. It is M&C's understanding WJA's improvements include, but not limited to the following:

1. Removal of the existing glass panels and installation of a new curtain wall system outside of the existing steel frame.
2. Upgrading the air handling system in the pool area.
3. Implementing Phase II of repairing the LCN interior structural steel locations not addressed in the previous phase.

The previous phase by M&C included an onsite up-close visual review of the facility to document the existing conditions reported by the city's personnel. Documentation from construction administration activities of the initial construction could not be provided by the city. In addition to the site review, M&C's scope of services included review of existing record drawings from the original construction. However, services excluded from M&C's site review included the following:

1. Non-destructive testing of existing concrete, steel, or masonry assemblies.
2. Load testing of existing anchor bolt, connection bolt or welded connections to determine capacities.

3. Testing existing materials for chemical composition or material grades.
4. Load testing to determine existing construction assembly deflections.

To assist in implementing the LCN Phase II repairs, in September 2023, M&C subcontracted with WJA to conduct a Non-Destructive Evaluation (NDE), to gather additional data regarding the existing conditions initially reviewed in the previous phase, and potentially document new additional locations recommended for repairs.

This Technical Memorandum (TM) is provided to bridge the work conducted for the previous phase repairs project with the new NDE data and develop a summary of updated conclusions and recommendations.

This TM will be utilized to help WJA, and M&C achieve the following future project goals:

1. Provide a complete set of Issued For Permit documents addressing the repair locations, the specific repair recommendations, and details for each location, in addition to the finish coating system.
2. Issue full size drawings to the City of Clearwater Building Department.
3. Issue full and half size drawings to the future CMAR to be hired by the City of Clearwater.

## 2. NON-DESTRUCTIVE EVALUATION DATA COLLECTION

---

M&C subcontracted with S&ME in September 2023 to material test the existing steel structure. S&ME mobilized to the LCN the second week of October. Testing the structural steel began October 9, 2023 and concluded October 13, 2023.

### 2.1 Testing

S&ME utilized the “Long Center Natatorium Structural Frame Repairs” drawings prepared by M&C and dated May 2022, detailing the locations where repairs were recommended, for the City of Clearwater. From these drawings M&C documented approximately 122 steel joints. Focusing on locations where corrosion was visually evident lowered the number of locations testing would occur. Testing the steel involved non-destructive tests (NDT) to determine existing steel thickness at and around the points of corrosion. In general the majority of the locations of corrosion occur at steel connection joints (nodes) between the various, HSS tube to HSS tube, and HSS tube to wide flange column connections. In general testing included the following:

1. The NDT was an ultrasonic thickness test (UTT) procedure.
2. The NDT was performed by personnel certified to conduct Level II UTT.
3. The equipment utilized to conduct the NDT an Olympus, model no. 38DL Plus, ultrasonic thickness gage. facility.
4. The NDT testing procedure included conducting an initial test reading at the joint centerline, followed by additional tests at approximate 4 inch intervals out from the centerline, and concluding at approximately 16 inches maximum from the initial test.
5. Each joint test was documented with an Ultrasonic Examination Thickness Report detailing test information and results.
6. Each joint test location was given the same designation utilized by M&C in the May 2022 drawings.

### 2.2 Report

The *Report of UT Thickness Testing of Existing Structural Steel Members Clearwater Long Center Pool* by S&ME was November 6, 2023. In general the report includes project information regarding the site, testing services, methods of inspection for the tests, and comments regarding results of data. In addition individual Ultrasonic Examination Thickness Report for each joint tested and pictures from the time onsite

of the NDT's are included in the appendices. A summary of the minimum thickness measured at each joint is provided in **Table 2.1** below. Regarding the table below note the following:

- Node Mk. No. = Building column grid.
- Elevation Mk. No. = Frame level height from bottom of column (5 framing intersects typical).

*Table 2.1– Minimum Measured Thickness and Member Thickness Net Section Loss*

Node Mk. No.	Elevation Mk. No.	Minimum Measured Thickness (inches)	Original Member Thickness (inches)	Member Thickness Net Loss (inches)
B-1-T2	2	0.103	0.25	0.147
B-1.3-T1	1	0.070	0.3125	0.243
B-2-T1	3	0.201	0.25	0.049
B-2.3-T1	2	0.163	0.3125	0.150
B-3-T1	3	0.113	0.25	0.137
B-4-T1	1	0.113	0.3125	0.200
B-4.3-T1	3	0.198	0.3125	0.115
B-5-T1	1	0.118	0.25	0.132
B-5.3-T1	1	0.097	0.3125	0.215
B-6-T1	1	0.239	0.3125	0.074
B-6.3-T1	1	0.234	0.25	0.016
B-7-T1	2	0.167	0.3125	0.146
B-8-T1	1	0.226	0.25	0.024
B-8.3-T1	2	0.211	0.25	0.039
B-9-T1	2	0.117	0.3125	0.196
B-9.3-T1	1	0.221	0.25	0.029
B-10-T1	2	0.208	0.25	0.042
B-10.3-T2	1	0.215	0.25	0.035
B.2-1-T2	1	0.405	0.50	0.095
B.4-1-T2-N	1	0.457	0.50	0.043
B.4-1-T2-S	1	0.376	0.50	0.124
B.4-10.3-T2-N	3	0.491	0.50	0.009
B.4-10.3-T2-S	2	0.478	0.50	0.022
B.5-1-T2-N	1	0.440	0.50	0.060
B.5-1-T2-S	1	0.440	0.50	0.060
B.5-10.3-T2	1	0.458	0.50	0.042
B.7-1-T2-N	1	0.440	0.50	0.060
B.7-1-T2-S	3	0.440	0.50	0.060
B.7-10.3-T2-N	3	0.467	0.50	0.033
B.7-10.3-T2-S	1	0.455	0.50	0.045
B.9-1-T2-N	3 & 4	0.440	0.50	0.060
B.9-1-T2-S	1	0.433	0.50	0.067

B.9-10.3-T2-N	1	0.328	0.50	0.172
B.9-10.3-T2-S	2	0.440	0.50	0.060
D-1-T2	2	0.112	0.25	0.130
D1.3-T1	4	0.185	0.25	0.065
D-10-T1	3	0.217	0.25	0.033
D-10.3-T2	2	0.207	0.25	0.043

Based upon the values shown in **Table 2.1** net section loss of the steel members varies from less than 1/16" to 1/4" maximum. For areas where corrosion was initially visually observed the design team has additional data to review the repair recommendations from the previous phase. Regarding the NDT report data provided note the following:

1. There were joints that were not tested due to safety access concerns with positioning the lift to access the steel and regarding the height of the joints, existing conduits, utilities and / or signage preventing hindering the vertical lift space.
2. Although the report provides a summary table indicating minimum member thickness measured for a joint assembly at each column, review of the individual Ultrasonic Examination Thickness Report documents for the various joints, indicates there are conditions where a single column has additional connections where the test results indicate section loss for multiple members.
3. The report includes information indicating locations where the extents of existing corrosion have increased in severity.

### 3. CONCLUSIONS

---

The information provided in the NDT and obtained for this NDE memorandum confirms section loss of the steel section wall thickness, for various connections observed to be exhibiting signs of corrosion, in the previous phase of the structural repairs. In addition the report data indicates profiles of the section loss from the center of the joints which can be used to assess the Phase II repair recommendations by the following:

1. Knowing the limits and the depth of the section loss allows the design team to be more efficient with the material lengths and widths of the repair plates and angles.
2. Knowing the depth of the section loss can help ensure the design team is providing an adequate design capable of withstanding the expected stresses the sections could be subjected to.

Utilizing the Ultrasonic Examination Thickness Report documents, M&C will use the member thickness data to verify the geometry of the connection repairs recommended in the previous phase. Review of the reports has indicated multiple locations where the plate assemblies may have to be revised, or added, to include diagonal bracing or horizontal beam and / or girt sections that were not accounted for due to the condition of the steel at the time of the previous visual observation.

The information provided in the NDT did not appear to indicate new areas of corrosion that have developed since the previous phase repairs. However, the NDT did indicate existing locations that have since continued to corrode. Note the following:

1. The most severe existing area of increased corrosion appears to be Node Mk. No. D-1T-2-3. At this location corrosion has progressed to a hole in the HSS tube wall (ref. photo nos. 8 & 9 pgs. 94 & 95 Appendix A).

The improvements WJA is planning and designing for the LCN will assist in the future maintenance of this facility for the City of Clearwater, resulting in a more efficient ventilation and air handling system, in addition to extending the structure's service life. This NDE is a critical component for the design team to extend the structure's service life, by providing an updated set of Issue For Permit documents. Provision of these documents will assist the design team in moving toward completion of project goals regarding implementing the second phase of structural repairs to the existing steel structure, and issuing repair documents to the city's Building department and the future construction managing consultant.

## APPENDIX A – ULTRASONIC THICKNESS TESTING REPORT



Report of UT Thickness Testing of  
Existing Structural Steel Members  
Clearwater Long Center Pool  
Clearwater, Florida  
S&ME Project No. 23050318

PREPARED FOR:

**McKim & Creed, Inc.**  
**1730 Varsity Drive, #500**  
**Raleigh, North Carolina 27606**

PREPARED BY:

**S&ME, Inc.**  
**3201 Spring Forest Road**  
**Raleigh, North Carolina 27616**

**November 6, 2023**



November 6, 2023

McKim & Creed, Inc.  
1730 Varsity Drive, #500  
Raleigh, North Carolina 27606

Attention: Mr. Aubrey Haudricourt, P.E.

Reference: **Report of UT Thickness Testing of Existing Structural Steel Members**  
Clearwater Long Center Pool Structural Assessment  
Clearwater, Florida  
S&ME Project No. 23050318

Dear Mr. Haudricourt:

S&ME, Inc. (S&ME) has completed the ultrasonic (UT) thickness testing services of the existing structural steel at the Clearwater Long Center Pool located at 1501 North Belcher Road, Clearwater, Florida. Our services were performed in general accordance with S&ME Proposal No. 23050318 dated April 5, 2023 as authorized by David Ardman, with McKim & Creed, Inc. on September 21, 2023. As noted in our proposal, our testing was limited to areas of the existing structure which were safe to access at the time of our site visit.

## ◆ PROJECT INFORMATION

Our understanding of the project is based on information provided to Mr. Perry Vezina of S&ME by Mr. Aubrey Haudricourt and David Ardman, with McKim & Creed, Inc. through a series of emails and phone conversations between April 4, 2023, and the date of this report. Appended to the emails was the following document:

- ◆ Structural Frame Repairs, Sheets S0.00 through S1.13 dated May 23, 2022 as prepared by McKim & Creed, Inc.

We understand that McKim & Creed has performed a visual structural assessment of the existing structural steel at the Clearwater Long Center Pool located at 1501 North Belcher Road, Clearwater, Florida. This assessment identified several structural nodes or joints with visually evident corrosion. We also understand that in order to design repairs for the identified corrosion McKim & Creed requested nondestructive testing be performed to determine the material thickness at and around the corroded structural nodes or joints. McKim & Creed requested S&ME Inc. perform ultrasonic thickness testing of the structural steel members at the joints identified in the attached drawings S1.03-S1.13 (Appendix III). We understand that there are approximately 122 joints requiring testing.

## ◆ METHODS OF INSPECTION

Ultrasonic thickness testing was performed on safely accessible members using an Olympus, model 38DL Plus, ultrasonic thickness gage. Ultrasonic thickness testing was performed by Mr. Larry Jernigan, a certified ultrasonic thickness testing (UTT) level II. UT thickness measurements are annotated on the UTT reports in Appendix I of this



## Report of UT Thickness Testing of Existing Structural Steel Members

Clearwater, Florida  
S&ME Project No. 23050318

report. Ultrasonic thickness testing was performed and interpreted in general conformance to ASTM E 797, and S&ME work instruction WI-TP-NDT-UT-02.

Each location was tested from the inside of the structure from a scissor lift provided by McKim & Creed. Measurements were taken starting at the center line of the column and the node and radiating outward along the members at approximately 4-inch intervals at each node identified. Testing was limited to areas which were safe to access at the time of our site visit. A scissor lift was used for access to elevated locations during field examination activities. The lift was not able to safely access the entire structure due to conflict with the HVAC ducting support structure.

### ◆ FINDINGS

Ultrasonic thickness measurements were taken at safely accessible steel members identified on Structural Frame Repair sheets supplied by McKim & Creed prior to our testing. Complete thickness information is annotated in Appendix I of this report. The summary table below identifies the minimum thickness measurement recorded of all the members tested at each node. Many of the nodes appear to have been constructed using HSS members of different nominal wall thicknesses. The measurements in red below, and on the thickness data sheets in Appendix I, indicate a measurement  $\geq 0.050$ " below what appears to have been the original nominal thickness of the member based on the other thickness measurements of that particular member. This is for reporting purposes only and assumes the following commercially available HSS member nominal wall thicknesses:

- 0.250"
- 0.313"
- 0.375"
- 0.500"

Minimum Measured Thickness at Each Node					
<b><u>Node Mark</u></b>	<b><u>Elevation 1</u></b>	<b><u>Elevation 2</u></b>	<b><u>Elevation 3</u></b>	<b><u>Elevation 4</u></b>	<b><u>Elevation 5</u></b>
D-1.3-T1	0.202"	NST	NST	0.185"	NST
D-1-T2	0.229"	0.112"	0.205"	0.125"	NST
B-1-T2	0.137"	0.103"	0.105"	NST	NSA
B-1.3-T1	0.070"	0.123"	0.200"	NSA	NST
B-2-T1	0.218"	0.209"	0.201"	NST	NST
B-2.3-T1	0.254"	0.163"	0.203"	NST	NST
B-3-T1	NST	0.225"	0.113"	NSA	NSA
B-3.3-T1	NST	NST	NST	NSA	NSA
B-4-T1	0.113"	NST	0.213"	NSA	NST
B-4.3-T1	NST	0.222"	0.198"	NSA	NSA
B-5-T1	0.118"	0.123"	0.250"	NSA	NSA
B-5.3-T1	0.097"	0.222"	0.180"	NSA	NSA
B-6-T1	0.114"	0.214"	0.211"	NSA	NSA
B-6.3-T1	0.149"	0.203"	0.222"	NSA	NSA
B-7-T1	0.186"	0.167"	0.201"	NSA	NSA



**Report of UT Thickness Testing of Existing Structural Steel Members**

Clearwater, Florida  
S&ME Project No. 23050318

B-7.3-T1	NST	NST	NST	NSA	NSA
B-8-T1	0.226"	NST	NST	NST	NSA
B-8.3-T1	0.223"	0.211"	0.223"	NSA	NSA
B-9-T1	0.226"	0.117"	0.121"	NSA	NSA
B-9.3-T1	0.221"	0.222"	0.229"	NSA	NSA
B-10-T1	0.229"	0.208"	0.216"	NSA	NST
B-10.3-T2	0.215"	0.229"	0.227"	NSA	NSA
D-10.3-T2	0.228"	0.207"	0.231"	0.232"	NST
D-10-T1	0.228"	0.218"	0.217"	0.232"	NST
B.9-1-T2-S	0.433"	0.451"	0.445"	NST	NST
B.9-1-T2-N	0.450"	0.440"	0.440"	NST	NST
B.7-1-T2-S	NST	NST	0.440"	NST	NST
B.7-1-T2-N	0.440"	0.452"	NST	NST	NST
B.5-1-T2-S	0.440"	NST	NST	NST	NST
B.5-1-T2-N	0.440"	NST	NST	NST	NST
B.4-1-T2-S	0.376"	NST	NST	NST	NST
B.4-1-T2-N	0.457"	NST	NST	NST	NST
B.2-1-T2-N	0.405"	NST	0.440"	NST	NST
B.2-10.3-T2-S	NST	NST	NST	NSA	NST
B.4-10.3-T2-N	NST	NST	0.491"	NST	NSA
B.4-10.3-T2-S	0.485"	0.478"	NST	NSA	NST
B.5-10.3-T2-S	0.458"	NST	NST	NSA	NST
B.7-10.3-T2-N	NST	NST	0.467"	NST	NST
B.7-10.3-T2-S	0.455"	NST	NST	NSA	NST
B.9-10.3-T2-N	0.328"	0.435"	NST	NST	NST
B.9-10.3-T2-S	0.443"	0.441"	NST	0.229"	NST

- ◆ NST = Node not scheduled for testing.
- ◆ NSA = Node could not be safely accessed for testing.

**◆ SUMMARY**

Significant material thickness loss due to corrosion appeared to be localized near the junction of the nodes tested. Material thickness readings appeared more consistent with less loss as distance increased from the center of the nodes. Location D-1-T2-3 had complete through wall loss due to corrosion (see images 8 & 9 in Appendix II). Measurements annotated at this node represent readings taken adjacent to the visible through wall loss.



## Report of UT Thickness Testing of Existing Structural Steel Members

Clearwater, Florida

S&ME Project No. 23050318

### ◆ CLOSING

S&ME appreciates the opportunity to be of service to you. If you have any questions regarding the information provided herein, please do not hesitate to contact us.

Sincerely,

**S&ME, Inc.**

A handwritten signature in black ink, appearing to read 'Russell Ogden'.

Russell Ogden, ASNT NDT Level III  
NDE Operations Manager

A handwritten signature in black ink, appearing to read 'Perry R. Vezina'.

Perry R. Vezina, ASNT NDT Level III  
NDE/NDT Service Line Leader



**Report of UT Thickness Testing of Existing Structural Steel Members**

Clearwater, Florida  
S&ME Project No. 23050318

## Appendices

## Appendix I – UT Thickness Data Sheets

# ULTRASONIC EXAMINATION THICKNESS REPORT



ASME

S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616


Project #: 23050318	Report Date: 10-9-23
Project Name: Clearwater Natatorium UTT of structure framing	Procedure No. TR-NDT-UT-2
Project Location: Clearwater, FL	Material Type: <b>CS</b>
Client Name: McKim & Creed	Surface Condition: bare

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)		
Manufacturer: Olympus		Manufacturer: Panmetric		Material: CS	Step #	Thickness
Model No.: DL38		Model No.: D7908		Serial No: 988285	1	0.100"
Serial No: 110194505		Serial No.: 1159629			<b>5</b>	0.500"
Cable Type: N/A		Frequency: 7.5				
Cable Length: 48"		Size: 0.25"				

Location: **B.2-1-T2-1N** Center: **N/A**

	6"	8"	12"	16"	20"	24"	28"	32"
A		0.467"	0.471"	0.465"				
B	0.405"	0.463"	0.464"	0.461"				
C		0.463"	0.467"	0.467"				
D								
E								
F								
G								
H								
I								
J								
K								
L								
M								
N								
O								
Aa								
Bb								
Cc								
Dd								

West side view "1N"



Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the surface area.

Larry Jernigan  
Technician Name

UT Level II  
Level/Certification

Signature

10-9-23  
Date

Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.

# ULTRASONIC EXAMINATION THICKNESS REPORT



ASME

S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616


Project #: 23050318	Report Date: 10-9-23
Project Name: Clearwater Natatorium UTT of structure framing	Procedure No. TR-NDT-UT-2
Project Location: Clearwater, FL	Material Type: <b>CS</b>
Client Name: McKim & Creed	Surface Condition: bare

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)		
Manufacturer: Olympus		Manufacturer: Panmetric		Material: CS	Step #	Thickness
Model No.: DL38		Model No.: D7908		Serial No: 988285	1	0.100"
Serial No: 110194505		Serial No.: 1159629			<b>5</b>	0.500"
Cable Type: N/A		Frequency: 7.5				
Cable Length: 48"		Size: 0.25"				

Location: **B.2-1-T2-3N** Center: **N/A**

	4"	8"	12"	16"	20"	24"	28"	32"
A	/							
B	0.440"	0.455"	0.456"	0.457"	/			
C	/							
D	/							
E	/							
F	/							
G	/							
H	/							
I	/							
J	/							
K	/							
L	/							
M	/							
N	/							
O	/							
Aa	/							
Bb	/							
Cc	/							
Dd	/							

West side view "3N"



Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the surface area.

Larry Jernigan  
Technician Name

UT Level II  
Level/Certification

*Larry Jernigan*  
Signature

10-9-23  
Date

Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.

# ULTRASONIC EXAMINATION THICKNESS REPORT



ASME


S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616

Project #: 23050318	Report Date: 10-9-23
Project Name: Clearwater Natatorium UTT of structure framing	Procedure No. TR-NDT-UT-2
Project Location: Clearwater, FL	Material Type: <b>CS</b>
Client Name: McKim & Creed	Surface Condition: bare

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)		
Manufacturer: Olympus		Manufacturer: Panmetric		Material: CS	Step #	Thickness
Model No.: DL38		Model No.: D7908		Serial No: 988285	1	0.100"
Serial No: 110194505		Serial No.: 1159629			<b>5</b>	0.500"
Cable Type: N/A		Frequency: 7.5				
Cable Length: 48"		Size: 0.25"				

Location: **B.4-1-T2-1N&1S**      Center: **N/A**      "1S"      West side view      "1N"

	4"	8"	12"	16"	20"	24"	28"	32"
A								
B	0.460"	0.460"	0.457"	0.462"				
C								
D								
E	0.376"	0.463"	0.460"	0.461"				
F								
G								
H								
I								
J								
K								
L								
M								
N								
O								
Aa								
Bb								
Cc								
Dd								



Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the surface area.

<u>Larry Jernigan</u> Technician Name	<u>UT Level II</u> Level/Certification	 Signature	<u>10-9-23</u> Date
--	---	---------------	------------------------

*Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.*

# ULTRASONIC EXAMINATION THICKNESS REPORT



ASME

S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616


Project #: 23050318	Report Date: 10-12-23
Project Name: Clearwater Natatorium UTT of structure framing	Procedure No. TR-NDT-UT-2
Project Location: Clearwater, FL	Material Type: <b>CS</b>
Client Name: McKim & Creed	Surface Condition: Painted

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)		
Manufacturer: Olympus	Model No.: DL38	Manufacturer: Panmetric	Model No.: D790-SM	Material: CS	Step #	Thickness
Serial No.: 110194505	Cable Type: N/A	Serial No.: 754080	Frequency: 5 MHz	Serial No: 988285	1	0.100"
Cable Length: 48"		Size: 7.9mm			5	0.500"

Location: **B.4-10.3-T2-1S** Center: **N/A**

	4"	8"	12"	16"	20"	24"	28"	32"
A	/	/	/	/	/	/	/	/
B	0.485"	0.497"	0.495"	0.492"	/	/	/	/
C	/	0.511"	0.511"	0.508"	/	/	/	/
D	/	/	/	/	/	/	/	/
E	/	/	/	/	/	/	/	/
F	/	/	/	/	/	/	/	/
G	/	/	/	/	/	/	/	/
H	/	/	/	/	/	/	/	/
I	/	/	/	/	/	/	/	/
J	/	/	/	/	/	/	/	/
K	/	/	/	/	/	/	/	/
L	/	/	/	/	/	/	/	/
M	/	/	/	/	/	/	/	/
N	/	/	/	/	/	/	/	/
O	/	/	/	/	/	/	/	/
Aa	/	/	/	/	/	/	/	/
Bb	/	/	/	/	/	/	/	/
Cc	/	/	/	/	/	/	/	/

East view "1S"



Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the and/or due to thickness of epoxy coating along the surface areas.

Larry Jernigan  
Technician Name

UT Level II  
Level/Certification

Signature

10-12-23  
Date

Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.

# ULTRASONIC EXAMINATION THICKNESS REPORT



ASME


S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616

Project #: 23050318	Report Date: 10-12-23
Project Name: Clearwater Natatorium UTT of structure framing	Procedure No. TR-NDT-UT-2
Project Location: Clearwater, FL	Material Type: <b>CS</b>
Client Name: McKim & Creed	Surface Condition: Painted

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)		
Manufacturer: Olympus	Model No.: DL38	Manufacturer: Panmetric	Model No.: D790-SM	Material: CS	Step #	Thickness
Serial No.: 110194505	Cable Type: N/A	Serial No.: 754080	Frequency: 5 MHz	Serial No: 988285	1	0.100"
Cable Length: 48"		Size: 7.9mm			5	0.500"

Location: **B.4-10.3-T2-2S** Center: **N/A**

	4"	8"	12"	16"	20"	24"	28"	32"
A	/	/	/	/	/	/	/	/
B	0.480"	0.482"	0.481"	0.478"	/	/	/	/
C	/	/	/	/	/	/	/	/
D	/	/	/	/	/	/	/	/
E	/	/	/	/	/	/	/	/
F	/	/	/	/	/	/	/	/
G	/	/	/	/	/	/	/	/
H	/	/	/	/	/	/	/	/
I	/	/	/	/	/	/	/	/
J	/	/	/	/	/	/	/	/
K	/	/	/	/	/	/	/	/
L	/	/	/	/	/	/	/	/
M	/	/	/	/	/	/	/	/
N	/	/	/	/	/	/	/	/
O	/	/	/	/	/	/	/	/
Aa	/	/	/	/	/	/	/	/
Bb	/	/	/	/	/	/	/	/
Cc	/	/	/	/	/	/	/	/



Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the and/or due to thickness of epoxy coating along the surface areas.

Larry Jernigan  
Technician Name

UT Level II  
Level/Certification

Signature

10-12-23  
Date

Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.

# ULTRASONIC EXAMINATION THICKNESS REPORT



ASME

S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616


Project #: 23050318	Report Date: 10-12-23
Project Name: Clearwater Natatorium UTT of structure framing	Procedure No. TR-NDT-UT-2
Project Location: Clearwater, FL	Material Type: <b>CS</b>
Client Name: McKim & Creed	Surface Condition: Painted

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)		
Manufacturer: Olympus	Model No.: DL38	Manufacturer: Panmetric	Model No.: D790-SM	Material: CS	Step #	Thickness
Serial No.: 110194505	Cable Type: N/A	Serial No.: 754080	Frequency: 5 MHz	Serial No: 988285	1	0.100"
Cable Length: 48"		Size: 7.9mm			5	0.500"

Location: **B.4-10.3-T2-3N** Center: **N/A**

	4"	8"	12"	16"	20"	24"	28"	32"
A	0.508"	0.502"	0.504"	0.505"				
B	0.495"	0.491"	0.501"	0.496"				
C								
D								
E								
F								
G								
H								
I								
J								
K								
L								
M								
N								
O								
Aa								
Bb								
Cc								

"3N East view



Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the and/or due to thickness of epoxy coating along the surface areas.

Larry Jernigan  
Technician Name

UT Level II  
Level/Certification

Signature

10-12-23  
Date

Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.

# ULTRASONIC EXAMINATION THICKNESS REPORT



ASME

S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616


Project #: 23050318	Report Date: 10-9-23
Project Name: Clearwater Natatorium UTT of structure framing	Procedure No. TR-NDT-UT-2
Project Location: Clearwater, FL	Material Type: <b>CS</b>
Client Name: McKim & Creed	Surface Condition: bare

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)		
Manufacturer: Olympus	Model No.: DL38	Manufacturer: Panmetric	Model No.: D7908	Material: CS	Step #	Thickness
Serial No.: 110194505	Cable Type: N/A	Serial No.: 1159629	Frequency: 7.5	Serial No: 988285	1	0.100"
Cable Length: 48"	Cable Length: 48"	Size: 0.25"			5	0.500"

Location: **B.5-1-T2-1N&1S** Center: **N/A**

"1S" West side view "1N"

	4"	8"	12"	16"	20"	24"	28"	32"
A	/	/	/	/	/	/	/	/
B	0.440"	0.454"	0.453"	0.454"	/	/	/	/
C	/	0.460"	0.460"	0.459	/	/	/	/
D	0.444"	0.454"	0.452"	0.449"	/	/	/	/
E	/	0.442"	0.440"	0.440"	/	/	/	/
F	/	/	/	/	/	/	/	/
G	/	/	/	/	/	/	/	/
H	/	/	/	/	/	/	/	/
I	/	/	/	/	/	/	/	/
J	/	/	/	/	/	/	/	/
K	/	/	/	/	/	/	/	/
L	/	/	/	/	/	/	/	/
M	/	/	/	/	/	/	/	/
N	/	/	/	/	/	/	/	/
O	/	/	/	/	/	/	/	/
Aa	/	/	/	/	/	/	/	/
Bb	/	/	/	/	/	/	/	/
Cc	/	/	/	/	/	/	/	/
Dd	/	/	/	/	/	/	/	/



Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the surface area.

Larry Jernigan  
Technician Name

UT Level II  
Level/Certification

*Larry Jernigan*  
Signature

10-9-23  
Date

*Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.*

# ULTRASONIC EXAMINATION THICKNESS REPORT



ASME


S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616

Project #: 23050318	Report Date: 10-12-23
Project Name: Clearwater Natatorium UTT of structure framing	Procedure No. TR-NDT-UT-2
Project Location: Clearwater, FL	Material Type: <b>CS</b>
Client Name: McKim & Creed	Surface Condition: Painted

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)		
Manufacturer: Olympus	Model No.: DL38	Manufacturer: Panmetric	Model No.: D790-SM	Material: CS	Step #	Thickness
Serial No.: 110194505	Cable Type: N/A	Serial No.: 754080	Frequency: 5 MHz	Serial No: 988285	1	0.100"
Cable Length: 48"	Cable Length: 48"	Size: 7.9mm			<b>5</b>	0.500"

Location: **B.5-10.3-T2-1S** Center: **N/A**

	4"	8"	12"	16"	20"	24"	28"	32"
A	/	/	/	/	/	/	/	/
B	0.489"	0.493"	0.487"	0.485"	/	/	/	/
C	0.458"	0.460"	0.460"	0.460"	/	/	/	/
D	/	/	/	/	/	/	/	/
E	/	/	/	/	/	/	/	/
F	/	/	/	/	/	/	/	/
G	/	/	/	/	/	/	/	/
H	/	/	/	/	/	/	/	/
I	/	/	/	/	/	/	/	/
J	/	/	/	/	/	/	/	/
K	/	/	/	/	/	/	/	/
L	/	/	/	/	/	/	/	/
M	/	/	/	/	/	/	/	/
N	/	/	/	/	/	/	/	/
O	/	/	/	/	/	/	/	/
Aa	/	/	/	/	/	/	/	/
Bb	/	/	/	/	/	/	/	/
Cc	/	/	/	/	/	/	/	/



Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the and/or due to thickness of epoxy coating along the surface areas.

Larry Jernigan  
Technician Name

UT Level II  
Level/Certification

Signature

10-12-23  
Date

*Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.*

# ULTRASONIC EXAMINATION THICKNESS REPORT



ASME

S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616


Project #: 23050318	Report Date: 10-9-23
Project Name: Clearwater Natatorium UTT of structure framing	Procedure No. TR-NDT-UT-2
Project Location: Clearwater, FL	Material Type: <b>CS</b>
Client Name: McKim & Creed	Surface Condition: bare

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)		
Manufacturer: Olympus		Manufacturer: Panmetric		Material: CS	Step #	Thickness
Model No.: DL38		Model No.: D7908		Serial No: 988285	1	0.100"
Serial No: 110194505		Serial No.: 1159629			<b>5</b>	0.500"
Cable Type: N/A		Frequency: 7.5				
Cable Length: 48"		Size: 0.25"				

Location: **B.7-1-T2-1N** Center: **N/A**

	4"	8"	12"	16"	20"	24"	28"	32"
A	/	/	/	/	/	/	/	/
B	<b>0.440"</b>	<b>0.449"</b>	<b>0.454"</b>	<b>0.449"</b>	/	/	/	/
C	/	<b>0.473"</b>	<b>0.462"</b>	<b>0.476"</b>	/	/	/	/
D	/	/	/	/	/	/	/	/
E	/	/	/	/	/	/	/	/
F	/	/	/	/	/	/	/	/
G	/	/	/	/	/	/	/	/
H	/	/	/	/	/	/	/	/
I	/	/	/	/	/	/	/	/
J	/	/	/	/	/	/	/	/
K	/	/	/	/	/	/	/	/
L	/	/	/	/	/	/	/	/
M	/	/	/	/	/	/	/	/
N	/	/	/	/	/	/	/	/
O	/	/	/	/	/	/	/	/
Aa	/	/	/	/	/	/	/	/
Bb	/	/	/	/	/	/	/	/
Cc	/	/	/	/	/	/	/	/
Dd	/	/	/	/	/	/	/	/

West side view "1N"



Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the surface area.

Larry Jernigan  
Technician Name

UT Level II  
Level/Certification

*Larry Jernigan*  
Signature

10-9-23  
Date

*Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.*

# ULTRASONIC EXAMINATION THICKNESS REPORT



ASME


S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616

Project #: 23050318	Report Date: 10-9-23
Project Name: Clearwater Natatorium UTT of structure framing	Procedure No. TR-NDT-UT-2
Project Location: Clearwater, FL	Material Type: <b>CS</b>
Client Name: McKim & Creed	Surface Condition: bare

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)		
Manufacturer: Olympus	Model No.: DL38	Manufacturer: Panmetric	Model No.: D7908	Material: CS	Step #	Thickness
Serial No.: 110194505	Cable Type: N/A	Serial No.: 1159629	Frequency: 7.5	Serial No: 988285	1	0.100"
Cable Length: 48"		Size: 0.25"			5	0.500"

Location: **B.7-1-T2-2N** Center: **N/A**

	4"	8"	12"	16"	20"	24"	28"	32"
A								
B	0.452"	0.467"	0.468"	0.468"				
C								
D								
E								
F								
G								
H								
I								
J								
K								
L								
M								
N								
O								
Aa								
Bb								
Cc								
Dd								



Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the surface area.

<u>Larry Jernigan</u> Technician Name	<u>UT Level II</u> Level/Certification	 Signature
		<u>10-9-23</u> Date

*Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.*

# ULTRASONIC EXAMINATION THICKNESS REPORT



ASME

S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616


Project #: 23050318	Report Date: 10-9-23
Project Name: Clearwater Natatorium UTT of structure framing	Procedure No. TR-NDT-UT-2
Project Location: Clearwater, FL	Material Type: <b>CS</b>
Client Name: McKim & Creed	Surface Condition: bare

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)		
Manufacturer: Olympus		Manufacturer: Panmetric		Material: CS	Step #	Thickness
Model No.: DL38		Model No.: D7908		Serial No: 988285	1	0.100"
Serial No: 110194505		Serial No.: 1159629			<b>5</b>	0.500"
Cable Type: N/A		Frequency: 7.5				
Cable Length: 48"		Size: 0.25"				

Location: **B.7-1-T2-3S** Center: **N/A**

	4"	8"	12"	16"	20"	24"	28"	32"
A	/	/	/	/	/	/	/	/
B	<b>0.440"</b>	<b>0.454"</b>	<b>0.456"</b>	<b>0.455"</b>	/	/	/	/
C	/	/	/	/	/	/	/	/
D	/	/	/	/	/	/	/	/
E	/	/	/	/	/	/	/	/
F	/	/	/	/	/	/	/	/
G	/	/	/	/	/	/	/	/
H	/	/	/	/	/	/	/	/
I	/	/	/	/	/	/	/	/
J	/	/	/	/	/	/	/	/
K	/	/	/	/	/	/	/	/
L	/	/	/	/	/	/	/	/
M	/	/	/	/	/	/	/	/
N	/	/	/	/	/	/	/	/
O	/	/	/	/	/	/	/	/
Aa	/	/	/	/	/	/	/	/
Bb	/	/	/	/	/	/	/	/
Cc	/	/	/	/	/	/	/	/
Dd	/	/	/	/	/	/	/	/

"35" West side view



Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the surface area.

Larry Jernigan  
Technician Name

UT Level II  
Level/Certification

Signature

10-9-23  
Date

*Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.*

# ULTRASONIC EXAMINATION THICKNESS REPORT



ASME


S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616

Project #: 23050318	Report Date: 10-12-23
Project Name: Clearwater Natatorium UTT of structure framing	Procedure No. TR-NDT-UT-2
Project Location: Clearwater, FL	Material Type: <b>CS</b>
Client Name: McKim & Creed	Surface Condition: Painted

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)		
Manufacturer: Olympus	Model No.: DL38	Manufacturer: Panmetric	Model No.: D790-SM	Material: CS	Step #	Thickness
Serial No.: 110194505	Cable Type: N/A	Serial No.: 754080	Frequency: 5 MHz	Serial No: 988285	1	0.100"
Cable Length: 48"		Size: 7.9mm			5	0.500"

Location: **B.7-10.3-T2-1S** Center: **N/A**

	4"	8"	12"	16"	20"	24"	28"	32"
A	/	/	/	/	/	/	/	/
B	0.456"	0.459"	0.455"	0.457"	/	/	/	/
C	0.460"	0.460"	0.460"	0.460"	/	/	/	/
D	/	/	/	/	/	/	/	/
E	/	/	/	/	/	/	/	/
F	/	/	/	/	/	/	/	/
G	/	/	/	/	/	/	/	/
H	/	/	/	/	/	/	/	/
I	/	/	/	/	/	/	/	/
J	/	/	/	/	/	/	/	/
K	/	/	/	/	/	/	/	/
L	/	/	/	/	/	/	/	/
M	/	/	/	/	/	/	/	/
N	/	/	/	/	/	/	/	/
O	/	/	/	/	/	/	/	/
Aa	/	/	/	/	/	/	/	/
Bb	/	/	/	/	/	/	/	/
Cc	/	/	/	/	/	/	/	/



Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the and/or due to thickness of epoxy coating along the surface areas.

Larry Jernigan  
Technician Name

UT Level II  
Level/Certification

Signature

10-12-23  
Date

Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.

# ULTRASONIC EXAMINATION THICKNESS REPORT



ASME

S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616


Project #: 23050318	Report Date: 10-12-23
Project Name: Clearwater Natatorium UTT of structure framing	Procedure No. TR-NDT-UT-2
Project Location: Clearwater, FL	Material Type: <b>CS</b>
Client Name: McKim & Creed	Surface Condition: Painted

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)		
Manufacturer: Olympus	Model No.: DL38	Manufacturer: Panmetric	Model No.: D790-SM	Material: CS	Step #	Thickness
Serial No.: 110194505	Cable Type: N/A	Serial No.: 754080	Frequency: 5 MHz	Serial No: 988285	1	0.100"
Cable Length: 48"		Size: 7.9mm			5	0.500"

Location: **B.7-10.3-T2-3N** Center: **N/A**

	4"	8"	12"	16"	20"	24"	28"	32"
A	/	/	/	/	/	/	/	/
B	0.467"	0.472"	0.470"	0.468"	/	/	/	/
C	/	/	/	/	/	/	/	/
D	/	/	/	/	/	/	/	/
E	/	/	/	/	/	/	/	/
F	/	/	/	/	/	/	/	/
G	/	/	/	/	/	/	/	/
H	/	/	/	/	/	/	/	/
I	/	/	/	/	/	/	/	/
J	/	/	/	/	/	/	/	/
K	/	/	/	/	/	/	/	/
L	/	/	/	/	/	/	/	/
M	/	/	/	/	/	/	/	/
N	/	/	/	/	/	/	/	/
O	/	/	/	/	/	/	/	/
Aa	/	/	/	/	/	/	/	/
Bb	/	/	/	/	/	/	/	/
Cc	/	/	/	/	/	/	/	/

"3N" East view



Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the and/or due to thickness of epoxy coating along the surface areas.

Larry Jernigan  
Technician Name

UT Level II  
Level/Certification

Signature

10-12-23  
Date

*Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.*

# ULTRASONIC EXAMINATION THICKNESS REPORT



ASME


S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616

Project #: 23050318	Report Date: 10-9-23
Project Name: Clearwater Natatorium UTT of structure framing	Procedure No. TR-NDT-UT-2
Project Location: Clearwater, FL	Material Type: <b>CS</b>
Client Name: McKim & Creed	Surface Condition: bare

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)		
Manufacturer: Olympus		Manufacturer: Panmetric		Material: CS	Step #	Thickness
Model No.: DL38		Model No.: D7908		Serial No: 988285	1	0.100"
Serial No: 110194505		Serial No.: 1159629			<b>5</b>	0.500"
Cable Type: N/A		Frequency: 7.5				
Cable Length: 48"		Size: 0.25"				

Location: **B.9-1-T2-1N&S**      Center: **N/A**      "1S"      West side view      "1N"

	4"	8"	12"	16"	20"	24"	28"	32"
A	/	/	/	/	/	/	/	/
B	<b>0.450"</b>	<b>0.455"</b>	<b>0.452"</b>	<b>0.452"</b>	/	/	/	/
C	/	<b>0.494"</b>	<b>0.476"</b>	<b>0.486"</b>	/	/	/	/
D	<b>0.440"</b>	<b>0.458"</b>	<b>0.455"</b>	<b>0.455"</b>	/	/	/	/
E	/	<b>0.433"</b>	<b>0.438"</b>	<b>0.434"</b>	/	/	/	/
F	/	/	/	/	/	/	/	/
G	/	/	/	/	/	/	/	/
H	/	/	/	/	/	/	/	/
I	/	/	/	/	/	/	/	/
J	/	/	/	/	/	/	/	/
K	/	/	/	/	/	/	/	/
L	/	/	/	/	/	/	/	/
M	/	/	/	/	/	/	/	/
N	/	/	/	/	/	/	/	/
O	/	/	/	/	/	/	/	/
Aa	/	/	/	/	/	/	/	/
Bb	/	/	/	/	/	/	/	/
Cc	/	/	/	/	/	/	/	/
Dd	/	/	/	/	/	/	/	/



Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the surface area.

<u>Larry Jernigan</u> Technician Name	<u>UT Level II</u> Level/Certification	 Signature	<u>10-9-23</u> Date
--	---	---------------	------------------------

*Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.*

# ULTRASONIC EXAMINATION THICKNESS REPORT



ASME


S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616

Project #: 23050318	Report Date: 10-9-23
Project Name: Clearwater Natatorium UTT of structure framing	Procedure No. TR-NDT-UT-2
Project Location: Clearwater, FL	Material Type: <b>CS</b>
Client Name: McKim & Creed	Surface Condition: bare

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)		
Manufacturer: Olympus		Manufacturer: Panmetric		Material: CS	Step #	Thickness
Model No.: DL38		Model No.: D7908		Serial No: 988285	1	0.100"
Serial No: 110194505		Serial No.: 1159629			<b>5</b>	0.500"
Cable Type: N/A		Frequency: 7.5				
Cable Length: 48"		Size: 0.25"				

Location: **B.9-1-T2-2N&S** Center: **N/A**

	4"	8"	12"	16"	20"	24"	28"	32"
A	/	/	/	/	/	/	/	/
B	0.440"	0.442"	0.445"	0.441"	/	/	/	/
C	/	/	/	/	/	/	/	/
D	/	/	/	/	/	/	/	/
E	0.451"	0.463"	0.463"	0.469"	/	/	/	/
F	/	/	/	/	/	/	/	/
G	/	/	/	/	/	/	/	/
H	/	/	/	/	/	/	/	/
I	/	/	/	/	/	/	/	/
J	/	/	/	/	/	/	/	/
K	/	/	/	/	/	/	/	/
L	/	/	/	/	/	/	/	/
M	/	/	/	/	/	/	/	/
N	/	/	/	/	/	/	/	/
O	/	/	/	/	/	/	/	/
Aa	/	/	/	/	/	/	/	/
Bb	/	/	/	/	/	/	/	/
Cc	/	/	/	/	/	/	/	/
Dd	/	/	/	/	/	/	/	/



Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the surface area.

<u>Larry Jernigan</u> Technician Name	<u>UT Level II</u> Level/Certification	 Signature	<u>10-9-23</u> Date
--	---	---------------	------------------------

*Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.*

# ULTRASONIC EXAMINATION THICKNESS REPORT



ASME


S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616

Project #: 23050318	Report Date: 10-9-23
Project Name: Clearwater Natatorium UTT of structure framing	Procedure No. TR-NDT-UT-2
Project Location: Clearwater, FL	Material Type: <b>CS</b>
Client Name: McKim & Creed	Surface Condition: bare

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)		
Manufacturer: Olympus		Manufacturer: Panmetric		Material: CS	Step #	Thickness
Model No.: DL38		Model No.: D7908		Serial No: 988285	1	0.100"
Serial No: 110194505		Serial No.: 1159629			<b>5</b>	0.500"
Cable Type: N/A		Frequency: 7.5				
Cable Length: 48"		Size: 0.25"				

Location: **B.9-1-T2-3N&S**      Center: **N/A**      "3S"      West side view      "3N"

	4"	8"	12"	16"	20"	24"	28"	32"
A	/	/	/	/	/	/	/	/
B	<b>0.440"</b>	<b>0.453"</b>	<b>0.452"</b>	<b>0.453"</b>	/	/	/	/
C	/	/	/	/	/	/	/	/
D	/	/	/	/	/	/	/	/
E	<b>0.445"</b>	<b>0.453"</b>	<b>0.453"</b>	<b>0.452"</b>	/	/	/	/
F	/	/	/	/	/	/	/	/
G	/	/	/	/	/	/	/	/
H	/	/	/	/	/	/	/	/
I	/	/	/	/	/	/	/	/
J	/	/	/	/	/	/	/	/
K	/	/	/	/	/	/	/	/
L	/	/	/	/	/	/	/	/
M	/	/	/	/	/	/	/	/
N	/	/	/	/	/	/	/	/
O	/	/	/	/	/	/	/	/
Aa	/	/	/	/	/	/	/	/
Bb	/	/	/	/	/	/	/	/
Cc	/	/	/	/	/	/	/	/
Dd	/	/	/	/	/	/	/	/



Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the surface area.

<u>Larry Jernigan</u> Technician Name	<u>UT Level II</u> Level/Certification	 Signature	<u>10-9-23</u> Date
--	---	---------------	------------------------

*Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.*

# ULTRASONIC EXAMINATION THICKNESS REPORT



ASME

S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616

Project #: 23050318	Report Date: 10-13-23
Project Name: Clearwater Natatorium UTT of structure framing	Procedure No. TR-NDT-UT-2
Project Location: Clearwater, FL	Material Type: <b>CS</b>
Client Name: McKim & Creed	Surface Condition: Painted

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)		
Manufacturer: Olympus	Model No.: DL38	Manufacturer: Panmetric	Model No.: D790-SM	Material: CS	Step #	Thickness
Serial No.: 110194505	Cable Type: N/A	Serial No.: 754080	Frequency: 5 MHz	Serial No: 988285	1	0.100"
Cable Length: 48"		Size: 7.9mm			5	0.500"

Location: <b>B.9-10.3-T2-1N&amp;1S</b>		Center: <b>N/A</b>		"1N"		"1S"		
	4"	8"	12"	16"	20"	24"	28"	32"
A								
B	0.463"	0.462"	0.464"	0.465"				
C	0.443"	0.452"	0.453"	0.452"				
D	0.464"	0.469"	0.463"	0.460"				
E	0.328"	0.454"	0.459"	0.455"				
F								
G								
H								
I								
J								
K								
L								
M								
N								
O								
Aa								
Bb								
Cc								

*Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the and/or due to thickness of epoxy coating along the surface areas.*

<u>Larry Jernigan</u> Technician Name	<u>UT Level II</u> Level/Certification	 Signature
		<u>10-13-23</u> Date

*Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.*

# ULTRASONIC EXAMINATION THICKNESS REPORT



ASME

S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616

Project #: 23050318	Report Date: 10-13-23
Project Name: Clearwater Natatorium UTT of structure framing	Procedure No. TR-NDT-UT-2
Project Location: Clearwater, FL	Material Type: <b>CS</b>
Client Name: McKim & Creed	Surface Condition: Painted

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)		
Manufacturer: Olympus	Model No.: DL38	Manufacturer: Panmetric	Model No.: D790-SM	Material: CS	Step #	Thickness
Serial No.: 110194505	Cable Type: N/A	Serial No.: 754080	Frequency: 5 MHz	Serial No: 988285	1	0.100"
Cable Length: 48"	Cable Length: 48"	Size: 7.9mm			5	0.500"

Location:	B.9-10.3-T2-2N&2S				Center:	N/A				"2N"	East view	"2S"
	4"	8"	12"	16"	20"	24"	28"	32"				
A												
B	0.447"	0.456"	0.449"	0.441"								
C		0.469"	0.470"	0.468"								
D												
E	0.439"	0.440"	0.442"	0.442"								
F	0.464"	0.435"	0.455"	0.464"								
G												
H												
I												
J												
K												
L												
M												
N												
O												
Aa												
Bb												
Cc												

Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the and/or due to thickness of epoxy coating along the surface areas.

<u>Larry Jernigan</u> Technician Name	<u>UT Level II</u> Level/Certification	 Signature
		<u>10-13-23</u> Date

*Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.*

# ULTRASONIC EXAMINATION THICKNESS REPORT



ASME

S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616


Project #: 23050318	Report Date: 10-13-23
Project Name: Clearwater Natatorium UTT of structure framing	Procedure No. TR-NDT-UT-2
Project Location: Clearwater, FL	Material Type: <b>CS</b>
Client Name: McKim & Creed	Surface Condition: Painted

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)		
Manufacturer: Olympus	Model No.: DL38	Manufacturer: Panmetric	Model No.: D790-SM	Material: CS	Step #: 1	Thickness: 0.100"
Serial No.: 110194505	Cable Type: N/A	Serial No.: 754080	Frequency: 5 MHz	Serial No: 988285	5	0.500"
Cable Length: 48"		Size: 7.9mm				


Location: **B.9-10.3-T2-4S** Center: **N/A**

	4"	8"	12"	16"	20"	24"	28"	32"
A	0.232"	0.233"	0.230"	0.229"				
B	0.229"	0.230"	0.230"	0.231"				
C								
D								
E	0.317"	0.316"	0.316"	0.316"				
F								
G								
H								
I								
J								
K								
L								
Aa		0.234"		0.229"				
Bb	0.234"	0.233"	0.232"	0.233"				
Cc		0.233"	0.234"	0.234"				
Dd	0.235"	0.235"	0.234"	0.236"				
Ee	0.235"	0.236"	0.235"	0.236"				
Ff		0.237"		0.235"				

East view "4S"



South view



Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the and/or due to thickness of epoxy coating along the surface areas.

Larry Jernigan  
Technician Name

UT Level II  
Level/Certification

*Larry Jernigan*  
Signature

10-13-23  
Date

Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.

# ULTRASONIC EXAMINATION THICKNESS REPORT



ASME


S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616

Project #: 23050318	Report Date: 10-10-23
Project Name: Clearwater Natatorium UTT of structure framing	Procedure No. TR-NDT-UT-2
Project Location: Clearwater, FL	Material Type: <b>CS</b>
Client Name: McKim & Creed	Surface Condition: bare

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)		
Manufacturer: Olympus	Model No.: DL38	Manufacturer: Panmetric	Model No.: D7908	Material: CS	Step #: 1	Thickness: 0.100"
Serial No.: 110194505	Cable Type: N/A	Serial No.: 1159629	Frequency: 7.5	Serial No: 988285	5	0.500"
Cable Length: 48"		Size: 0.25"				

Location: **B-1.3-T1-1** Center: **0.373"**

	4"	8"	12"	16"	20"	24"	28"	32"
A			0.366"	0.361"				
B	0.353"	0.352"	0.358"	0.360"				
C	0.357"	0.357"	0.358"	0.361"				
D								
E	0.070"	0.353"	0.345"	0.344"				
F	0.076"							
G			0.362"	0.357"				
H	0.352"	0.351"	0.351"					
I				0.356"				
J								
K	0.233"	0.234"	0.234"	0.234"				
L		0.239"	0.234"	0.234"				
M								
N	0.228"	0.231"	0.231"	0.231"				
O			0.241"	0.241"				
P								
Q	0.212"	0.239"	0.237"	0.235"				
R		0.237"	0.237"	0.237"				



Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the surface area.

\*Material was observed to be thin along the E and F face corners at connection joint

Larry Jernigan  
Technician Name

UT Level II  
Level/Certification

*Larry Jernigan*  
Signature

10-10-23  
Date

Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.

# ULTRASONIC EXAMINATION THICKNESS REPORT



ASME

S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616


Project #: 23050318	Report Date: 10-10-23
Project Name: Clearwater Natatorium UTT of structure framing	Procedure No. TR-NDT-UT-2
Project Location: Clearwater, FL	Material Type: <b>CS</b>
Client Name: McKim & Creed	Surface Condition: bare

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)		
Manufacturer: Olympus		Manufacturer: Panmetric		Material: CS	Step #	Thickness
Model No.: DL38		Model No.: D7908		Serial No: 988285	1	0.100"
Serial No: 110194505		Serial No.: 1159629			<b>5</b>	0.500"
Cable Type: N/A		Frequency: 7.5				
Cable Length: 48"		Size: 0.25"				

Location: **B-1.3-T1-2** Center: **N/A**

	4"	8"	12"	16"	20"	24"	28"	32"
A	/	/	/	/	/	/	/	/
B	<b>0.123"</b>	<b>0.343"</b>	<b>0.344"</b>	<b>0.344"</b>	<b>0.346"</b>	/	/	/
C	/	/	/	/	/	/	/	/
D	/	/	/	/	/	/	/	/
E	/	/	/	/	/	/	/	/
F	/	/	/	/	/	/	/	/
G	/	/	/	/	/	/	/	/
H	/	/	/	/	/	/	/	/
I	/	/	/	/	/	/	/	/
J	/	/	/	/	/	/	/	/
K	/	/	/	/	/	/	/	/
L	/	/	/	/	/	/	/	/
M	/	/	/	/	/	/	/	/
N	/	/	/	/	/	/	/	/
O	/	/	/	/	/	/	/	/
P	/	/	/	/	/	/	/	/
Q	/	/	/	/	/	/	/	/
R	/	/	/	/	/	/	/	/

South side view



Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the surface area.

Larry Jernigan  
Technician Name

UT Level II  
Level/Certification

*Larry Jernigan*  
Signature

10-10-23  
Date

*Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.*

# ULTRASONIC EXAMINATION THICKNESS REPORT



ASME


S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616

Project #: 23050318	Report Date: 10-10-23
Project Name: Clearwater Natatorium UTT of structure framing	Procedure No. TR-NDT-UT-2
Project Location: Clearwater, FL	Material Type: <b>CS</b>
Client Name: McKim & Creed	Surface Condition: bare

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)		
Manufacturer: Olympus		Manufacturer: Panmetric		Material: CS	Step #	Thickness
Model No.: DL38		Model No.: D7908		Serial No: 988285	1	0.100"
Serial No: 110194505		Serial No.: 1159629			5	0.500"
Cable Type: N/A		Frequency: 7.5				
Cable Length: 48"		Size: 0.25"				

Location: **B-1.3-T1-3**      Center: **0.353"**

	4"	8"	12"	16"	20"	24"	28"	32"
A	/	/	/	/	/	/	/	/
B	/	/	/	/	/	/	/	/
C	/	/	/	/	/	/	/	/
D	/	/	/	/	/	/	/	/
E	0.200"	0.341"	0.344"	0.338"	/	/	/	/
F	/	/	/	/	/	/	/	/
G	/	/	/	/	/	/	/	/
H	0.352"	0.351"	0.352"	0.352"	/	/	/	/
I	/	/	0.363"	0.363"	/	/	/	/
J	/	/	/	/	/	/	/	/
K	0.225"	0.233"	0.239"	0.231"	/	/	/	/
L	/	/	0.234"	0.238"	/	/	/	/
M	/	/	/	/	/	/	/	/
N	0.237"	0.236"	0.236"	/	/	/	/	/
O	/	/	/	/	/	/	/	/
P	/	0.235"	0.236"	/	/	/	/	/
Q	0.232"	0.232"	0.225"	0.222"	/	/	/	/
R	/	/	/	/	/	/	/	/



Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the surface area.

<u>Larry Jernigan</u> Technician Name	<u>UT Level II</u> Level/Certification	 Signature	<u>10-10-23</u> Date
--	---	---------------	-------------------------

*Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.*

# ULTRASONIC EXAMINATION THICKNESS REPORT




ASME

S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616

Project #: 23050318	Report Date: 10-9-23
Project Name: Clearwater Natatorium UTT of structure framing	Procedure No. TR-NDT-UT-2
Project Location: Clearwater, FL	Material Type: <b>CS</b>
Client Name: McKim & Creed	Surface Condition: bare

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)		
Manufacturer: Olympus		Manufacturer: Panmetric		Material: CS	Step #	Thickness
Model No.: DL38		Model No.: D7908		Serial No: 988285	1	0.100"
Serial No: 110194505		Serial No.: 1159629			5	0.500"
Cable Type: N/A		Frequency: 7.5				
Cable Length: 48"		Size: 0.25"				

Location:	<b>B-1-T2-1</b>				Center:	<b>N/A</b>			
	4"	8"	12"	16"	20"	24"	28"	32"	
A									
B									
C		0.359"	0.365"	0.359"					
D		0.238"	0.244"	0.239"					
E	0.202"	0.248"	0.242"	0.238"					
F									
G		0.237"	0.240"	0.239"					
H	0.137"	0.236"	0.239"	0.232"					
I									
J		0.239"	0.250"	0.238"					
K	0.202"	0.212"	0.205"	0.228"					
L									
M	0.360"	0.365"	0.367"	0.362"					
N									
O									
Aa									
Bb	0.273"	0.463"	0.468"	0.460"					
Cc									
Dd									



Aa \_\_\_\_\_  
Bb **16" 12" 8" 4"**  
Cc \_\_\_\_\_

Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the surface area.

<u>Larry Jernigan</u> Technician Name	<u>UT Level II</u> Level/Certification	 Signature	<u>10-9-23</u> Date
--	---	---------------	------------------------

*Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.*

# ULTRASONIC EXAMINATION THICKNESS REPORT




ASME

S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616

Project #: 23050318	Report Date: 10-9-23
Project Name: Clearwater Natatorium UTT of structure framing	Procedure No. TR-NDT-UT-2
Project Location: Clearwater, FL	Material Type: <b>CS</b>
Client Name: McKim & Creed	Surface Condition: bare

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)		
Manufacturer: Olympus	Model No.: DL38	Manufacturer: Panmetric	Model No.: D7908	Material: CS	Step #: 1	Thickness: 0.100"
Serial No.: 110194505	Cable Type: N/A	Serial No.: 1159629	Frequency: 7.5	Serial No.: 988285	5	0.500"
Cable Length: 48"		Size: 0.25"				

Location: <b>B-1-T2-2</b>	Center: <b>N/A</b>							
	4"	8"	12"	16"	20"	24"	28"	32"
A	/	/	/	/	/	/	/	/
B	0.360"	0.369"	0.362"	0.365"	/	/	/	/
C	/	/	/	/	/	/	/	/
D	/	/	/	/	/	/	/	/
E	0.103"	0.235"	0.237"	0.235"	/	/	/	/
F	/	/	/	/	/	/	/	/
G	/	/	/	/	/	/	/	/
H	0.115"	0.238"	0.239"	0.241"	/	/	/	/
I	/	/	/	/	/	/	/	/
J	/	/	/	/	/	/	/	/
K	0.211"	0.347"	0.348"	0.336"	/	/	/	/
L	/	0.355"	0.358"	0.343"	/	/	/	/
M	/	/	/	/	/	/	/	/
N	0.362"	0.368"	0.362"	0.362"	/	/	/	/
O	/	/	/	/	/	/	/	/
Aa	/	/	/	/	/	/	/	/
Bb	0.366"	0.457"	0.457"	0.461"	0.454"	0.467"	/	/
Cc	/	/	/	/	/	/	/	/
Dd	/	/	/	/	/	/	/	/



Aa \_\_\_\_\_  
Bb **16" 12" 8" 4"**  
Cc \_\_\_\_\_

Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the surface area.

Larry Jernigan  
Technician Name

UT Level II  
Level/Certification

*Larry Jernigan*  
Signature

10-9-23  
Date

Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.

# ULTRASONIC EXAMINATION THICKNESS REPORT




ASME

S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616

Project #: 23050318	Report Date: 10-9-23
Project Name: Clearwater Natatorium UTT of structure framing	Procedure No. TR-NDT-UT-2
Project Location: Clearwater, FL	Material Type: <b>CS</b>
Client Name: McKim & Creed	Surface Condition: bare

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)		
Manufacturer: Olympus	Model No.: DL38	Manufacturer: Panmetric	Model No.: D7908	Material: CS	Step #: 1	Thickness: 0.100"
Serial No.: 110194505	Cable Type: N/A	Serial No.: 1159629	Frequency: 7.5	Serial No.: 988285	5	0.500"
Cable Length: 48"		Size: 0.25"				

Location:	<b>B-1-T2-3</b>				Center:	<b>N/A</b>			
	4"	8"	12"	16"	20"	24"	28"	32"	
A	/	/	/	/	/	/	/	/	
B	/	0.125"	/	/	/	/	/	/	
C	/	/	0.365"	0.370"	0.362"	/	/	/	
D	/	0.248"	0.252"	0.239"	/	/	/	/	
E	0.156"	0.254"	0.252"	0.232"	0.231"	/	/	/	
F	/	0.263"	0.244"	0.231"	0.237"	/	/	/	
G	/	0.228"	0.229"	0.229"	/	/	/	/	
H	0.122"	0.229"	0.186"	0.186"	0.235"	/	/	/	
I	/	/	/	/	/	/	/	/	
J	/	0.231"	0.232"	0.233"	/	/	/	/	
K	0.105"	0.223"	0.233"	0.225"	0.224"	/	/	/	
L	/	/	/	/	/	/	/	/	
M	/	/	/	/	/	/	/	/	
N	/	0.366"	0.357"	0.365"	/	/	/	/	
O	/	/	/	/	/	/	/	/	
Aa	/	/	/	/	/	/	/	/	
Bb	0.329"	0.455"	0.469"	0.455"	/	/	/	/	
Cc	/	/	/	/	/	/	/	/	
Dd	/	/	/	/	/	/	/	/	



Aa \_\_\_\_\_  
Bb **16" 12" 8" 4"**  
Cc \_\_\_\_\_

Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the surface area.

Larry Jernigan  
Technician Name

UT Level II  
Level/Certification

*Larry Jernigan*  
Signature

10-9-23  
Date

Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.

# ULTRASONIC EXAMINATION THICKNESS REPORT



ASME

S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616


Project #: 23050318	Report Date: 10-10-23
Project Name: Clearwater Natatorium UTT of structure framing	Procedure No. TR-NDT-UT-2
Project Location: Clearwater, FL	Material Type: <b>CS</b>
Client Name: McKim & Creed	Surface Condition: Painted

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)		
Manufacturer: Olympus		Manufacturer: Panmetric		Material: CS	Step #	Thickness
Model No.: DL38		Model No.: D7908		Serial No: 988285	1	0.100"
Serial No: 110194505		Serial No.: 1159629			5	0.500"
Cable Type: N/A		Frequency: 7.5				
Cable Length: 48"		Size: 0.25"				

Location: **B-2.3-T1-1** Center: **0.331"**

	4"	8"	12"	16"	20"	24"	28"	32"
A	/	/	/	/	/	/	/	/
B	/	0.387"	0.376"	0.374"	/	/	/	/
C	/	0.385"	0.382"	0.390"	/	/	/	/
D	/	/	/	/	/	/	/	/
E	0.389"	0.382"	0.376"	0.369"	/	/	/	/
F	/	/	/	/	/	/	/	/
G	/	/	/	/	/	/	/	/
H	/	0.391"	0.395"	0.392"	/	/	/	/
I	/	0.381"	0.379"	0.379"	/	/	/	/
J	/	0.256"	0.254"	0.258"	/	/	/	/
K	0.268"	0.259"	0.256"	0.260"	/	/	/	/
L	/	/	/	/	/	/	/	/
M	/	/	/	/	/	/	/	/
N	0.271"	0.261"	0.259"	0.259"	/	/	/	/
O	/	/	0.255"	0.255"	/	/	/	/
P	/	0.266"	/	/	/	/	/	/
Q	0.278"	0.267"	0.269"	0.262"	/	/	/	/
R	/	0.269"	/	0.268"	/	/	/	/

South side view



Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the and/or due to thickness of epoxy coating along the surface areas.

Larry Jernigan  
Technician Name

UT Level II  
Level/Certification

Signature

10-10-23  
Date

Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.

# ULTRASONIC EXAMINATION THICKNESS REPORT



ASME


S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616

Project #: 23050318	Report Date: 10-10-23
Project Name: Clearwater Natatorium UTT of structure framing	Procedure No. TR-NDT-UT-2
Project Location: Clearwater, FL	Material Type: <b>CS</b>
Client Name: McKim & Creed	Surface Condition: Painted

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)		
Manufacturer: Olympus	Model No.: DL38	Manufacturer: Panmetric	Model No.: D7908	Material: CS	Step #	Thickness
Serial No.: 110194505	Cable Type: N/A	Serial No.: 1159629	Frequency: 7.5	Serial No: 988285	1	0.100"
Cable Length: 48"		Size: 0.25"			5	0.500"

Location: **B-2.3-T1-2** Center: **0.399"**

	4"	8"	12"	16"	20"	24"	28"	32"
A	/	/	/	/	/	/	/	/
B	0.393"	0.379"	0.375"	0.372"	/	/	/	/
C	/	/	0.377"	0.378"	/	/	/	/
D	/	/	/	/	/	/	/	/
E	0.163"	0.380"	0.380"	0.379"	/	/	/	/
F	/	/	/	/	/	/	/	/
G	/	/	/	/	/	/	/	/
H	0.370"	0.389"	0.374"	0.375"	/	/	/	/
I	/	/	0.378"	0.383"	/	/	/	/
J	/	0.258"	0.258"	0.263"	/	/	/	/
K	0.253"	0.261"	0.264"	0.268"	/	/	/	/
L	/	0.270"	0.267"	0.270"	/	/	/	/
M	/	/	0.280"	0.274"	/	/	/	/
N	0.266"	0.265"	0.269"	0.257"	/	/	/	/
O	/	/	/	/	/	/	/	/
P	/	/	/	/	/	/	/	/
Q	0.274"	0.261"	0.267"	0.273"	/	/	/	/
R	0.273"	0.264"	0.258"	/	/	/	/	/



Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the and/or due to thickness of epoxy coating along the surface areas.

<u>Larry Jernigan</u> Technician Name	<u>UT Level II</u> Level/Certification	 Signature
		<u>10-10-23</u> Date

*Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.*

# ULTRASONIC EXAMINATION THICKNESS REPORT



ASME


S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616

Project #: 23050318	Report Date: 10-10-23
Project Name: Clearwater Natatorium UTT of structure framing	Procedure No. TR-NDT-UT-2
Project Location: Clearwater, FL	Material Type: <b>CS</b>
Client Name: McKim & Creed	Surface Condition: Painted

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)		
Manufacturer: Olympus	Model No.: DL38	Manufacturer: Panmetric	Model No.: D7908	Material: CS	Step #: 1	Thickness: 0.100"
Serial No.: 110194505	Cable Type: N/A	Serial No.: 1159629	Frequency: 7.5	Serial No: 988285	5	0.500"
Cable Length: 48"		Size: 0.25"				

Location: **B-2.3-T1-3** Center: **0.350"**

	4"	8"	12"	16"	20"	24"	28"	32"
A	/	/	/	/	/	/	/	/
B	0.348"	0.348"	0.348"	0.349"	/	/	/	/
C	0.361"	0.362"	0.347"	0.347"	/	/	/	/
D	/	0.350"	0.350"	0.350"	/	/	/	/
E	/	0.331	0.330"	0.331"	/	/	/	/
F	/	/	/	/	/	/	/	/
G	0.349"	0.346"	0.366"	0.365"	/	/	/	/
H	0.348"	0.349"	0.348"	0.350"	/	/	/	/
I	/	/	/	/	/	/	/	/
J	/	/	/	/	/	/	/	/
K	0.213"	0.211"	0.211"	0.220"	0.236"	/	/	/
L	/	/	0.236"	0.223"	/	/	/	/
M	/	/	0.235"	0.235"	/	/	/	/
N	0.232"	0.232"	0.233"	0.223"	/	/	/	/
O	/	0.231"	0.237"	0.235"	/	/	/	/
P	/	/	/	/	/	/	/	/
Q	0.203"	0.249"	0.249"	0.249"	/	/	/	/
R	/	0.243"	0.242"	0.240"	/	/	/	/



Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the and/or due to thickness of epoxy coating along the surface areas.

<u>Larry Jernigan</u> Technician Name	<u>UT Level II</u> Level/Certification	 Signature
		<u>10-10-23</u> Date

Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.

# ULTRASONIC EXAMINATION THICKNESS REPORT



ASME

S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616


Project #: 23050318	Report Date: 10-10-23
Project Name: Clearwater Natatorium UTT of structure framing	Procedure No. TR-NDT-UT-2
Project Location: Clearwater, FL	Material Type: <b>CS</b>
Client Name: McKim & Creed	Surface Condition: Painted

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)		
Manufacturer: Olympus		Manufacturer: Panmetric		Material: CS	Step #	Thickness
Model No.: DL38		Model No.: D7908		Serial No: 988285	1	0.100"
Serial No: 110194505		Serial No.: 1159629			5	0.500"
Cable Type: N/A		Frequency: 7.5				
Cable Length: 48"		Size: 0.25"				

Location: **B-2-T1-1** Center: **0.353"**

	4"	8"	12"	16"	20"	24"	28"	32"
A	0.356"	0.356"	0.359"	0.359"				
B	0.367"	0.368"	0.367"	0.367"				
C								
D	0.219"	0.231"	0.233"	0.233"				
E		0.230"	0.230"	0.233"				
F								
G								
H	0.218"	0.231"	0.247"	0.247"				
I								
J		0.237"	0.235"	0.235"				
K	0.237"	0.237"	0.247"	0.247"				
L								
M		0.349"	0.349"	0.349"				
N	0.349"	0.349"	0.364"	0.364"				
O								
P								
Q	0.343"	0.344"	0.343"	0.357"				
R		0.357"	0.359"					

North side view



Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the and/or due to thickness of epoxy coating along the surface areas.

Larry Jernigan  
Technician Name

UT Level II  
Level/Certification

Larry Jernigan  
Signature

10-10-23  
Date

Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.

# ULTRASONIC EXAMINATION THICKNESS REPORT



ASME

S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616


Project #: 23050318	Report Date: 10-10-23
Project Name: Clearwater Natatorium UTT of structure framing	Procedure No. TR-NDT-UT-2
Project Location: Clearwater, FL	Material Type: <b>CS</b>
Client Name: McKim & Creed	Surface Condition: Painted

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)		
Manufacturer: Olympus	Model No.: DL38	Manufacturer: Panmetric	Model No.: D7908	Material: CS	Step #	Thickness
Serial No.: 110194505	Cable Type: N/A	Serial No.: 1159629	Frequency: 7.5	Serial No: 988285	1	0.100"
Cable Length: 48"		Size: 0.25"			5	0.500"

Location: **B-2-T1-2** Center: **0.349"**

	4"	8"	12"	16"	20"	24"	28"	32"
A	/	/	/	/	/	/	/	/
B	0.347"	/	0.325"	0.349"	/	/	/	/
C	/	0.348"	0.347"	0.341"	/	/	/	/
D	/	0.240"	0.243"	0.209"	0.246"	/	/	/
E	0.225"	0.233"	0.249"	0.234"	/	/	/	/
F	/	/	/	/	/	/	/	/
G	/	/	/	/	/	/	/	/
H	0.227"	0.233"	0.231"	0.233"	/	/	/	/
I	/	/	/	/	/	/	/	/
J	/	0.236"	0.238"	0.240"	/	/	/	/
K	0.227"	0.234"	0.236"	0.237"	/	/	/	/
L	/	/	/	/	/	/	/	/
M	/	/	/	/	/	/	/	/
N	0.348"	0.348"	0.348"	0.349"	/	/	/	/
O	0.355"	0.355"	/	0.346"	/	/	/	/
P	/	/	/	/	/	/	/	/
Q	0.342"	0.342"	0.342"	0.342"	/	/	/	/
R	0.346"	0.347"	0.348"	0.346"	/	/	/	/

North view



Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the and/or due to thickness of epoxy coating along the surface areas.

Larry Jernigan  
Technician Name

UT Level II  
Level/Certification

Larry Jernigan  
Signature

10-10-23  
Date

Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.

# ULTRASONIC EXAMINATION THICKNESS REPORT



ASME


S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616

Project #: 23050318	Report Date: 10-10-23
Project Name: Clearwater Natatorium UTT of structure framing	Procedure No. TR-NDT-UT-2
Project Location: Clearwater, FL	Material Type: <b>CS</b>
Client Name: McKim & Creed	Surface Condition: Painted

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)		
Manufacturer: Olympus	Model No.: DL38	Manufacturer: Panmetric	Model No.: D7908	Material: CS	Step #: 1	Thickness: 0.100"
Serial No.: 110194505	Cable Type: N/A	Serial No.: 1159629	Frequency: 7.5	Serial No: 988285	5	0.500"
Cable Length: 48"		Size: 0.25"				

Location: **B-2-T1-3** Center: **0.331"**

	4"	8"	12"	16"	20"	24"	28"	32"
A	/	/	/	/	/	/	/	/
B	0.347"	0.349"	0.350"	0.350"	/	/	/	/
C	/	/	/	/	/	/	/	/
D	/	/	/	/	/	/	/	/
E	0.206"	0.235"	0.235"	0.235"	/	/	/	/
F	/	/	/	/	/	/	/	/
G	/	0.235"	0.238"	0.238"	/	/	/	/
H	0.214"	0.207"	0.232"	0.230"	/	/	/	/
I	/	/	/	0.236"	/	/	/	/
J	/	0.235"	0.235"	0.236"	/	/	/	/
K	0.201"	0.232"	0.248"	0.232"	/	/	/	/
L	0.203"	0.236"	0.236"	/	/	/	/	/
M	/	0.348"	0.353"	0.355"	/	/	/	/
N	0.324"	0.327"	0.365"	0.364"	/	/	/	/
O	/	/	/	/	/	/	/	/
P	/	/	/	/	/	/	/	/
Q	0.350"	0.336"	0.340"	0.340"	/	/	/	/
R	/	/	/	/	/	/	/	/



Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the and/or due to thickness of epoxy coating along the surface areas.

Larry Jernigan  
Technician Name

UT Level II  
Level/Certification

Signature

10-10-23  
Date

Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.

# ULTRASONIC EXAMINATION THICKNESS REPORT




ASME

S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616

Project #: 23050318	Report Date: 10-10-23
Project Name: Clearwater Natatorium UTT of structure framing	Procedure No. TR-NDT-UT-2
Project Location: Clearwater, FL	Material Type: <b>CS</b>
Client Name: McKim & Creed	Surface Condition: Painted

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)		
Manufacturer: Olympus	Model No.: DL38	Manufacturer: Panmetric	Model No.: D7908	Material: CS	Step #	Thickness
Serial No.: 110194505	Cable Type: N/A	Serial No.: 1159629	Frequency: 7.5	Serial No: 988285	1	0.100"
Cable Length: 48"		Size: 0.25"			5	0.500"

Location:	<b>B-3-T1-2</b>				Center:	<b>352"</b>			
	4"	8"	12"	16"	20"	24"	28"	32"	
A	0.356"	0.337"	0.370"	0.354"	/	/	/	/	
B	0.353"	0.367"	0.352"	0.352"	/	/	/	/	
C	/	/	/	/	/	/	/	/	
D	/	0.238"	0.238"	0.235"	/	/	/	/	
E	0.225"	0.233"	0.233"	0.233"	/	/	/	/	
F	/	/	/	/	/	/	/	/	
G	/	0.231"	0.232"	0.233"	/	/	/	/	
H	0.237"	0.232"	0.232"	0.230"	/	/	/	/	
I	/	/	/	/	/	/	/	/	
J	/	0.231"	0.232"	0.232"	/	/	/	/	
K	0.237"	0.233"	0.233"	0.233"	/	/	/	/	
L	/	/	/	/	/	/	/	/	
M	/	0.355"	0.355"	0.354"	/	/	/	/	
N	0.352"	0.366"	0.350"	0.351"	/	/	/	/	
O	/	0.353"	0.356"	0.348"	/	/	/	/	
P	/	/	/	/	/	/	/	/	
Q	0.342"	0.351"	0.342"	0.343"	/	/	/	/	
R	/	0.349"	0.351"	0.351"	/	/	/	/	



*Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the and/or due to thickness of epoxy coating along the surface areas.*

<u>Larry Jernigan</u> Technician Name	<u>UT Level II</u> Level/Certification	 Signature
		<u>10-10-23</u> Date

*Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.*

# ULTRASONIC EXAMINATION THICKNESS REPORT



ASME


S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616

Project #: 23050318	Report Date: 10-10-23
Project Name: Clearwater Natatorium UTT of structure framing	Procedure No. TR-NDT-UT-2
Project Location: Clearwater, FL	Material Type: <b>CS</b>
Client Name: McKim & Creed	Surface Condition: Painted

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)		
Manufacturer: Olympus	Model No.: DL38	Manufacturer: Panmetric	Model No.: D7908	Material: CS	Step #: 1	Thickness: 0.100"
Serial No.: 110194505	Cable Type: N/A	Serial No.: 1159629	Frequency: 7.5	Serial No: 988285	5	0.500"
Cable Length: 48"		Size: 0.25"				

Location: **B-3-T1-3** Center: **0.352"**

	4"	8"	12"	16"	20"	24"	28"	32"
A	0.355"	0.355"	0.358"					
B	0.353"	0.368"	0.368"	0.352"				
C		0.368"						
D								
E	0.113"		0.116"	0.117"	0.234"	0.234"	0.234"	0.234"
F								
G		0.236"	0.236"	0.236"				
H	0.232"	0.233"	0.232"	0.232"				
I								
J		0.215"	0.195"	0.199"	0.207"	0.238"	0.238"	
K	0.230"	0.210"	0.225"	0.230"	0.231"			
L								
M		0.351"	0.356"	0.355"				
N	0.352"	0.352"	0.352"	0.352"				
O	0.347"	0.355"	0.335"	0.358"				
P								
Q	0.331"	0.311"	0.340"	0.347"				
R		0.347"	0.348"	0.350"				



Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the and/or due to thickness of epoxy coating along the surface areas.

Larry Jernigan  
Technician Name

UT Level II  
Level/Certification

*Larry Jernigan*  
Signature

10-10-23  
Date

Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.

# ULTRASONIC EXAMINATION THICKNESS REPORT



ASME

S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616


Project #: 23050318	Report Date: 10-11-23
Project Name: Clearwater Natatorium UTT of structure framing	Procedure No. TR-NDT-UT-2
Project Location: Clearwater, FL	Material Type: <b>CS</b>
Client Name: McKim & Creed	Surface Condition: Painted

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)		
Manufacturer: Olympus	Model No.: DL38	Manufacturer: Panmetric	Model No.: D7908	Material: CS	Step #: 1	Thickness: 0.100"
Serial No.: 110194505	Cable Type: N/A	Serial No.: 1159629	Frequency: 7.5	Serial No: 988285	5	0.500"
Cable Length: 48"		Size: 0.25"				

Location: **B-4.3-T1-2**      Center: **0.353"**

	4"	8"	12"	16"	20"	24"	28"	32"
A		<b>0.309"</b>	<b>0.348"</b>	<b>0.334"</b>				
B	<b>0.352"</b>	<b>0.352"</b>	<b>0.350"</b>	<b>0.351"</b>				
C	<b>0.355"</b>	<b>0.354"</b>	<b>0.355"</b>	<b>0.346"</b>				
D								
E	<b>0.322"</b>	<b>0.325"</b>	<b>0.355"</b>	<b>0.337"</b>				
F	<b>0.348"</b>	<b>0.348"</b>	<b>0.348"</b>	<b>0.348"</b>				
G	<b>0.339"</b>	<b>0.365"</b>	<b>0.350"</b>	<b>0.366"</b>				
H	<b>0.351"</b>	<b>0.351"</b>	<b>0.351"</b>	<b>0.351"</b>				
I		<b>0.360"</b>	<b>0.360"</b>	<b>0.357"</b>				
J								
K	<b>0.222"</b>	<b>0.248"</b>	<b>0.249"</b>	<b>0.249"</b>				
L			<b>0.235"</b>	<b>0.234"</b>				
M								
N	<b>0.229"</b>	<b>0.245"</b>	<b>0.244"</b>	<b>0.230"</b>				
O		<b>0.233"</b>	<b>0.233"</b>	<b>0.234"</b>				
P								
Q	<b>0.228"</b>	<b>0.231"</b>	<b>0.232"</b>	<b>0.232"</b>				
R		<b>0.235"</b>	<b>0.233"</b>	<b>0.233"</b>				

North view



*Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the and/or due to thickness of epoxy coating along the surface areas.*

Larry Jernigan  
Technician Name

UT Level II  
Level/Certification

Signature

10-10-23  
Date

*Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.*

# ULTRASONIC EXAMINATION THICKNESS REPORT



ASME

S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616


Project #: 23050318	Report Date: 10-11-23
Project Name: Clearwater Natatorium UTT of structure framing	Procedure No. TR-NDT-UT-2
Project Location: Clearwater, FL	Material Type: <b>CS</b>
Client Name: McKim & Creed	Surface Condition: Painted

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)		
Manufacturer: Olympus		Manufacturer: Panmetric		Material: CS	Step #	Thickness
Model No.: DL38		Model No.: D7908		Serial No: 988285	1	0.100"
Serial No: 110194505		Serial No.: 1159629			5	0.500"
Cable Type: N/A		Frequency: 7.5				
Cable Length: 48"		Size: 0.25"				

Location: **B-4.3-T1-3** Center: **0.354"**

South side view

	4"	8"	12"	16"	20"	24"	28"	32"
A	/	0.360"	0.357"	0.358"	/	/	/	/
B	0.351"	0.357"	0.351"	0.350"	/	/	/	/
C	/	0.351"	0.351"	0.352"	/	/	/	/
D	0.345"	0.336"	0.322"	0.349"	/	/	/	/
E	0.338"	0.322"	0.342"	0.357"	/	/	/	/
F	/	/	/	/	/	/	/	/
G	/	0.350"	/	0.352"	0.353"	/	/	/
H	0.351"	0.350"	0.327"	0.351"	/	/	/	/
I	/	0.357"	0.359"	0.359"	/	/	/	/
J	/	/	0.236"	0.236"	/	/	/	/
K	0.198"	0.233"	0.233"	0.232"	/	/	/	/
L	/	0.238"	0.238"	0.236"	/	/	/	/
M	/	/	0.231"	0.231"	/	/	/	/
N	0.230"	0.230"	0.230"	0.230"	/	/	/	/
O	/	0.235"	0.231"	0.234"	/	/	/	/
P	/	/	/	/	/	/	/	/
Q	0.228"	0.235"	0.235"	0.235"	/	/	/	/
R	0.238"	0.238"	0.232"	/	/	/	/	/



Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the and/or due to thickness of epoxy coating along the surface areas.

Larry Jernigan  
Technician Name

UT Level II  
Level/Certification

Larry Jernigan  
Signature

10-11-23  
Date

Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.

# ULTRASONIC EXAMINATION THICKNESS REPORT



ASME


S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616

Project #: 23050318	Report Date: 10-11-23
Project Name: Clearwater Natatorium UTT of structure framing	Procedure No. TR-NDT-UT-2
Project Location: Clearwater, FL	Material Type: <b>CS</b>
Client Name: McKim & Creed	Surface Condition: Painted

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)		
Manufacturer: Olympus	Model No.: DL38	Manufacturer: Panmetric	Model No.: D7908	Material: CS	Step #: 1	Thickness: 0.100"
Serial No.: 110194505	Cable Type: N/A	Serial No.: 1159629	Frequency: 7.5	Serial No: 988285	5	0.500"
Cable Length: 48"		Size: 0.25"				

Location: **B-4-T1-1** Center: **0.352"**

	4"	8"	12"	16"	20"	24"	28"	32"
A	/	/	/	/	/	/	/	/
B	0.351"	0.352	0.352"	0.351"	/	/	/	/
C	/	0.351"	0.351"	0.351"	/	/	/	/
D	/	0.243"	0.242"	0.244"	/	/	/	/
E	0.228"	0.235"	0.249"	0.249"	/	/	/	/
F	/	0.235"	0.235"	0.236"	/	/	/	/
G	/	0.234"	0.235"	0.234"	/	/	/	/
H	0.231"	0.232"	0.232"	0.232"	/	/	/	/
I	/	/	/	/	/	/	/	/
J	/	/	0.240"	0.238"	/	/	/	/
K	0.230"	0.245"	0.245"	0.245"	/	/	/	/
L	/	0.236"	0.234"	0.237"	/	/	/	/
M	/	0.355"	0.355"	0.355"	/	/	/	/
N	0.352"	0.352"	0.352"	0.352"	/	/	/	/
O	/	/	/	/	/	/	/	/
P	/	/	/	/	/	/	/	/
Q	0.113"	0.322"	0.334"	0.345"	/	/	/	/
R	/	/	/	/	/	/	/	/



Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the and/or due to thickness of epoxy coating along the surface areas.

Larry Jernigan  
Technician Name

UT Level II  
Level/Certification

Signature

10-10-23  
Date

Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.

# ULTRASONIC EXAMINATION THICKNESS REPORT



ASME


S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616

Project #: 23050318	Report Date: 10-11-23
Project Name: Clearwater Natatorium UTT of structure framing	Procedure No. TR-NDT-UT-2
Project Location: Clearwater, FL	Material Type: <b>CS</b>
Client Name: McKim & Creed	Surface Condition: Painted

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)		
Manufacturer: Olympus	Model No.: DL38	Manufacturer: Panmetric	Model No.: D7908	Material: CS	Step #: 1	Thickness: 0.100"
Serial No.: 110194505	Cable Type: N/A	Serial No.: 1159629	Frequency: 7.5	Serial No: 988285	5	0.500"
Cable Length: 48"		Size: 0.25"				

Location: **B-4-T1-3** Center: **0.353"**

	4"	8"	12"	16"	20"	24"	28"	32"
A	/	/	/	/	/	/	/	/
B	0.352"	0.352"	0.352"	0.351"	/	/	/	/
C	/	0.351"	0.356"	0.356"	/	/	/	/
D	/	0.241"	0.240"	0.241"	/	/	/	/
E	0.240"	0.233"	0.235"	0.235"	/	/	/	/
F	/	0.241"	0.241"	0.241"	/	/	/	/
G	/	0.237"	0.235"	0.234"	/	/	/	/
H	0.232"	0.231"	0.231"	0.231"	/	/	/	/
I	/	/	0.232"	0.233"	/	/	/	/
J	/	/	0.231"	0.231"	/	/	/	/
K	0.213"	0.213"	0.233"	0.232"	/	/	/	/
L	0.229"	0.235"	0.236"	0.236"	/	/	/	/
M	/	/	0.329"	0.338"	/	/	/	/
N	0.330"	0.330"	0.332"	0.333"	/	/	/	/
O	/	/	/	/	/	/	/	/
P	/	/	/	/	/	/	/	/
Q	0.341"	0.341"	0.342"	0.343"	/	/	/	/
R	/	/	/	/	/	/	/	/



Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the and/or due to thickness of epoxy coating along the surface areas.

<u>Larry Jernigan</u> Technician Name	<u>UT Level II</u> Level/Certification	 Signature
		<u>10-11-23</u> Date

Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.

# ULTRASONIC EXAMINATION THICKNESS REPORT



ASME

S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616


Project #: 23050318	Report Date: 10-11-23
Project Name: Clearwater Natatorium UTT of structure framing	Procedure No. TR-NDT-UT-2
Project Location: Clearwater, FL	Material Type: <b>CS</b>
Client Name: McKim & Creed	Surface Condition: Painted

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)		
Manufacturer: Olympus	Model No.: DL38	Manufacturer: Panmetric	Model No.: D7908	Material: CS	Step #: 1	Thickness: 0.100"
Serial No.: 110194505	Cable Type: N/A	Serial No.: 1159629	Frequency: 7.5	Serial No: 988285	5	0.500"
Cable Length: 48"		Size: 0.25"				

Location: **B-5.3-T1-1** Center: **0.135"**

	4"	8"	12"	16"	20"	24"	28"	32"
A	/	/	0.383"	0.398"	/	/	/	/
B	0.395"	0.390"	0.386"	0.386"	/	/	/	/
C	/	/	/	0.398"	/	/	/	/
D	/	/	/	/	/	/	/	/
E	0.097"	0.377"	0.376"	0.377"	/	/	/	/
F	/	/	/	/	/	/	/	/
G	/	/	/	/	/	/	/	/
H	0.374"	0.389"	0.378"	0.376"	/	/	/	/
I	/	/	/	/	/	/	/	/
J	0.275"	0.264"	0.267"	0.263"	/	/	/	/
K	0.267"	0.259"	0.254"	0.260"	/	/	/	/
L	/	0.277"	0.268"	0.258"	/	/	/	/
M	/	/	/	/	/	/	/	/
N	0.267"	0.268"	0.268"	0.263"	/	/	/	/
O	/	0.268"	0.264"	0.263"	/	/	/	/
P	/	/	/	/	/	/	/	/
Q	0.275"	0.279"	0.272"	0.264"	/	/	/	/
R	/	0.286"	0.278"	0.276"	/	/	/	/

North view



*Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the and/or due to thickness of epoxy coating along the surface areas.*

*\*Center and E Face was observed to have a thin wall along the its joint, additional readings along the other sides could not be taken due to window framing covering the surfaces.*

Larry Jernigan  
Technician Name

UT Level II  
Level/Certification

*Larry Jernigan*  
Signature

10-11-23  
Date

*Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.*

# ULTRASONIC EXAMINATION THICKNESS REPORT



ASME


S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616

Project #: 23050318	Report Date: 10-11-23
Project Name: Clearwater Natatorium UTT of structure framing	Procedure No. TR-NDT-UT-2
Project Location: Clearwater, FL	Material Type: <b>CS</b>
Client Name: McKim & Creed	Surface Condition: Painted

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)		
Manufacturer: Olympus	Model No.: DL38	Manufacturer: Panmetric	Model No.: D7908	Material: CS	Step #: 1	Thickness: 0.100"
Serial No.: 110194505	Cable Type: N/A	Serial No.: 1159629	Frequency: 7.5	Serial No: 988285	5	0.500"
Cable Length: 48"		Size: 0.25"				

Location: **B-5.3-T1-2** Center: **0.348"**

	4"	8"	12"	16"	20"	24"	28"	32"
A	/	/	/	/	/	/	/	/
B	0.351"	0.351"	/	0.348"	/	/	/	/
C	/	0.351"	0.351"	/	/	/	/	/
D	/	0.358"	0.357"	/	/	/	/	/
E	0.320"	0.321"	0.359"	0.359"	/	/	/	/
F	/	/	/	/	/	/	/	/
G	0.359"	0.359"	0.360"	0.359"	/	/	/	/
H	/	0.354"	0.368"	0.353"	/	/	/	/
I	/	0.366"	0.363"	0.362"	/	/	/	/
J	/	0.234"	0.235"	0.235"	/	/	/	/
K	0.239"	0.226"	0.222"	0.242"	/	/	/	/
L	/	/	/	/	/	/	/	/
M	/	/	/	/	/	/	/	/
N	0.235"	0.235"	0.235"	0.236"	/	/	/	/
O	/	/	0.237"	0.239"	/	/	/	/
P	/	/	/	/	/	/	/	/
Q	0.229"	0.249"	0.247"	0.247"	/	/	/	/
R	0.234"	0.235"	0.233"	0.234"	/	/	/	/



Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the and/or due to thickness of epoxy coating along the surface areas.

Larry Jernigan  
Technician Name

UT Level II  
Level/Certification

Signature

10-11-23  
Date

Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.

# ULTRASONIC EXAMINATION THICKNESS REPORT



ASME


S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616

Project #: 23050318	Report Date: 10-11-23
Project Name: Clearwater Natatorium UTT of structure framing	Procedure No. TR-NDT-UT-2
Project Location: Clearwater, FL	Material Type: <b>CS</b>
Client Name: McKim & Creed	Surface Condition: Painted

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)		
Manufacturer: Olympus	Model No.: DL38	Manufacturer: Panmetric	Model No.: D7908	Material: CS	Step #: 1	Thickness: 0.100"
Serial No.: 110194505	Cable Type: N/A	Serial No.: 1159629	Frequency: 7.5	Serial No: 988285	5	0.500"
Cable Length: 48"		Size: 0.25"				

Location: **B-5.3-T1-3** Center: **0.353"**

	4"	8"	12"	16"	20"	24"	28"	32"
A	/	/	/	/	/	/	/	/
B	0.356"	0.353"	0.355"	0.354"	/	/	/	/
C	0.360"	0.337"	0.324"	0.346"	/	/	/	/
D	/	/	/	/	/	/	/	/
E	0.342"	0.344"	0.344"	0.344"	/	/	/	/
F	/	/	/	/	/	/	/	/
G	/	/	/	/	/	/	/	/
H	0.338"	0.335"	0.335"	0.335"	/	/	/	/
I	/	0.339"	0.337"	0.350"	/	/	/	/
J	/	0.231"	0.231"	0.231"	/	/	/	/
K	0.180"	0.207"	0.225"	0.225"	/	/	/	/
L	/	0.236"	0.236"	0.238"	/	/	/	/
M	/	/	/	/	/	/	/	/
N	0.250"	0.235"	/	0.234"	/	/	/	/
O	/	0.239"	0.236"	0.237"	/	/	/	/
P	/	/	/	/	/	/	/	/
Q	0.231"	0.235"	0.235"	0.236"	/	/	/	/
R	/	0.236"	0.237"	0.236"	/	/	/	/



Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the and/or due to thickness of epoxy coating along the surface areas.

<u>Larry Jernigan</u> Technician Name	<u>UT Level II</u> Level/Certification	 Signature
		<u>10-11-23</u> Date

*Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.*

# ULTRASONIC EXAMINATION THICKNESS REPORT



ASME

S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616


Project #:	23050318	Report Date:	10-11-23
Project Name:	Clearwater Natatorium UTT of structure framing	Procedure No.	TR-NDT-UT-2
Project Location:	Clearwater, FL	Material Type:	<b>CS</b>
Client Name:	McKim & Creed	Surface Condition:	Painted

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)			
Manufacturer:	Olympus	Manufacturer:	Panmetric	Material:	CS	Step #	Thickness
Model No.:	DL38	Model No.:	D7908	Serial No:	988285	1	0.100"
Serial No:	110194505	Serial No.:	1159629			5	0.500"
Cable Type:	N/A	Frequency:	7.5				
Cable Length:	48"	Size:	0.25"				

Location: **B-5-T1-1** Center: **0.350"**

	4"	8"	12"	16"	20"	24"	28"	32"
A	/	0.355"	0.355"	0.435"	/	/	/	/
B	0.349"	0.348"	0.347"	0.347"	/	/	/	/
C	/	0.352"	0.354"	0.356"	/	/	/	/
D	/	0.278"	0.288"	0.287"	/	/	/	/
E	0.118"	0.270"	0.279"	0.269"	0.273"	/	/	/
F	/	/	0.267"	0.269"	/	/	/	/
G	/	/	0.274"	0.260"	/	/	/	/
H	0.288"	0.260"	0.262"	0.262"	/	/	/	/
I	/	/	/	/	/	/	/	/
J	/	/	/	/	/	/	/	/
K	0.253"	0.267"	0.257"	0.267"	/	/	/	/
L	/	0.263"	0.264"	/	/	/	/	/
M	/	/	/	/	/	/	/	/
N	0.349"	0.352"	0.351"	0.326"	/	/	/	/
O	/	/	/	/	/	/	/	/
P	/	0.405"	0.399"	0.371"	0.376"	/	/	/
Q	0.420"	0.418"	0.372"	0.365"	0.371"	0.373"	/	/
R	/	0.378"	0.374"	0.378"	/	/	/	/

North view



Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the and/or due to thickness of epoxy coating along the surface areas.

Larry Jernigan  
Technician Name

UT Level II  
Level/Certification

Signature

10-11-23  
Date

Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.

# ULTRASONIC EXAMINATION THICKNESS REPORT



ASME


S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616

Project #: 23050318	Report Date: 10-11-23
Project Name: Clearwater Natatorium UTT of structure framing	Procedure No. TR-NDT-UT-2
Project Location: Clearwater, FL	Material Type: <b>CS</b>
Client Name: McKim & Creed	Surface Condition: Painted

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)		
Manufacturer: Olympus	Model No.: DL38	Manufacturer: Panmetric	Model No.: D7908	Material: CS	Step #: 1	Thickness: 0.100"
Serial No.: 110194505	Cable Type: N/A	Serial No.: 1159629	Frequency: 7.5	Serial No: 988285	5	0.500"
Cable Length: 48"		Size: 0.25"				

Location: **B-5-T1-2** Center: **0.123"**

	4"	8"	12"	16"	20"	24"	28"	32"
A	0.365"	0.385"	0.388"	0.390"	/	/	/	/
B	0.365"	0.387"	0.385"	0.376"	0.378"	/	/	/
C	/	/	/	/	/	/	/	/
D	0.262"	0.266"	0.260"	0.266"	/	/	/	/
E	0.247"	0.253"	0.253"	/	/	/	/	/
F	/	0.257"	0.254"	0.254"	/	/	/	/
G	/	0.263"	0.269"	/	/	/	/	/
H	0.273"	0.268"	0.261"	0.264"	/	/	/	/
I	/	/	/	/	/	/	/	/
J	/	0.269"	0.278"	0.275"	/	/	/	/
K	0.155"	0.274"	0.276"	0.268"	/	/	/	/
L	/	/	/	/	/	/	/	/
M	/	/	0.395"	0.398"	0.392"	0.386"	/	/
N	0.381"	/	/	0.388"	0.364"	0.346"	0.371"	/
O	/	/	/	/	/	/	/	/
P	/	/	/	/	/	/	/	/
Q	0.373"	0.373"	0.374"	0.369"	/	/	/	/
R	/	0.395"	0.383"	0.386"	/	/	/	/



Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the and/or due to thickness of epoxy coating along the surface areas.

Larry Jernigan  
Technician Name

UT Level II  
Level/Certification

Signature

10-11-23  
Date

Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.

# ULTRASONIC EXAMINATION THICKNESS REPORT



ASME


S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616

Project #: 23050318	Report Date: 10-11-23
Project Name: Clearwater Natatorium UTT of structure framing	Procedure No. TR-NDT-UT-2
Project Location: Clearwater, FL	Material Type: <b>CS</b>
Client Name: McKim & Creed	Surface Condition: Painted

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)		
Manufacturer: Olympus	Model No.: DL38	Manufacturer: Panmetric	Model No.: D7908	Material: CS	Step #: 1	Thickness: 0.100"
Serial No.: 110194505	Cable Type: N/A	Serial No.: 1159629	Frequency: 7.5	Serial No: 988285	5	0.500"
Cable Length: 48"		Size: 0.25"				

Location: **B-5-T1-3**      Center: **0.390"**

	4"	8"	12"	16"	20"	24"	28"	32"
A	/	<b>0.392"</b>	/	<b>0.404"</b>	/	/	/	/
B	<b>0.389</b>	<b>0.393"</b>	<b>0.381"</b>	<b>0.376"</b>	<b>0.380"</b>	/	/	/
C	/	/	<b>0.404"</b>	<b>0.404"</b>	<b>0.405"</b>	<b>0.391"</b>	/	/
D	/	/	<b>0.274"</b>	<b>0.273"</b>	/	/	/	/
E	<b>0.269"</b>	<b>0.272"</b>	<b>0.267"</b>	<b>0.266"</b>	/	/	/	/
F	/	/	/	/	/	/	/	/
G	/	/	<b>0.285"</b>	<b>0.273"</b>	/	/	/	/
H	<b>0.277"</b>	<b>0.285"</b>	<b>0.266"</b>	<b>0.273"</b>	<b>0.271"</b>	/	/	/
I	/	<b>0.260"</b>	<b>0.250"</b>	<b>0.269"</b>	/	/	/	/
J	/	<b>0.280"</b>	<b>0.264"</b>	<b>0.257"</b>	/	/	/	/
K	<b>0.269"</b>	<b>0.272"</b>	<b>0.265"</b>	<b>0.258"</b>	/	/	/	/
L	/	/	<b>0.265"</b>	<b>0.266"</b>	/	/	/	/
M	/	/	/	/	/	/	/	/
N	<b>0.380"</b>	<b>0.386"</b>	<b>0.365"</b>	<b>0.385"</b>	<b>0.384"</b>	/	/	/
O	/	<b>0.357"</b>	/	<b>0.390"</b>	<b>0.371"</b>	<b>0.396"</b>	/	/
P	/	/	<b>0.389"</b>	<b>0.388"</b>	/	/	/	/
Q	/	<b>0.379"</b>	<b>0.378"</b>	<b>0.379"</b>	<b>0.371"</b>	/	/	/
R	<b>0.377"</b>	<b>0.398"</b>	<b>0.379"</b>	<b>0.379"</b>	/	/	/	/



Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the and/or due to thickness of epoxy coating along the surface areas.

Larry Jernigan  
Technician Name

UT Level II  
Level/Certification

Signature

10-11-23  
Date

Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.

# ULTRASONIC EXAMINATION THICKNESS REPORT



ASME

S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616


Project #: 23050318	Report Date: 10-11-23
Project Name: Clearwater Natatorium UTT of structure framing	Procedure No. TR-NDT-UT-2
Project Location: Clearwater, FL	Material Type: <b>CS</b>
Client Name: McKim & Creed	Surface Condition: Painted

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)		
Manufacturer: Olympus	Model No.: DL38	Manufacturer: Panmetric	Model No.: D7908	Material: CS	Step #: 1	Thickness: 0.100"
Serial No.: 110194505	Cable Type: N/A	Serial No.: 1159629	Frequency: 7.5	Serial No: 988285	5	0.500"
Cable Length: 48"		Size: 0.25"				

Location: **B-6.3-T1-1** Center: **0.149"**

	4"	8"	12"	16"	20"	24"	28"	32"
A	/	0.357"	0.357"	0.354"	/	/	/	/
B	0.355"	0.353"	0.353"	0.353"	/	/	/	/
C	/	/	0.354"	0.355"	/	/	/	/
D	/	/	/	/	/	/	/	/
E	0.339"	0.344"	0.345"	0.345"	/	/	/	/
F	/	0.318"	0.312"	0.320"	0.350"	/	/	/
G	/	0.340"	0.341"	/	/	/	/	/
H	0.354"	0.354"	0.354"	0.354"	/	/	/	/
I	/	/	/	/	/	/	/	/
J	0.241"	0.241"	0.239"	0.234"	/	/	/	/
K	0.251"	0.235"	0.235"	0.235"	/	/	/	/
L	/	/	/	/	/	/	/	/
M	/	/	/	/	/	/	/	/
N	0.234"	0.236"	0.235"	0.235"	/	/	/	/
O	/	0.238"	0.237"	0.237"	/	/	/	/
P	/	/	/	/	/	/	/	/
Q	/	0.236"	0.238"	0.237"	0.232"	0.234"	/	/
R	/	0.243"	0.242"	0.241"	/	/	/	/

North view



Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the and/or due to thickness of epoxy coating along the surface areas.

Larry Jernigan  
Technician Name

UT Level II  
Level/Certification

Larry Jernigan  
Signature

10-11-23  
Date

Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.

# ULTRASONIC EXAMINATION THICKNESS REPORT



ASME

S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616


Project #: 23050318	Report Date: 10-11-23
Project Name: Clearwater Natatorium UTT of structure framing	Procedure No. TR-NDT-UT-2
Project Location: Clearwater, FL	Material Type: <b>CS</b>
Client Name: McKim & Creed	Surface Condition: Painted

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)		
Manufacturer: Olympus	Model No.: DL38	Manufacturer: Panmetric	Model No.: D7908	Material: CS	Step #	Thickness
Serial No.: 110194505	Cable Type: N/A	Serial No.: 1159629	Frequency: 7.5	Serial No: 988285	1	0.100"
Cable Length: 48"		Size: 0.25"			5	0.500"

Location: **B-6.3-T1-2** Center: **0.356"**

	4"	8"	12"	16"	20"	24"	28"	32"
A	/	/	0.358"	/	/	/	/	/
B	0.355"	0.355"	0.354"	0.354"	/	/	/	/
C	0.357"	0.360"	0.359"	0.358"	/	/	/	/
D	/	/	/	/	/	/	/	/
E	0.343"	0.346"	0.345"	0.341"	/	/	/	/
F	0.318"	0.320"	0.319"	0.317"	0.328"	0.322"	/	/
G	0.359"	0.358"	0.358"	0.358"	/	/	/	/
H	0.355"	0.355"	0.355"	0.354"	/	/	/	/
I	/	/	/	/	/	/	/	/
J	/	/	0.232"	0.231"	0.234"	/	/	/
K	0.230"	0.230"	0.230"	0.231"	/	/	/	/
L	/	0.231"	0.231"	0.233"	/	/	/	/
M	0.238"	0.240"	0.242"	0.241"	/	/	/	/
N	0.203"	0.246"	0.245"	0.249"	/	/	/	/
O	0.242"	0.240"	0.242"	0.241"	/	/	/	/
P	/	/	0.231"	0.235"	/	/	/	/
Q	0.228"	0.225"	0.233"	0.233"	/	/	/	/
R	0.238"	0.235"	0.236"	0.233"	/	/	/	/

North view



Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the and/or due to thickness of epoxy coating along the surface areas.

Larry Jernigan  
Technician Name

UT Level II  
Level/Certification

*Larry Jernigan*  
Signature

10-11-23  
Date

Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.

# ULTRASONIC EXAMINATION THICKNESS REPORT



ASME


S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616

Project #: 23050318	Report Date: 10-11-23
Project Name: Clearwater Natatorium UTT of structure framing	Procedure No. TR-NDT-UT-2
Project Location: Clearwater, FL	Material Type: <b>CS</b>
Client Name: McKim & Creed	Surface Condition: Painted

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)		
Manufacturer: Olympus	Model No.: DL38	Manufacturer: Panmetric	Model No.: D7908	Material: CS	Step #	Thickness
Serial No.: 110194505	Cable Type: N/A	Serial No.: 1159629	Frequency: 7.5	Serial No: 988285	1	0.100"
Cable Length: 48"	Cable Length: 48"	Size: 0.25"			5	0.500"

Location: **B-6.3-T1-3** Center: **0.254"**

	4"	8"	12"	16"	20"	24"	28"	32"
A	/	0.359"	/	/	/	/	/	/
B	0.355"	0.355"	0.354"	0.354"	/	/	/	/
C	/	0.357"	0.357"	0.357"	/	/	/	/
D	/	/	/	/	/	/	/	/
E	0.322"	0.342"	0.340"	0.341"	/	/	/	/
F	/	/	/	/	/	/	/	/
G	0.335"	0.327"	0.357"	0.350"	/	/	/	/
H	0.355"	0.354"	0.354"	0.354"	/	/	/	/
I	/	0.357"	0.357"	0.357"	/	/	/	/
J	/	0.223"	0.234"	0.231"	/	/	/	/
K	0.222"	0.224"	0.227"	0.226"	/	/	/	/
L	/	/	/	/	/	/	/	/
M	/	0.234"	0.234"	0.235"	/	/	/	/
N	0.234"	0.234"	0.234"	0.234"	/	/	/	/
O	/	/	/	/	/	/	/	/
P	/	/	/	/	/	/	/	/
Q	0.229"	0.234"	0.234"	0.234"	/	/	/	/
R	/	0.236"	0.234"	0.235"	/	/	/	/



Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the and/or due to thickness of epoxy coating along the surface areas.

<u>Larry Jernigan</u> Technician Name	<u>UT Level II</u> Level/Certification	 Signature
		<u>10-11-23</u> Date

*Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.*

# ULTRASONIC EXAMINATION THICKNESS REPORT



ASME


S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616

Project #: 23050318	Report Date: 10-11-23
Project Name: Clearwater Natatorium UTT of structure framing	Procedure No. TR-NDT-UT-2
Project Location: Clearwater, FL	Material Type: <b>CS</b>
Client Name: McKim & Creed	Surface Condition: Painted

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)		
Manufacturer: Olympus	Model No.: DL38	Manufacturer: Panmetric	Model No.: D7908	Material: CS	Step #: 1	Thickness: 0.100"
Serial No.: 110194505	Cable Type: N/A	Serial No.: 1159629	Frequency: 7.5	Serial No: 988285	5	0.500"
Cable Length: 48"		Size: 0.25"				

Location: **B-6-T1-1** Center: **0.114"**

	4"	8"	12"	16"	20"	24"	28"	32"
A	/	/	/	/	/	/	/	/
B	0.355"	0.354"	0.354"	0.355"	/	/	/	/
C	/	0.358"	0.353"	0.337"	0.363"	/	/	/
D	/	0.227"	0.223"	0.233"	/	/	/	/
E	0.220"	0.225"	0.225"	0.227"	0.226"	/	/	/
F	/	/	/	/	/	/	/	/
G	/	/	0.239"	0.239"	/	/	/	/
H	0.235"	0.235"	0.235"	0.235"	/	/	/	/
I	/	/	/	/	/	/	/	/
J	/	/	0.236"	0.240"	/	/	/	/
K	0.233"	0.233"	0.234"	0.236"	/	/	/	/
L	0.237"	0.238"	0.240"	0.238"	/	/	/	/
M	/	/	/	/	/	/	/	/
N	0.353"	0.353"	0.354"	0.354"	/	/	/	/
O	0.335"	0.320"	0.327"	/	/	/	/	/
P	0.354"	0.345"	0.349"	0.348"	/	/	/	/
Q	0.239"	0.336"	0.346"	0.346"	/	/	/	/
R	0.335"	0.336"	0.334"	0.352"	/	/	/	/



Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the and/or due to thickness of epoxy coating along the surface areas.

Larry Jernigan  
Technician Name

UT Level II  
Level/Certification

*Larry Jernigan*  
Signature

10-11-23  
Date

Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.

# ULTRASONIC EXAMINATION THICKNESS REPORT



ASME


S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616

Project #: 23050318	Report Date: 10-11-23
Project Name: Clearwater Natatorium UTT of structure framing	Procedure No. TR-NDT-UT-2
Project Location: Clearwater, FL	Material Type: <b>CS</b>
Client Name: McKim & Creed	Surface Condition: Painted

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)		
Manufacturer: Olympus	Model No.: DL38	Manufacturer: Panmetric	Model No.: D7908	Material: CS	Step #	Thickness
Serial No.: 110194505	Cable Type: N/A	Serial No.: 1159629	Frequency: 7.5	Serial No: 988285	1	0.100"
Cable Length: 48"		Size: 0.25"			5	0.500"

Location: **B-6-T1-2** Center: **0.333"**

	4"	8"	12"	16"	20"	24"	28"	32"
A	0.353"	0.354"	0.359"	0.358"				
B	0.334"	0.329"	0.333"	0.335"				
C								
D								
E	0.214"	0.234"	0.234"	0.234"				
F		0.234"	0.234"	0.233"				
G		0.237"	0.236"	0.238"				
H	0.231"	0.231"	0.231"	0.231"				
I		0.231"	0.231"	0.232"				
J		0.240"	0.236"	0.239"				
K	0.236"	0.234"	0.234"	0.239"				
L								
M		0.340"	0.349"	0.349"				
N	0.353"	0.352"	0.353"	0.352"				
O		0.353"	0.355"	0.353"				
P								
Q	0.340"	0.342"	0.342"	0.342"				
R								



Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the and/or due to thickness of epoxy coating along the surface areas.

Larry Jernigan  
Technician Name

UT Level II  
Level/Certification

Larry Jernigan  
Signature

10-11-23  
Date

Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.

# ULTRASONIC EXAMINATION THICKNESS REPORT



ASME


S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616

Project #: 23050318	Report Date: 10-11-23
Project Name: Clearwater Natatorium UTT of structure framing	Procedure No. TR-NDT-UT-2
Project Location: Clearwater, FL	Material Type: <b>CS</b>
Client Name: McKim & Creed	Surface Condition: Painted

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)		
Manufacturer: Olympus		Manufacturer: Panmetric		Material: CS	Step #	Thickness
Model No.: DL38		Model No.: D7908		Serial No: 988285	1	0.100"
Serial No: 110194505		Serial No.: 1159629			5	0.500"
Cable Type: N/A		Frequency: 7.5				
Cable Length: 48"		Size: 0.25"				

Location: **B-6-T1-3** Center: **0.352"**

	4"	8"	12"	16"	20"	24"	28"	32"
A	/	/	/	/	/	/	/	/
B	0.353"	0.355"	0.354"	0.354"	/	/	/	/
C	/	0.358"	0.359"	0.357"	/	/	/	/
D	/	0.225"	0.227"	0.227"	/	/	/	/
E	0.232"	0.233"	0.233"	0.233"	/	/	/	/
F	/	0.233"	/	/	/	/	/	/
G	/	0.239"	0.238"	0.239"	/	/	/	/
H	0.232"	0.232"	0.233"	0.233"	/	/	/	/
I	/	0.232"	0.231"	0.231"	/	/	/	/
J	/	0.236"	0.240"	0.239"	/	/	/	/
K	0.211"	0.234"	0.234"	0.234"	/	/	/	/
L	/	0.236"	0.236"	0.236"	/	/	/	/
M	/	0.355"	0.357"	/	/	/	/	/
N	0.353"	0.354"	0.354"	0.354"	/	/	/	/
O	/	0.359"	0.357"	0.359"	/	/	/	/
P	/	/	/	/	/	/	/	/
Q	0.330"	0.343"	0.343"	0.343"	/	/	/	/
R	/	/	/	/	/	/	/	/



Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the and/or due to thickness of epoxy coating along the surface areas.

<u>Larry Jernigan</u> Technician Name	<u>UT Level II</u> Level/Certification	 Signature	<u>10-11-23</u> Date
--	---	---------------	-------------------------

*Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.*

# ULTRASONIC EXAMINATION THICKNESS REPORT



ASME


S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616

Project #: 23050318	Report Date: 10-11-23
Project Name: Clearwater Natatorium UTT of structure framing	Procedure No. TR-NDT-UT-2
Project Location: Clearwater, FL	Material Type: <b>CS</b>
Client Name: McKim & Creed	Surface Condition: Painted

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)		
Manufacturer: Olympus	Model No.: DL38	Manufacturer: Panmetric	Model No.: D7908	Material: CS	Step #: 1	Thickness: 0.100"
Serial No.: 110194505	Cable Type: N/A	Serial No.: 1159629	Frequency: 7.5	Serial No: 988285	5	0.500"
Cable Length: 48"		Size: 0.25"				

Location: **B-7-T1-1** Center: **0.364"**

	4"	8"	12"	16"	20"	24"	28"	32"
A	/	0.359"	0.359"	0.359"	/	/	/	/
B	0.347"	0.354"	0.353"	0.353"	/	/	/	/
C	/	0.358"	/	/	/	/	/	/
D	/	/	/	/	/	/	/	/
E	0.186"	0.231"	0.233"	0.233"	/	/	/	/
F	/	0.246"	0.241"	0.242"	/	/	/	/
G	/	0.232"	0.233"	0.234"	/	/	/	/
H	0.229"	0.219"	0.222"	0.233"	/	/	/	/
I	/	/	0.232"	/	/	/	/	/
J	/	/	/	/	/	/	/	/
K	0.236"	0.235"	0.235"	0.235"	/	/	/	/
L	0.236"	0.236"	0.236"	0.236"	/	/	/	/
M	/	0.357"	0.357"	0.356"	/	/	/	/
N	0.354"	0.356"	0.353"	0.353"	/	/	/	/
O	/	/	/	/	/	/	/	/
P	0.350"	0.348"	0.333"	0.344"	/	/	/	/
Q	0.336"	0.322"	0.344"	0.344"	/	/	/	/
R	/	0.346"	/	/	/	/	/	/



Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the and/or due to thickness of epoxy coating along the surface areas.

<u>Larry Jernigan</u> Technician Name	<u>UT Level II</u> Level/Certification	 Signature
		<u>10-11-23</u> Date

*Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.*

# ULTRASONIC EXAMINATION THICKNESS REPORT



ASME


S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616

Project #: 23050318	Report Date: 10-11-23
Project Name: Clearwater Natatorium UTT of structure framing	Procedure No. TR-NDT-UT-2
Project Location: Clearwater, FL	Material Type: <b>CS</b>
Client Name: McKim & Creed	Surface Condition: Painted

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)		
Manufacturer: Olympus	Model No.: DL38	Manufacturer: Panmetric	Model No.: D7908	Material: CS	Step #: 1	Thickness: 0.100"
Serial No.: 110194505	Cable Type: N/A	Serial No.: 1159629	Frequency: 7.5	Serial No: 988285	5	0.500"
Cable Length: 48"		Size: 0.25"				

Location: **B-7-T1-2** Center: **0.331"**

	4"	8"	12"	16"	20"	24"	28"	32"
A	/	/	/	/	/	/	/	/
B	0.329"	0.330"	0.328"	0.353"	0.354"	/	/	/
C	/	0.357"	0.359"	/	/	/	/	/
D	/	/	0.243"	0.242"	/	/	/	/
E	0.213"	0.234"	0.234"	0.234"	/	/	/	/
F	/	0.240"	0.242"	0.239"	/	/	/	/
G	/	0.235"	0.234"	0.234"	/	/	/	/
H	0.227"	0.230"	0.230"	0.230"	/	/	/	/
I	/	0.231"	0.232"	0.231"	/	/	/	/
J	/	0.232"	0.237"	0.236"	/	/	/	/
K	0.233"	0.237"	0.238"	0.241"	/	/	/	/
L	0.241"	0.240"	0.240"	0.240"	/	/	/	/
M	/	0.356"	0.356"	0.356"	/	/	/	/
N	0.354"	0.353"	0.353"	0.353"	/	/	/	/
O	/	0.354"	0.358"	0.357"	/	/	/	/
P	/	/	/	/	/	/	/	/
Q	0.167"	0.344"	0.344"	0.343"	/	/	/	/
R	/	0.346"	/	/	/	/	/	/



Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the and/or due to thickness of epoxy coating along the surface areas.


<u>Larry Jernigan</u> Technician Name	<u>UT Level II</u> Level/Certification	 Signature
		<u>10-11-23</u> Date

*Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.*

# ULTRASONIC EXAMINATION THICKNESS REPORT



ASME


S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616

Project #: 23050318	Report Date: 10-11-23
Project Name: Clearwater Natatorium UTT of structure framing	Procedure No. TR-NDT-UT-2
Project Location: Clearwater, FL	Material Type: <b>CS</b>
Client Name: McKim & Creed	Surface Condition: Painted

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)		
Manufacturer: Olympus	Model No.: DL38	Manufacturer: Panmetric	Model No.: D7908	Material: CS	Step #	Thickness
Serial No.: 110194505	Cable Type: N/A	Serial No.: 1159629	Frequency: 7.5	Serial No: 988285	1	0.100"
Cable Length: 48"		Size: 0.25"			5	0.500"

Location: **B-7-T1-3** Center: **0.331"**

	4"	8"	12"	16"	20"	24"	28"	32"
A	/	0.360"	0.360"	0.360"	/	/	/	/
B	0.355"	0.355"	0.354"	0.354"	/	/	/	/
C	/	0.358"	0.358"	0.358"	/	/	/	/
D	/	0.229"	0.228"	0.229"	/	/	/	/
E	0.201"	0.226"	0.226"	0.226"	/	/	/	/
F	/	/	0.230"	0.232"	/	/	/	/
G	/	0.238"	0.236"	/	/	/	/	/
H	0.230"	0.233"	0.233"	0.233"	/	/	/	/
I	/	0.240"	0.240"	0.242"	/	/	/	/
J	/	/	/	/	/	/	/	/
K	0.226"	0.234"	0.234"	0.234"	/	/	/	/
L	0.238"	0.237"	0.237"	0.238"	/	/	/	/
M	/	0.357"	0.330"	0.329"	/	/	/	/
N	0.354"	0.354"	0.354"	0.353"	/	/	/	/
O	/	0.325"	0.327"	0.325"	/	/	/	/
P	/	/	/	/	/	/	/	/
Q	0.334"	0.340"	0.341"	0.342"	/	/	/	/
R	/	/	/	/	/	/	/	/



Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the and/or due to thickness of epoxy coating along the surface areas.

Larry Jernigan  
Technician Name

UT Level II  
Level/Certification

Signature

10-11-23  
Date

Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.

# ULTRASONIC EXAMINATION THICKNESS REPORT



ASME

S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616


Project #:	23050318	Report Date:	10-12-23
Project Name:	Clearwater Natatorium UTT of structure framing	Procedure No.	TR-NDT-UT-2
Project Location:	Clearwater, FL	Material Type:	<b>CS</b>
Client Name:	McKim & Creed	Surface Condition:	Painted

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)			
Manufacturer:	Olympus	Manufacturer:	Panmetric	Material:	CS	Step #	Thickness
Model No.:	DL38	Model No.:	D790-SM	Serial No:	988285	1	0.100"
Serial No:	110194505	Serial No.:	754080			5	0.500"
Cable Type:	N/A	Frequency:	5 MHz				
Cable Length:	48"	Size:	7.9mm				

Location: **B-8.3-T1-1** Center: **0.353"**

	4"	8"	12"	16"	20"	24"	28"	32"
A	/	/	/	/	/	/	/	/
B	0.353"	0.353"	0.353"	0.355"	/	/	/	/
C	0.363"	0.362"	0.363"	0.363"	/	/	/	/
D	/	0.240"	0.247"	0.246"	/	/	/	/
E	0.232"	0.232"	0.233"	0.233"	/	/	/	/
F	/	/	/	/	/	/	/	/
G	/	/	/	/	/	/	/	/
H	0.223"	0.233"	0.233"	0.233"	/	/	/	/
I	/	0.244"	0.234"	0.234"	/	/	/	/
J	/	/	/	/	/	/	/	/
K	0.230"	0.231"	0.230"	0.230"	/	/	/	/
L	/	0.238"	0.239"	0.240"	/	/	/	/
M	/	/	/	/	/	/	/	/
N	0.353"	0.354"	0.354"	0.354"	/	/	/	/
O	0.358"	0.358"	0.342"	0.342"	/	/	/	/
P	0.352"	0.347"	0.354"	0.354"	/	/	/	/
Q	0.343"	0.341"	0.344"	0.344"	/	/	/	/
R	/	/	/	/	/	/	/	/

North view



Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the and/or due to thickness of epoxy coating along the surface areas.

Larry Jernigan  
Technician Name

UT Level II  
Level/Certification

Larry Jernigan  
Signature

10-12-23  
Date

Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.

## ULTRASONIC EXAMINATION THICKNESS REPORT



ASME


S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616

Project #:	23050318	Report Date:	10-12-23
Project Name:	Clearwater Natatorium UTT of structure framing	Procedure No.	TR-NDT-UT-2
Project Location:	Clearwater, FL	Material Type:	<b>CS</b>
Client Name:	McKim & Creed	Surface Condition:	Painted

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)			
Manufacturer:	Olympus	Manufacturer:	Panmetric	Material:	CS	Step #	Thickness
Model No.:	DL38	Model No.:	D790-SM	Serial No:	988285	1	0.100"
Serial No:	110194505	Serial No.:	754080			5	0.500"
Cable Type:	N/A	Frequency:	5 MHz				
Cable Length:	48"	Size:	7.9mm				

Location: **B-8.3-T1-2** Center: **0.351"**

	4"	8"	12"	16"	20"	24"	28"	32"
A	/	/	/	/	/	/	/	/
B	0.351"	0.350"	0.350"	0.351"	/	/	/	/
C	0.353"	0.352"	0.353"	0.353"	/	/	/	/
D	/	/	/	/	/	/	/	/
E	0.300"	0.341"	0.342"	0.343"	/	/	/	/
F	/	/	/	/	/	/	/	/
G	/	/	/	/	/	/	/	/
H	0.351"	0.352"	0.351"	0.352"	/	/	/	/
I	0.356"	0.357"	0.357"	0.356"	/	/	/	/
J	/	0.236"	0.238"	0.238"	/	/	/	/
K	0.233"	0.232"	0.233"	0.233"	/	/	/	/
L	/	/	0.234"	0.234"	/	/	/	/
M	/	/	/	/	/	/	/	/
N	0.234"	0.233"	0.233"	0.233"	/	/	/	/
O	/	0.238"	0.238"	0.238"	/	/	/	/
P	/	/	/	/	/	/	/	/
Q	0.211"	0.228"	0.229"	0.222"	0.232"	0.232"	/	/
R	/	0.242"	0.242"	0.240"	/	/	/	/



Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the and/or due to thickness of epoxy coating along the surface areas.

Larry Jernigan  
Technician Name

UT Level II  
Level/Certification

*Larry Jernigan*  
Signature

10-12-23  
Date

Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.

# ULTRASONIC EXAMINATION THICKNESS REPORT



ASME

S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616


Project #: 23050318	Report Date: 10-12-23
Project Name: Clearwater Natatorium UTT of structure framing	Procedure No. TR-NDT-UT-2
Project Location: Clearwater, FL	Material Type: <b>CS</b>
Client Name: McKim & Creed	Surface Condition: Painted

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)		
Manufacturer: Olympus	Model No.: DL38	Manufacturer: Panmetric	Model No.: D790-SM	Material: CS	Step #	Thickness
Serial No.: 110194505	Cable Type: N/A	Serial No.: 754080	Frequency: 5 MHz	Serial No: 988285	1	0.100"
Cable Length: 48"		Size: 7.9mm			5	0.500"

Location: **B-8.3-T1-3** Center: **0.351"**

	4"	8"	12"	16"	20"	24"	28"	32"
A	/	/	/	/	/	/	/	/
B	0.351"	0.351"	0.352"	0.352"	/	/	/	/
C	/	0.353"	0.355"	0.355"	/	/	/	/
D	0.325"	0.330"	0.352"	0.355"	0.350"	/	/	/
E	0.325"	0.339"	0.325"	0.331"	0.330"	/	/	/
F	/	/	/	/	/	/	/	/
G	/	/	/	/	/	/	/	/
H	0.351"	0.350"	0.351"	0.352"	/	/	/	/
I	/	/	/	/	/	/	/	/
J	/	/	/	/	/	/	/	/
K	0.233"	0.235"	0.236"	0.235"	/	/	/	/
L	/	0.237"	0.237"	0.234"	/	/	/	/
M	/	0.233"	0.241"	0.241"	0.241"	/	/	/
N	0.232	0.231"	0.241"	0.242"	/	/	/	/
O	/	/	/	/	/	/	/	/
P	/	/	/	/	/	/	/	/
Q	0.236"	0.231"	0.223"	0.234"	0.232"	0.232"	/	/
R	/	/	0.240"	0.238"	/	/	/	/

North view



Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the and/or due to thickness of epoxy coating along the surface areas.

Larry Jernigan  
Technician Name

UT Level II  
Level/Certification

*Larry Jernigan*  
Signature

10-12-23  
Date

Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.

# ULTRASONIC EXAMINATION THICKNESS REPORT



ASME


S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616

Project #: 23050318	Report Date: 10-12-23
Project Name: Clearwater Natatorium UTT of structure framing	Procedure No. TR-NDT-UT-2
Project Location: Clearwater, FL	Material Type: <b>CS</b>
Client Name: McKim & Creed	Surface Condition: Painted

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)		
Manufacturer: Olympus	Model No.: DL38	Manufacturer: Panmetric	Model No.: D790-SM	Material: CS	Step #: 1	Thickness: 0.100"
Serial No.: 110194505	Cable Type: N/A	Serial No.: 754080	Frequency: 5 MHz	Serial No: 988285	5	0.500"
Cable Length: 48"		Size: 7.9mm				

Location: **B-8-T1-1** Center: **0.350"**

	4"	8"	12"	16"	20"	24"	28"	32"
A	0.358"	0.357"	/	0.356"	/	/	/	/
B	0.351"	0.351"	0.351"	0.351"	/	/	/	/
C	/	0.355"	0.355"	0.355"	/	/	/	/
D	/	/	/	/	/	/	/	/
E	0.336"	0.337"	0.333"	0.327"	/	/	/	/
F	0.349"	0.346"	0.348"	0.350"	/	/	/	/
G	0.255"	0.258"	0.256"	0.256"	/	/	/	/
H	0.251"	0.251"	0.250"	0.250"	/	/	/	/
I	/	0.254"	0.253"	0.255"	/	/	/	/
J	/	0.243"	0.242"	0.243"	/	/	/	/
K	0.226"	0.232"	0.232"	0.232"	/	/	/	/
L	/	/	/	/	/	/	/	/
M	/	/	/	/	/	/	/	/
N	0.232"	0.233"	0.233"	0.232"	/	/	/	/
O	/	/	0.235"	0.235"	/	/	/	/
P	/	0.240"	0.238"	0.236"	/	/	/	/
Q	0.235"	0.236"	0.236"	0.235"	/	/	/	/
R	/	0.238"	0.238"	0.236"	/	/	/	/



Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the and/or due to thickness of epoxy coating along the surface areas.

Larry Jernigan  
Technician Name

UT Level II  
Level/Certification

Signature

10-12-23  
Date

Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.

# ULTRASONIC EXAMINATION THICKNESS REPORT



ASME


S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616

Project #: 23050318	Report Date: 10-12-23
Project Name: Clearwater Natatorium UTT of structure framing	Procedure No. TR-NDT-UT-2
Project Location: Clearwater, FL	Material Type: <b>CS</b>
Client Name: McKim & Creed	Surface Condition: Painted

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)		
Manufacturer: Olympus	Model No.: DL38	Manufacturer: Panmetric	Model No.: D790-SM	Material: CS	Step #: 1	Thickness: 0.100"
Serial No.: 110194505	Cable Type: N/A	Serial No.: 754080	Frequency: 5 MHz	Serial No: 988285	5	0.500"
Cable Length: 48"		Size: 7.9mm				

Location: **B-9.3-T1-1** Center: **0.295"**

	4"	8"	12"	16"	20"	24"	28"	32"
A	/	/	/	/	/	/	/	/
B	0.348"	0.348"	0.348"	0.348"	/	/	/	/
C	0.355"	0.355"	0.355"	0.355"	/	/	/	/
D	/	/	/	/	/	/	/	/
E	0.334"	0.344"	0.344"	0.344"	/	/	/	/
F	0.349"	0.329"	0.338"	0.349"	/	/	/	/
G	/	0.354"	0.355"	0.355"	/	/	/	/
H	0.349"	0.349"	0.348"	0.346"	/	/	/	/
I	/	/	/	/	/	/	/	/
J	/	0.239"	0.230"	0.230"	/	/	/	/
K	0.222"	0.230"	0.235"	0.233"	/	/	/	/
L	/	/	/	/	/	/	/	/
M	0.221"	/	0.238"	0.237"	/	/	/	/
N	0.232"	0.233"	0.234"	0.233"	/	/	/	/
O	/	/	/	/	/	/	/	/
P	/	0.231"	0.241"	/	/	/	/	/
Q	0.225"	0.230"	0.231"	0.231"	/	/	/	/
R	/	/	0.237"	0.234"	/	/	/	/



Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the and/or due to thickness of epoxy coating along the surface areas.

Larry Jernigan  
Technician Name

UT Level II  
Level/Certification

Signature

10-12-23  
Date

Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.

# ULTRASONIC EXAMINATION THICKNESS REPORT



ASME


S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616

Project #: 23050318	Report Date: 10-12-23
Project Name: Clearwater Natatorium UTT of structure framing	Procedure No. TR-NDT-UT-2
Project Location: Clearwater, FL	Material Type: <b>CS</b>
Client Name: McKim & Creed	Surface Condition: Painted

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)		
Manufacturer: Olympus		Manufacturer: Panmetric		Material: CS	Step #	Thickness
Model No.: DL38		Model No.: D790-SM		Serial No: 988285	1	0.100"
Serial No: 110194505		Serial No.: 754080			5	0.500"
Cable Type: N/A		Frequency: 5 MHz				
Cable Length: 48"		Size: 7.9mm				

Location: **B-9.3-T1-2** Center: **0.347"**

	4"	8"	12"	16"	20"	24"	28"	32"
A	/	/	/	/	/	/	/	/
B	0.345"	0.345"	0.345"	0.345"	/	/	/	/
C	0.353"	0.353"	0.352"	0.352"	/	/	/	/
D	/	/	/	/	/	/	/	/
E	0.325"	0.335"	0.336"	0.334"	/	/	/	/
F	/	/	/	/	/	/	/	/
G	/	0.357"	0.352"	0.353"	/	/	/	/
H	0.345"	0.345"	0.346"	0.346"	/	/	/	/
I	/	/	/	/	/	/	/	/
J	/	0.231"	0.233"	0.230"	/	/	/	/
K	0.228"	0.229"	0.222"	0.234"	/	/	/	/
L	/	/	/	/	/	/	/	/
M	/	0.237"	/	0.239"	/	/	/	/
N	0.233"	0.232"	0.233"	0.233"	/	/	/	/
O	/	0.237"	/	/	/	/	/	/
P	/	/	/	/	/	/	/	/
Q	0.233"	0.232"	0.233"	0.232"	/	/	/	/
R	/	/	0.240"	0.241"	/	/	/	/



Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the and/or due to thickness of epoxy coating along the surface areas.

Larry Jernigan  
Technician Name

UT Level II  
Level/Certification

Signature

10-12-23  
Date

Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.

# ULTRASONIC EXAMINATION THICKNESS REPORT



ASME

S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616


Project #: 23050318	Report Date: 10-12-23
Project Name: Clearwater Natatorium UTT of structure framing	Procedure No. TR-NDT-UT-2
Project Location: Clearwater, FL	Material Type: <b>CS</b>
Client Name: McKim & Creed	Surface Condition: Painted

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)		
Manufacturer: Olympus	Model No.: DL38	Manufacturer: Panmetric	Model No.: D790-SM	Material: CS	Step #: 1	Thickness: 0.100"
Serial No.: 110194505	Cable Type: N/A	Serial No.: 754080	Frequency: 5 MHz	Serial No: 988285	5	0.500"
Cable Length: 48"		Size: 7.9mm				

Location: **B-9.3-T1-3** Center: **0.345"**

	4"	8"	12"	16"	20"	24"	28"	32"
A	/	/	/	/	/	/	/	/
B	0.345"	0.346"	0.345"	0.345"	/	/	/	/
C	0.352"	0.351"	0.350"	0.352"	/	/	/	/
D	/	/	/	/	/	/	/	/
E	0.344"	0.345"	0.345"	0.344"	/	/	/	/
F	/	/	/	/	/	/	/	/
G	0.349"	0.351"	0.351"	0.351"	/	/	/	/
H	0.344"	0.346"	0.345"	0.344"	/	/	/	/
I	/	/	/	/	/	/	/	/
J	0.235"	0.238"	0.239"	0.232"	/	/	/	/
K	/	0.236"	0.238"	/	/	/	/	/
L	0.233"	0.232"	0.231"	0.232"	/	/	/	/
M	/	/	/	/	/	/	/	/
N	0.232"	0.234"	0.235"	0.233"	/	/	/	/
O	/	0.237"	0.238"	/	/	/	/	/
P	/	/	/	/	/	/	/	/
Q	0.229"	0.231"	0.232"	0.232"	/	/	/	/
R	/	0.240"	0.240"	0.239"	/	/	/	/

North view



Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the and/or due to thickness of epoxy coating along the surface areas.

Larry Jernigan  
Technician Name

UT Level II  
Level/Certification

Signature

10-12-23  
Date

Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.

# ULTRASONIC EXAMINATION THICKNESS REPORT



ASME


S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616

Project #: 23050318	Report Date: 10-12-23
Project Name: Clearwater Natatorium UTT of structure framing	Procedure No. TR-NDT-UT-2
Project Location: Clearwater, FL	Material Type: <b>CS</b>
Client Name: McKim & Creed	Surface Condition: Painted

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)		
Manufacturer: Olympus	Model No.: DL38	Manufacturer: Panmetric	Model No.: D790-SM	Material: CS	Step #: 1	Thickness: 0.100"
Serial No.: 110194505	Cable Type: N/A	Serial No.: 754080	Frequency: 5 MHz	Serial No: 988285	5	0.500"
Cable Length: 48"		Size: 7.9mm				

Location: **B-9-T1-1** Center: **0.348"**

	4"	8"	12"	16"	20"	24"	28"	32"
A	/	0.347"	0.358"	0.345"	/	/	/	/
B	0.349"	0.349"	0.349"	0.349"	/	/	/	/
C	/	/	/	/	/	/	/	/
D	/	0.236"	0.230"	0.231"	/	/	/	/
E	0.239"	0.231"	0.232"	0.230"	/	/	/	/
F	/	0.230"	/	0.230"	/	/	/	/
G	/	0.236"	0.234"	/	/	/	/	/
H	0.226"	0.231"	0.230"	0.231"	/	/	/	/
I	/	/	0.234"	/	/	/	/	/
J	/	/	/	/	/	/	/	/
K	0.231"	0.231"	0.231"	0.231"	/	/	/	/
L	/	0.238"	0.236"	0.237"	0.238"	/	/	/
M	/	/	/	/	/	/	/	/
N	0.349"	0.346"	0.348"	0.348"	/	/	/	/
O	/	0.358"	0.352"	0.351"	/	/	/	/
P	0.345"	0.355"	0.350"	0.345"	/	/	/	/
Q	0.302"	0.340"	0.341"	0.340"	/	/	/	/
R	/	/	/	/	/	/	/	/



*Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the and/or due to thickness of epoxy coating along the surface areas.*

Larry Jernigan  
Technician Name

UT Level II  
Level/Certification

*Larry Jernigan*  
Signature

10-12-23  
Date

*Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.*

# ULTRASONIC EXAMINATION THICKNESS REPORT



ASME


S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616

Project #: 23050318	Report Date: 10-12-23
Project Name: Clearwater Natatorium UTT of structure framing	Procedure No. TR-NDT-UT-2
Project Location: Clearwater, FL	Material Type: <b>CS</b>
Client Name: McKim & Creed	Surface Condition: Painted

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)		
Manufacturer: Olympus	Model No.: DL38	Manufacturer: Panmetric	Model No.: D790-SM	Material: CS	Step #: 1	Thickness: 0.100"
Serial No.: 110194505	Cable Type: N/A	Serial No.: 754080	Frequency: 5 MHz	Serial No: 988285	5	0.500"
Cable Length: 48"		Size: 7.9mm				

Location: **B-9-T1-2** Center: **0.350"**

	4"	8"	12"	16"	20"	24"	28"	32"
A		0.359"	0.361"	0.360"				
B	0.350"	0.350"	0.350"	0.350"				
C								
D		0.237"	0.235"	0.236"				
E	0.239"	0.230"	0.230"	0.230"				
F		0.235"		0.233"				
G								
H	0.234"	0.234"	0.233"	0.233"				
I		0.237"	0.238"					
J								
K	0.231"	0.229"	0.231"	0.231"				
L		0.238"	0.234"	0.238"				
M								
N	0.350"	0.348"	0.349"	0.351"				
O	0.360"	0.359"	0.359"	0.356"				
P								
Q	0.117"	0.341"	0.339"	0.340"	0.340"			
R		0.346"	0.346"	0.346"				



Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the and/or due to thickness of epoxy coating along the surface areas.

Larry Jernigan  
Technician Name

UT Level II  
Level/Certification

Signature

10-12-23  
Date

Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.

# ULTRASONIC EXAMINATION THICKNESS REPORT



ASME


S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616

Project #: 23050318	Report Date: 10-12-23
Project Name: Clearwater Natatorium UTT of structure framing	Procedure No. TR-NDT-UT-2
Project Location: Clearwater, FL	Material Type: <b>CS</b>
Client Name: McKim & Creed	Surface Condition: Painted

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)		
Manufacturer: Olympus	Model No.: DL38	Manufacturer: Panmetric	Model No.: D790-SM	Material: CS	Step #	Thickness
Serial No.: 110194505	Cable Type: N/A	Serial No.: 754080	Frequency: 5 MHz	Serial No: 988285	1	0.100"
Cable Length: 48"		Size: 7.9mm			5	0.500"

Location: **B-9-T1-3** Center: **0.350"**

	4"	8"	12"	16"	20"	24"	28"	32"
A		0.354"						
B	0.348"	0.349"	0.349"	0.349"				
C			0.349"	0.348"				
D		0.235"	0.235"	0.234"				
E	0.121"	0.232"	0.230"	0.232"				
F								
G								
H	0.230"	0.230"	0.235"	0.232"				
I		0.232"	0.232"	0.232"				
J		0.232"	0.232"	0.232"				
K	0.219"	0.231"	0.232"	0.232"				
L		0.233"	0.233"	0.232"				
M								
N	0.349"	0.349"	0.349"	0.349"				
O	0.358"	0.358"	0.354"	0.354"				
P								
Q	0.315"	0.333"	0.327"	0.326"				
R								



Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the and/or due to thickness of epoxy coating along the surface areas.

Larry Jernigan  
Technician Name

UT Level II  
Level/Certification

Signature

10-12-23  
Date

Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.

# ULTRASONIC EXAMINATION THICKNESS REPORT



ASME


S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616

Project #:	23050318	Report Date:	10-12-23
Project Name:	Clearwater Natatorium UTT of structure framing	Procedure No.	TR-NDT-UT-2
Project Location:	Clearwater, FL	Material Type:	<b>CS</b>
Client Name:	McKim & Creed	Surface Condition:	Painted

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)			
Manufacturer:	Olympus	Manufacturer:	Panmetric	Material:	CS	Step #	Thickness
Model No.:	DL38	Model No.:	D790-SM	Serial No:	988285	1	0.100"
Serial No:	110194505	Serial No.:	754080			<b>5</b>	0.500"
Cable Type:	N/A	Frequency:	5 MHz				
Cable Length:	48"	Size:	7.9mm				

Location: **B-10.3-T2-1** Center: **N/A**

	4"	8"	12"	16"	20"	24"	28"	32"
A	/	/	/	/	/	/	/	/
B	0.359"	0.359"	0.359"	0.359"	/	/	/	/
C	/	0.355"	/	/	/	/	/	/
D	/	/	0.356"	0.356"	/	/	/	/
E	0.354"	0.355"	0.356"	0.356"	/	/	/	/
F	/	/	/	/	/	/	/	/
G	/	0.222"	0.218"	0.223"	/	/	/	/
H	0.215"	0.231"	0.231"	0.230"	/	/	/	/
I	/	/	/	/	/	/	/	/
J	/	0.235"	0.235"	0.235"	/	/	/	/
K	0.235"	0.234"	0.234"	0.233"	/	/	/	/
L	/	0.236"	0.235"	0.235"	/	/	/	/
M	/	/	/	/	/	/	/	/
N	0.232"	0.232"	0.232"	0.232"	/	/	/	/
O	0.239"	0.239"	0.240"	0.240"	/	/	/	/
Aa	/	/	/	/	/	/	/	/
Bb	0.450"	0.450"	0.450"	0.442"	/	/	/	/
Cc	0.455"	0.455"	0.455"	0.455"	/	/	/	/



Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the and/or due to thickness of epoxy coating along the surface areas.

Larry Jernigan  
Technician Name

UT Level II  
Level/Certification

*Larry Jernigan*  
Signature

10-12-23  
Date

Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.

# ULTRASONIC EXAMINATION THICKNESS REPORT



ASME


S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616

Project #:	23050318	Report Date:	10-12-23
Project Name:	Clearwater Natatorium UTT of structure framing	Procedure No.	TR-NDT-UT-2
Project Location:	Clearwater, FL	Material Type:	<b>CS</b>
Client Name:	McKim & Creed	Surface Condition:	Painted

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)			
Manufacturer:	Olympus	Manufacturer:	Panmetric	Material:	CS	Step #	Thickness
Model No.:	DL38	Model No.:	D790-SM	Serial No:	988285	1	0.100"
Serial No:	110194505	Serial No.:	754080			5	0.500"
Cable Type:	N/A	Frequency:	5 MHz				
Cable Length:	48"	Size:	7.9mm				

Location: **B-10.3-T2-2** Center: **N/A**

	4"	8"	12"	16"	20"	24"	28"	32"
A	/	/	/	/	/	/	/	/
B	0.341"	0.355"	0.357"	0.357"	/	/	/	/
C	/	/	/	/	/	/	/	/
D	/	/	/	/	/	/	/	/
E	0.359"	0.359"	0.362"	0.359"	/	/	/	/
F	/	/	0.359"	0.356"	/	/	/	/
G	/	0.238"	0.238"	0.239"	/	/	/	/
H	0.236"	0.236"	0.235"	0.235"	/	/	/	/
I	/	/	/	/	/	/	/	/
J	/	/	0.234"	0.234"	/	/	/	/
K	0.229"	0.231"	0.230"	0.231"	/	/	/	/
L	/	/	/	/	/	/	/	/
M	/	/	/	/	/	/	/	/
N	0.236"	0.233"	0.232"	0.232"	/	/	/	/
O	/	0.239"	0.238"	0.239"	/	/	/	/
Aa	/	/	/	/	/	/	/	/
Bb	0.457"	0.460"	0.460"	0.459"	/	/	/	/
Cc	/	/	/	/	/	/	/	/



Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the and/or due to thickness of epoxy coating along the surface areas.

Larry Jernigan  
Technician Name

UT Level II  
Level/Certification

*Larry Jernigan*  
Signature

10-12-23  
Date

Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.

# ULTRASONIC EXAMINATION THICKNESS REPORT



ASME


S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616

Project #: 23050318	Report Date: 10-12-23
Project Name: Clearwater Natatorium UTT of structure framing	Procedure No. TR-NDT-UT-2
Project Location: Clearwater, FL	Material Type: <b>CS</b>
Client Name: McKim & Creed	Surface Condition: Painted

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)		
Manufacturer: Olympus	Model No.: DL38	Manufacturer: Panmetric	Model No.: D790-SM	Material: CS	Step #	Thickness
Serial No.: 110194505	Cable Type: N/A	Serial No.: 754080	Frequency: 5 MHz	Serial No: 988285	1	0.100"
Cable Length: 48"		Size: 7.9mm			5	0.500"

Location: **B-10.3-T2-3** Center: **N/A**

	4"	8"	12"	16"	20"	24"	28"	32"
A	/	/	/	/	/	/	/	/
B	0.359"	0.359"	0.359"	0.359"	/	/	/	/
C	/	/	/	/	/	/	/	/
D	/	/	/	/	/	/	/	/
E	0.366"	0.337"	0.336"	0.356"	/	/	/	/
F	/	/	/	/	/	/	/	/
G	/	/	/	/	/	/	/	/
H	0.231"	0.231"	0.231"	0.230"	/	/	/	/
I	/	0.231"	0.237"	0.235"	/	/	/	/
J	/	0.231"	0.231"	0.233"	/	/	/	/
K	0.227"	0.233"	0.232"	0.233"	/	/	/	/
L	/	0.238"	0.232"	0.232"	/	/	/	/
M	/	0.240"	0.241"	0.240"	/	/	/	/
N	0.233"	0.233"	0.233"	0.233"	/	/	/	/
O	/	/	/	/	/	/	/	/
Aa	/	/	/	/	/	/	/	/
Bb	0.422"	0.447"	0.466"	0.448"	/	/	/	/
Cc	0.478"	0.478"	0.478"	0.476"	/	/	/	/



Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the and/or due to thickness of epoxy coating along the surface areas.

Larry Jernigan  
Technician Name

UT Level II  
Level/Certification

*Larry Jernigan*  
Signature

10-12-23  
Date

Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.

# ULTRASONIC EXAMINATION THICKNESS REPORT



ASME


S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616

Project #: 23050318	Report Date: 10-12-23
Project Name: Clearwater Natatorium UTT of structure framing	Procedure No. TR-NDT-UT-2
Project Location: Clearwater, FL	Material Type: <b>CS</b>
Client Name: McKim & Creed	Surface Condition: Painted

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)		
Manufacturer: Olympus	Model No.: DL38	Manufacturer: Panmetric	Model No.: D790-SM	Material: CS	Step #: 1	Thickness: 0.100"
Serial No.: 110194505	Cable Type: N/A	Serial No.: 754080	Frequency: 5 MHz	Serial No: 988285	5	0.500"
Cable Length: 48"		Size: 7.9mm				

Location: **B-10-T1-1** Center: **0.350"**

	4"	8"	12"	16"	20"	24"	28"	32"
A	/	/	/	/	/	/	/	/
B	0.329"	0.350"	0.350"	0.350"	/	/	/	/
C	/	0.354"	0.356"	0.354"	/	/	/	/
D	/	/	0.238"	0.238"	/	/	/	/
E	0.234"	0.239"	0.235"	0.235"	/	/	/	/
F	/	/	/	/	/	/	/	/
G	/	/	/	/	/	/	/	/
H	0.233"	0.233"	0.233"	0.233"	/	/	/	/
I	/	0.234"	0.234"	/	/	/	/	/
J	/	/	/	/	/	/	/	/
K	0.229"	0.232"	0.232"	0.232"	/	/	/	/
L	/	0.233"	0.238"	0.235"	/	/	/	/
M	/	/	/	/	/	/	/	/
N	0.249"	0.250"	0.249"	0.248"	/	/	/	/
O	0.251"	0.251"	0.252"	0.252"	/	/	/	/
P	/	/	/	/	/	/	/	/
Q	0.344"	0.344"	0.344"	0.344"	/	/	/	/
R	0.345"	0.343"	0.346"	0.346"	/	/	/	/



Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the and/or due to thickness of epoxy coating along the surface areas.

Larry Jernigan  
Technician Name

UT Level II  
Level/Certification

Signature

10-12-23  
Date

Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.

# ULTRASONIC EXAMINATION THICKNESS REPORT



ASME

S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616


Project #:	23050318	Report Date:	10-12-23
Project Name:	Clearwater Natatorium UTT of structure framing	Procedure No.	TR-NDT-UT-2
Project Location:	Clearwater, FL	Material Type:	<b>CS</b>
Client Name:	McKim & Creed	Surface Condition:	Painted

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)			
Manufacturer:	Olympus	Manufacturer:	Panmetric	Material:	CS	Step #	Thickness
Model No.:	DL38	Model No.:	D790-SM	Serial No:	988285	1	0.100"
Serial No:	110194505	Serial No.:	754080			5	0.500"
Cable Type:	N/A	Frequency:	5 MHz				
Cable Length:	48"	Size:	7.9mm				

Location: **B-10-T1-2** Center: **0.347"**

	4"	8"	12"	16"	20"	24"	28"	32"
A	/	/	0.354"	0.353"	/	/	/	/
B	0.349"	0.350"	0.350"	0.350"	/	/	/	/
C	/	/	0.354"	0.354"	/	/	/	/
D	/	0.239"	0.238"	/	/	/	/	/
E	0.228"	0.220"	0.231"	0.233"	/	/	/	/
F	/	0.236"	0.236"	0.237"	/	/	/	/
G	/	/	/	/	/	/	/	/
H	0.229"	0.231"	0.231"	0.231"	/	/	/	/
I	/	/	0.235"	0.234"	/	/	/	/
J	/	/	0.230"	0.230"	/	/	/	/
K	0.208"	0.234"	0.234"	0.232"	/	/	/	/
L	/	0.240"	0.235"	0.238"	/	/	/	/
M	/	/	/	/	/	/	/	/
N	0.349"	0.348"	0.349"	0.349"	/	/	/	/
O	/	0.353"	0.356"	0.354"	/	/	/	/
P	/	/	/	/	/	/	/	/
Q	0.330"	0.323"	0.329"	0.325"	/	/	/	/
R	/	/	/	/	/	/	/	/

North view



Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the and/or due to thickness of epoxy coating along the surface areas.

Larry Jernigan  
Technician Name

UT Level II  
Level/Certification

Signature

10-12-23  
Date

Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.

# ULTRASONIC EXAMINATION THICKNESS REPORT



ASME


S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616

Project #: 23050318	Report Date: 10-12-23
Project Name: Clearwater Natatorium UTT of structure framing	Procedure No. TR-NDT-UT-2
Project Location: Clearwater, FL	Material Type: <b>CS</b>
Client Name: McKim & Creed	Surface Condition: Painted

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)		
Manufacturer: Olympus	Model No.: DL38	Manufacturer: Panmetric	Model No.: D790-SM	Material: CS	Step #	Thickness
Serial No.: 110194505	Cable Type: N/A	Serial No.: 754080	Frequency: 5 MHz	Serial No: 988285	1	0.100"
Cable Length: 48"		Size: 7.9mm			5	0.500"

Location: **B-10-T1-3** Center: **0.347"**

	4"	8"	12"	16"	20"	24"	28"	32"
A	/	/	0.354"	0.353"	/	/	/	/
B	0.347"	0.347"	0.349"	0.349"	/	/	/	/
C	/	/	/	/	/	/	/	/
D	/	/	0.216"	0.244"	/	/	/	/
E	0.234"	0.221"	0.233"	0.234"	/	/	/	/
F	/	/	/	/	/	/	/	/
G	/	/	/	/	/	/	/	/
H	0.231"	0.233"	0.233"	0.233"	/	/	/	/
I	/	/	0.231"	0.231"	/	/	/	/
J	/	0.240"	0.240"	0.242"	/	/	/	/
K	0.231"	0.232"	0.231"	0.232"	/	/	/	/
L	/	/	0.234"	0.236"	/	/	/	/
M	/	/	0.352"	0.354"	/	/	/	/
N	0.347"	0.347"	0.347"	0.348"	/	/	/	/
O	0.352"	/	/	/	/	/	/	/
P	/	/	/	/	/	/	/	/
Q	0.345"	0.342"	0.345"	0.345"	/	/	/	/
R	/	/	/	/	/	/	/	/



Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the and/or due to thickness of epoxy coating along the surface areas.

Larry Jernigan  
Technician Name

UT Level II  
Level/Certification

Signature

10-12-23  
Date

Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.

# ULTRASONIC EXAMINATION THICKNESS REPORT



ASME

S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616


Project #: 23050318	Report Date: 10-9-23
Project Name: Clearwater Natatorium UTT of structure framing	Procedure No. TR-NDT-UT-2
Project Location: Clearwater, FL	Material Type: <b>CS</b>
Client Name: McKim & Creed	Surface Condition: bare

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)		
Manufacturer: Olympus	Model No.: DL38	Manufacturer: Panmetric	Model No.: D7908	Material: CS	Step #	Thickness
Serial No.: 110194505	Cable Type: N/A	Serial No.: 1159629	Frequency: 7.5	Serial No: 988285	1	0.100"
Cable Length: 48"		Size: 0.25"			5	0.500"

Location: **D-1.3-T1-1** Center: **(B)0.359" (A)0.371"**

South side view

	4"	8"	12"	16"	20"	24"	28"	32"
A	0.356"	0.356"	0.355"	0.356"				
B	0.363"	0.353"	0.352"	0.353"				
C		0.371"	0.375"					
D		0.238"	0.235"	0.237"				
E	0.202"	0.202"	0.210"	0.243"				
F								
G								
H	0.249"	0.233"	0.233"	0.233"				
I								
J								
K	0.353"	0.357"	0.351"	0.351"				
L	0.356"	0.362"	0.363"	0.366"				
M								
N								
O								
Aa								
Bb								
Cc								
Dd								



Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the surface area.

Larry Jernigan  
Technician Name

UT Level II  
Level/Certification

Signature

10-9-23  
Date

Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.

# ULTRASONIC EXAMINATION THICKNESS REPORT



ASME


S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616

Project #: 23050318	Report Date: 10-9-23
Project Name: Clearwater Natatorium UTT of structure framing	Procedure No. TR-NDT-UT-2
Project Location: Clearwater, FL	Material Type: <b>CS</b>
Client Name: McKim & Creed	Surface Condition: bare

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)		
Manufacturer: Olympus		Manufacturer: Panmetric		Material: CS	Step #	Thickness
Model No.: DL38		Model No.: D7908		Serial No: 988285	1	0.100"
Serial No: 110194505		Serial No.: 1159629			5	0.500"
Cable Type: N/A		Frequency: 7.5				
Cable Length: 48"		Size: 0.25"				

Location: **D-1.3-T1-4** Center: **N/A**

	4"	8"	12"	16"	20"	24"	28"	32"
A	/	/	/	/	/	/	/	/
B	0.357"	0.355"	0.356"	0.355"	/	/	/	/
C	/	/	/	/	/	/	/	/
D	/	/	/	/	/	/	/	/
E	0.239"	0.234"	0.236"	0.235"	/	/	/	/
F	/	/	/	/	/	/	/	/
G	/	/	/	/	/	/	/	/
H	0.185"	0.231"	0.222"	0.224"	/	/	/	/
I	/	/	/	/	/	/	/	/
J	/	/	/	/	/	/	/	/
K	0.227"	0.229"	0.228"	0.224"	/	/	/	/
L	/	/	/	/	/	/	/	/
M	/	/	/	/	/	/	/	/
N	0.355"	0.356"	0.357"	0.356"	/	/	/	/
O	/	/	/	/	/	/	/	/
Aa	/	0.256"	0.302"	0.299"	/	/	/	/
Bb	0.280"	0.299"	0.295"	0.328"	/	/	/	/
Cc	0.294"	0.300"	0.315"	0.332"	/	/	/	/
Dd	/	/	/	/	/	/	/	/



Aa  
Bb **16" 12" 8" 4"**  
Cc

Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the surface area.

Larry Jernigan  
Technician Name

UT Level II  
Level/Certification

*Larry Jernigan*  
Signature

10-9-23  
Date

Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.

# ULTRASONIC EXAMINATION THICKNESS REPORT




ASME

S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616

Project #: 23050318	Report Date: 10-9-23
Project Name: Clearwater Natatorium UTT of structure framing	Procedure No. TR-NDT-UT-2
Project Location: Clearwater, FL	Material Type: <b>CS</b>
Client Name: McKim & Creed	Surface Condition: bare

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)		
Manufacturer: Olympus	Model No.: DL38	Manufacturer: Panmetric	Model No.: D7908	Material: CS	Step #	Thickness
Serial No.: 110194505	Cable Type: N/A	Serial No.: 1159629	Frequency: 7.5	Serial No: 988285	1	0.100"
Cable Length: 48"	Cable Length: 48"	Size: 0.25"			5	0.500"

Location:	<b>D-1-T2-1</b>				<b>Center: N/A</b>			
	4"	8"	12"	16"	20"	24"	28"	32"
A	/	/	/	/	/	/	/	/
B	/	0.363"	0.365"	0.365"	/	/	/	/
C	/	/	/	/	/	/	/	/
D	/	/	/	/	/	/	/	/
E	/	0.360"	0.356"	0.352"	/	/	/	/
F	/	/	/	/	/	/	/	/
G	/	/	/	/	/	/	/	/
H	/	/	/	0.232"	0.245"	0.245"	0.241"	0.247"
I	/	/	/	/	/	/	/	/
J	/	/	/	/	/	/	/	/
K	/	/	0.232"	0.230"	0.229"	0.229"	/	/
L	/	/	/	/	/	/	/	/
M	/	/	/	/	/	/	/	/
N	/	/	/	/	/	/	/	/
O	/	/	/	/	/	/	/	/
Aa	/	/	/	/	/	/	/	/
Bb	/	/	0.436"	0.439"	0.439"	0.452"	/	/
Cc	/	/	0.449"	0.449"	0.460"	0.460"	/	/
Dd	/	/	/	/	/	/	/	/



*Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the surface area.*

*Repiar plate present along the connection, plate thickness 0.375".*

<u>Larry Jernigan</u> Technician Name	<u>UT Level II</u> Level/Certification	 Signature
		<u>10-9-23</u> Date

*Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.*

# ULTRASONIC EXAMINATION THICKNESS REPORT





ASME

S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616

Project #: 23050318	Report Date: 10-9-23
Project Name: Clearwater Natatorium UTT of structure framing	Procedure No. TR-NDT-UT-2
Project Location: Clearwater, FL	Material Type: <b>CS</b>
Client Name: McKim & Creed	Surface Condition: bare

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)		
Manufacturer: Olympus	Model No.: DL38	Manufacturer: Panmetric	Model No.: D7908	Material: CS	Step #: 1	Thickness: 0.100"
Serial No.: 110194505	Cable Type: N/A	Serial No.: 1159629	Frequency: 7.5	Serial No: 988285	5	0.500"
Cable Length: 48"		Size: 0.25"				

Location:	D-1-T2-2				Center: N/A			
	4"	8"	12"	16"	20"	24"	28"	32"
A								
B								
C								
D								
E								
F								
G								
H	0.130"	0.232"	0.230"	0.227"				
I								
J								
K	0.112"	0.229"	0.228"	0.226"				
L								
M								
N	0.126"	0.198"	0.199"	0.198"				
O								
Aa				0.450"				
Bb	0.430"	0.448"	0.449"	0.450"				
Cc								
Dd								



Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the surface area.

<u>Larry Jernigan</u> Technician Name	<u>UT Level II</u> Level/Certification	 Signature	<u>10-9-23</u> Date
--	---	---------------	------------------------

*Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.*

# ULTRASONIC EXAMINATION THICKNESS REPORT




ASME

S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616

Project #: 23050318	Report Date: 10-9-23
Project Name: Clearwater Natatorium UTT of structure framing	Procedure No. TR-NDT-UT-2
Project Location: Clearwater, FL	Material Type: <b>CS</b>
Client Name: McKim & Creed	Surface Condition: bare

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)		
Manufacturer: Olympus		Manufacturer: Panmetric		Material: CS	Step #	Thickness
Model No.: DL38		Model No.: D7908		Serial No: 988285	1	0.100"
Serial No: 110194505		Serial No.: 1159629			<b>5</b>	0.500"
Cable Type: N/A		Frequency: 7.5				
Cable Length: 48"		Size: 0.25"				

Location: <b>D-1-T2-3</b>	Center: <b>N/A</b>							
	4"	8"	12"	16"	20"	24"	28"	32"
A								
B								
C								
D								
E								
F								
G								
H	0.206"	0.230"	0.229"	0.230"				
I								
J								
K	0.205"	0.229"	0.237"	0.236"				
L								
M								
N	0.212"	0.220"	0.224"	0.223"				
O								
Aa								
Bb	0.381"	0.464"	0.444"	0.439"				
Cc								
Dd								



Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the surface area.

\* H&K surfaces has a 1"x3" thorough wall hole along it corners.

<u>Larry Jernigan</u> Technician Name	<u>UT Level II</u> Level/Certification	 Signature	<u>10-9-23</u> Date
--	---	---------------	------------------------

*Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.*

# ULTRASONIC EXAMINATION THICKNESS REPORT




ASME

S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616

Project #: 23050318	Report Date: 10-9-23
Project Name: Clearwater Natatorium UTT of structure framing	Procedure No. TR-NDT-UT-2
Project Location: Clearwater, FL	Material Type: <b>CS</b>
Client Name: McKim & Creed	Surface Condition: bare

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)		
Manufacturer: Olympus		Manufacturer: Panmetric		Material: CS	Step #	Thickness
Model No.: DL38		Model No.: D7908		Serial No: 988285	1	0.100"
Serial No: 110194505		Serial No.: 1159629			<b>5</b>	0.500"
Cable Type: N/A		Frequency: 7.5				
Cable Length: 48"		Size: 0.25"				

Location: <b>D-1-T2-4</b>	Center: <b>N/A</b>							
	4"	8"	12"	16"	20"	24"	28"	32"
A								
B								
C								
D								
E								
F								
G								
H	0.162"	0.228"	0.228"	0.228"				
I								
J								
K	0.140"	0.208"	0.210"	0.199"	0.230"	0.230"		
L								
M								
N	0.125"	0.229"	0.229"	0.229"				
O								
Aa								
Bb	0.240"	0.293"	0.275"	0.326"	0.336"			
Cc								
Dd								



Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the surface area.

<u>Larry Jernigan</u> Technician Name	<u>UT Level II</u> Level/Certification	<u><i>Larry Jernigan</i></u> Signature	<u>10-9-23</u> Date
--	---	---	------------------------

*Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.*

# ULTRASONIC EXAMINATION THICKNESS REPORT



ASME


S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616

Project #: 23050318	Report Date: 10-13-23
Project Name: Clearwater Natatorium UTT of structure framing	Procedure No. TR-NDT-UT-2
Project Location: Clearwater, FL	Material Type: <b>CS</b>
Client Name: McKim & Creed	Surface Condition: Painted

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)		
Manufacturer: Olympus		Manufacturer: Panmetric		Material: CS	Step #	Thickness
Model No.: DL38		Model No.: D790-SM		Serial No: 988285	1	0.100"
Serial No: 110194505		Serial No.: 754080			<b>5</b>	0.500"
Cable Type: N/A		Frequency: 5 MHz				
Cable Length: 48"		Size: 7.9mm				

Location: **D-10.3-T2-1** Center: **N/A**

	4"	8"	12"	16"	20"	24"	28"	32"
A	/	/	/	/	/	/	/	/
B	/	/	/	/	/	/	/	/
C	/	0.354"	0.354"	0.355"	/	/	/	/
D	/	0.241"	0.243"	0.242"	/	/	/	/
E	0.236"	0.236"	0.235"	0.235"	/	/	/	/
F	/	/	/	/	/	/	/	/
G	/	/	/	/	/	/	/	/
H	0.228"	0.231"	0.233"	0.232"	/	/	/	/
I	0.231"	0.235"	0.230"	0.240"	/	/	/	/
J	/	/	/	/	/	/	/	/
K	/	/	/	/	/	/	/	/
L	/	/	/	/	/	/	/	/
M	/	/	/	/	/	/	/	/
N	/	/	/	/	/	/	/	/
O	/	/	/	/	/	/	/	/
Aa	/	/	/	/	/	/	/	/
Bb	0.460"	0.462"	0.461"	0.461"	/	/	/	/
Cc	0.443"	0.433"	0.459"	0.447"	/	/	/	/



East view

Aa	
Bb	16" 12" 8" 4"
Cc	

*Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the and/or due to thickness of epoxy coating along the surface areas.*

Larry Jernigan  
Technician Name

UT Level II  
Level/Certification

*Larry Jernigan*  
Signature

10-13-23  
Date

*Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.*

# ULTRASONIC EXAMINATION THICKNESS REPORT



ASME

S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616


Project #: 23050318	Report Date: 10-13-23
Project Name: Clearwater Natatorium UTT of structure framing	Procedure No. TR-NDT-UT-2
Project Location: Clearwater, FL	Material Type: <b>CS</b>
Client Name: McKim & Creed	Surface Condition: Painted

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)		
Manufacturer: Olympus		Manufacturer: Panmetric		Material: CS	Step #	Thickness
Model No.: DL38		Model No.: D790-SM		Serial No: 988285	1	0.100"
Serial No: 110194505		Serial No.: 754080			5	0.500"
Cable Type: N/A		Frequency: 5 MHz				
Cable Length: 48"		Size: 7.9mm				


Location: **D-10.3-T2-2** Center: **N/A**

	4"	8"	12"	16"	20"	24"	28"	32"
A	/	/	/	/	/	/	/	/
B	/	/	/	/	/	/	/	/
C	/	0.361"	0.362"	0.364"	0.364"	/	/	/
D	/	0.237"	0.238"	0.238"	/	/	/	/
E	0.207"	0.230"	0.232"	0.232"	/	/	/	/
F	/	/	/	/	/	/	/	/
G	/	/	0.233"	0.233"	/	/	/	/
H	0.232"	0.233"	0.233"	0.233"	/	/	/	/
I	/	/	0.243"	0.242"	/	/	/	/
J	/	0.233"	/	0.233"	/	/	/	/
K	0.220"	0.231"	0.231"	0.231"	/	/	/	/
L	/	0.234"	0.236"	0.236"	/	/	/	/
M	/	/	/	/	/	/	/	/
N	0.364"	/	0.362"	/	/	/	/	/
O	0.358"	0.356"	0.357"	0.357"	/	/	/	/
Aa	/	/	/	/	/	/	/	/
Bb	0.463"	0.452"	0.463"	0.468"	/	/	/	/
Cc	/	/	/	/	/	/	/	/

South view



East view



*Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the and/or due to thickness of epoxy coating along the surface areas.*

Larry Jernigan  
Technician Name

UT Level II  
Level/Certification

Signature

10-13-23  
Date

*Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.*

# ULTRASONIC EXAMINATION THICKNESS REPORT



ASME

S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616


Project #: 23050318	Report Date: 10-13-23
Project Name: Clearwater Natatorium UTT of structure framing	Procedure No. TR-NDT-UT-2
Project Location: Clearwater, FL	Material Type: <b>CS</b>
Client Name: McKim & Creed	Surface Condition: Painted

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)		
Manufacturer: Olympus	Model No.: DL38	Manufacturer: Panmetric	Model No.: D790-SM	Material: CS	Step #	Thickness
Serial No.: 110194505	Cable Type: N/A	Serial No.: 754080	Frequency: 5 MHz	Serial No: 988285	1	0.100"
Cable Length: 48"		Size: 7.9mm			5	0.500"

Location: **D-10.3-T2-3** Center: **N/A**

	4"	8"	12"	16"	20"	24"	28"	32"
A	/	/	/	/	/	/	/	/
B	0.358"	0.358"	0.358"	0.359"	/	/	/	/
C	/	/	/	/	/	/	/	/
D	/	0.243"	0.244"	0.231"	/	/	/	/
E	0.237"	0.237"	0.237"	0.238"	/	/	/	/
F	/	/	/	/	/	/	/	/
G	/	/	/	/	/	/	/	/
H	0.234"	0.233"	0.234"	0.234"	/	/	/	/
I	/	0.238"	0.237"	0.236"	/	/	/	/
J	/	/	/	/	/	/	/	/
K	0.235"	0.236"	0.236"	0.235"	/	/	/	/
L	/	/	0.242"	0.243"	0.247"	/	/	/
M	/	/	/	/	/	/	/	/
N	/	/	/	/	/	/	/	/
O	/	/	/	/	/	/	/	/
Aa	/	/	/	/	/	/	/	/
Bb	0.456"	0.454"	0.461"	0.463"	/	/	/	/
Cc	/	/	/	/	/	/	/	/

South view



East view



Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the and/or due to thickness of epoxy coating along the surface areas.

Larry Jernigan  
Technician Name

UT Level II  
Level/Certification

*Larry Jernigan*  
Signature

10-13-23  
Date

Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.

# ULTRASONIC EXAMINATION THICKNESS REPORT



ASME


S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616

Project #: 23050318	Report Date: 10-13-23
Project Name: Clearwater Natatorium UTT of structure framing	Procedure No. TR-NDT-UT-2
Project Location: Clearwater, FL	Material Type: <b>CS</b>
Client Name: McKim & Creed	Surface Condition: Painted

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)		
Manufacturer: Olympus		Manufacturer: Panmetric		Material: CS	Step #	Thickness
Model No.: DL38		Model No.: D790-SM		Serial No: 988285	1	0.100"
Serial No: 110194505		Serial No.: 754080			5	0.500"
Cable Type: N/A		Frequency: 5 MHz				
Cable Length: 48"		Size: 7.9mm				

Location: **D-10.3-T2-4** Center: **N/A**

	4"	8"	12"	16"	20"	24"	28"	32"
A	/	/	/	/	/	/	/	/
B	0.360"	0.360"	0.360"	0.360"	/	/	/	/
C	/	/	/	/	/	/	/	/
D	/	0.237"	/	/	/	/	/	/
E	0.232"	0.233"	0.232"	0.234"	/	/	/	/
F	/	/	/	/	/	/	/	/
G	/	/	/	/	/	/	/	/
H	0.232"	0.235"	0.235"	0.234"	/	/	/	/
I	/	0.233"	0.233"	0.233"	/	/	/	/
J	/	/	/	/	/	/	/	/
K	0.239"	0.238"	0.239"	0.239"	/	/	/	/
L	0.249"	0.239"	0.249"	0.246"	/	/	/	/
M	/	/	/	/	/	/	/	/
N	0.361"	0.363"	0.363"	0.359"	/	/	/	/
O	/	/	/	/	/	/	/	/
Aa	/	0.299"	0.298"	0.317"	0.322"	/	/	/
Bb	0.294"	0.294"	0.295"	0.315"	0.313"	/	/	/
Cc	/	/	/	/	/	/	/	/



East view

Aa  
Bb **16" 12" 8" 4"**  
Cc

Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the and/or due to thickness of epoxy coating along the surface areas.

Larry Jernigan  
Technician Name

UT Level II  
Level/Certification

Signature

10-13-23  
Date

Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.

# ULTRASONIC EXAMINATION THICKNESS REPORT



ASME

S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616


Project #: 23050318	Report Date: 10-13-23
Project Name: Clearwater Natatorium UTT of structure framing	Procedure No. TR-NDT-UT-2
Project Location: Clearwater, FL	Material Type: <b>CS</b>
Client Name: McKim & Creed	Surface Condition: Painted

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)		
Manufacturer: Olympus	Model No.: DL38	Manufacturer: Panmetric	Model No.: D790-SM	Material: CS	Step #	Thickness
Serial No.: 110194505	Cable Type: N/A	Serial No.: 754080	Frequency: 5 MHz	Serial No: 988285	1	0.100"
Cable Length: 48"		Size: 7.9mm			5	0.500"

Location: **D-10-T1-1** Center: **0.347"**

	4"	8"	12"	16"	20"	24"	28"	32"
A	/	/	/	/	/	/	/	/
B	0.348"	0.349"	0.349"	0.348"	/	/	/	/
C	0.352"	0.351"	0.350"	0.350"	/	/	/	/
D	/	/	/	/	/	/	/	/
E	0.347"	0.348"	0.348"	0.349"	/	/	/	/
F	0.349"	0.352"	0.352"	0.352"	/	/	/	/
G	/	0.228"	0.232"	0.231"	/	/	/	/
H	0.231"	0.231"	0.233"	0.232"	/	/	/	/
I	/	/	/	/	/	/	/	/
J	/	/	/	/	/	/	/	/
K	0.283"	0.234"	0.232"	0.233"	/	/	/	/
L	/	0.238"	0.235"	0.237"	/	/	/	/
M	/	/	/	/	/	/	/	/
N	/	/	/	/	/	/	/	/
O	/	/	/	/	/	/	/	/
Aa	/	/	/	/	/	/	/	/
Bb	/	/	/	/	/	/	/	/
Cc	/	/	/	/	/	/	/	/

South view



Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the and/or due to thickness of epoxy coating along the surface areas.

Larry Jernigan  
Technician Name

UT Level II  
Level/Certification

*Larry Jernigan*  
Signature

10-13-23  
Date

Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.

# ULTRASONIC EXAMINATION THICKNESS REPORT



ASME


S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616

Project #: 23050318	Report Date: 10-13-23
Project Name: Clearwater Natatorium UTT of structure framing	Procedure No. TR-NDT-UT-2
Project Location: Clearwater, FL	Material Type: <b>CS</b>
Client Name: McKim & Creed	Surface Condition: Painted

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)		
Manufacturer: Olympus	Model No.: DL38	Manufacturer: Panmetric	Model No.: D790-SM	Material: CS	Step #: 1	Thickness: 0.100"
Serial No.: 110194505	Cable Type: N/A	Serial No.: 754080	Frequency: 5 MHz	Serial No: 988285	5	0.500"
Cable Length: 48"		Size: 7.9mm				

Location: **D-10-T1-2**      Center: **0.347"**

	4"	8"	12"	16"	20"	24"	28"	32"
A	/	/	/	/	/	/	/	/
B	0.348"	0.348"	0.349"	0.348"	/	/	/	/
C	0.351"	0.351"	0.351"	0.352"	/	/	/	/
D	0.349"	0.349"	0.350"	0.350"	/	/	/	/
E	0.346"	0.347"	0.343"	0.348"	/	/	/	/
F	/	/	/	/	/	/	/	/
G	/	0.237"	0.236"	0.234"	/	/	/	/
H	0.234"	0.236"	0.234"	0.234"	/	/	/	/
I	/	/	/	/	/	/	/	/
J	/	0.235"	0.235"	0.235"	/	/	/	/
K	0.230"	0.231"	0.232"	0.232"	/	/	/	/
L	/	0.242"	0.243"	0.243"	/	/	/	/
M	/	/	/	/	/	/	/	/
N	0.231"	0.218"	0.234"	0.232"	/	/	/	/
O	/	0.237"	0.236"	0.235"	/	/	/	/
Aa	/	/	/	/	/	/	/	/
Bb	/	/	/	/	/	/	/	/
Cc	/	/	/	/	/	/	/	/



*Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the and/or due to thickness of epoxy coating along the surface areas.*

Larry Jernigan  
Technician Name

UT Level II  
Level/Certification

Signature

10-13-23  
Date

*Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.*

# ULTRASONIC EXAMINATION THICKNESS REPORT



ASME


S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616

Project #: 23050318	Report Date: 10-13-23
Project Name: Clearwater Natatorium UTT of structure framing	Procedure No. TR-NDT-UT-2
Project Location: Clearwater, FL	Material Type: <b>CS</b>
Client Name: McKim & Creed	Surface Condition: Painted

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)		
Manufacturer: Olympus		Manufacturer: Panmetric		Material: CS	Step #	Thickness
Model No.: DL38		Model No.: D790-SM		Serial No: 988285	1	0.100"
Serial No: 110194505		Serial No.: 754080			5	0.500"
Cable Type: N/A		Frequency: 5 MHz				
Cable Length: 48"		Size: 7.9mm				

Location: **D-10-T1-3** Center: **0.347"**

	4"	8"	12"	16"	20"	24"	28"	32"
A	/	/	/	/	/	/	/	/
B	0.347"	0.347"	0.347"	0.347"	/	/	/	/
C	0.348"	0.350"	0.352"	0.350"	/	/	/	/
D	0.349"	0.350"	0.350"	0.351"	/	/	/	/
E	0.348"	0.348"	0.349"	0.349"	/	/	/	/
F	/	/	/	/	/	/	/	/
G	/	0.231"	0.230"	0.230"	/	/	/	/
H	0.224"	0.232"	0.235"	0.234"	/	/	/	/
I	/	/	/	/	/	/	/	/
J	/	0.237"	0.236"	0.236"	/	/	/	/
K	0.232"	0.234"	0.234"	0.235"	/	/	/	/
L	/	/	/	/	/	/	/	/
M	/	/	/	/	/	/	/	/
N	0.217"	0.234"	0.234"	0.232"	/	/	/	/
O	/	0.245"	0.244"	0.239"	/	/	/	/
Aa	/	/	/	/	/	/	/	/
Bb	/	/	/	/	/	/	/	/
Cc	/	/	/	/	/	/	/	/



Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the and/or due to thickness of epoxy coating along the surface areas.

Larry Jernigan  
Technician Name

UT Level II  
Level/Certification

*Larry Jernigan*  
Signature

10-13-23  
Date

Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.

# ULTRASONIC EXAMINATION THICKNESS REPORT



ASME


S&ME, Inc. Raleigh: 3201 Spring Forest Road, Raleigh, NC 27616

Project #: 23050318	Report Date: 10-13-23
Project Name: Clearwater Natatorium UTT of structure framing	Procedure No. TR-NDT-UT-2
Project Location: Clearwater, FL	Material Type: <b>CS</b>
Client Name: McKim & Creed	Surface Condition: Painted

Ultrasonic Flaw Detector		Search Unit(s)		Calibration Standard(s)		
Manufacturer: Olympus	Model No.: DL38	Manufacturer: Panmetric	Model No.: D790-SM	Material: CS	Step #: 1	Thickness: 0.100"
Serial No.: 110194505	Cable Type: N/A	Serial No.: 754080	Frequency: 5 MHz	Serial No: 988285	5	0.500"
Cable Length: 48"		Size: 7.9mm				

Location: **D-10-T1-4** Center: **(C)0.352"**

	4"	8"	12"	16"	20"	24"	28"	32"
A	/	/	/	/	/	/	/	/
B	/	0.348"	0.349"	0.349"	0.349"	/	/	/
C	0.355"	0.352"	0.352"	0.352"	/	/	/	/
D	0.352"	0.357"	0.352"	0.352"	0.352"	/	/	/
E	0.347"	0.347"	0.348"	0.348"	/	/	/	/
F	/	/	/	/	/	/	/	/
G	/	0.245"	0.243"	0.244"	/	/	/	/
H	0.240"	0.241"	0.241"	0.241"	/	/	/	/
I	/	/	/	/	/	/	/	/
J	/	/	0.235"	0.235"	/	/	/	/
K	0.233"	0.233"	0.234"	0.234"	/	/	/	/
L	/	/	0.235"	/	/	/	/	/
M	/	/	/	/	/	/	/	/
N	0.233"	0.233"	0.232"	0.232"	/	/	/	/
O	/	0.241"	0.241"	0.240"	/	/	/	/
Aa	0.292"	0.294"	0.287"	0.309"	/	/	/	/
Bb	0.295"	0.294"	0.309"	0.306"	/	/	/	/
Cc	0.282"	0.282"	0.304"	0.307"	/	/	/	/



Notes: Some faces of the HSS members could not have thicknesses retrieved due to window framing covering the and/or due to thickness of epoxy coating along the surface areas.

Larry Jernigan  
Technician Name

UT Level II  
Level/Certification

*Larry Jernigan*  
Signature

10-13-23  
Date

Disclaimer: The presence of S&ME at the project site shall not be construed as an acceptance or approval of activities at the site. S&ME is at the project site to perform specific services and has certain responsibilities which are limited to those specifically authorized in our agreement with our client. In no event shall S&ME be responsible for the safety or means and methods of other parties at the project site. The information presented in this field report has not been reviewed by an engineer and is to be considered preliminary.


## Appendix II- **Photolog**



Date: 10-11-23

Photographer: Larry Jernigan

<b>1</b>	<b>Location / Orientation</b>	West wall
	<b>Remarks</b>	



Date: 10-11-23

Photographer: Larry Jernigan


<b>2</b>	<b>Location / Orientation</b>	North wall
	<b>Remarks</b>	



Date: 10-11-23

Photographer: Larry Jernigan


<b>3</b>	<b>Location / Orientation</b>	East Wall
	<b>Remarks</b>	



Date: 10-9-23

Photographer: Larry Jernigan


<b>4</b>	<b>Location / Orientation</b>	B-1 corner
	<b>Remarks</b>	



Date: 10-9-23

Photographer: Larry Jernigan

<b>5</b>	<b>Location / Orientation</b>	B-1-T2-1
	<b>Remarks</b>	



Date: 10-9-23

Photographer: Larry Jernigan


<b>6</b>	<b>Location / Orientation</b>	D-1-T2-1
	<b>Remarks</b>	



Date: 10-9-23

Photographer: Larry Jernigan

<b>7</b>	<b>Location / Orientation</b>	D-1-T2-2
	<b>Remarks</b>	



Date: 10-9-23

Photographer: Larry Jernigan

<b>8</b>	<b>Location / Orientation</b>	D-1-T2-3
	<b>Remarks</b>	



		Photographer: Larry Jernigan	Date: 10-9-23
<b>9</b>	<b>Location / Orientation</b>	D-1-T2-3	
	<b>Remarks</b>	Hole	
		Photographer: Larry Jernigan	Date: 10-12-23
<b>10</b>	<b>Location / Orientation</b>	B-9.3-T1-1	
	<b>Remarks</b>		



Date: 10-12-23

Photographer: Larry Jernigan

<b>11</b>	<b>Location / Orientation</b>	B-10_10.3 truss joints
	<b>Remarks</b>	



Date: 10-12-23

Photographer: Larry Jernigan

<b>12</b>	<b>Location / Orientation</b>	B-10_10.3 truss joints
	<b>Remarks</b>	



## **Appendix III– Structural Frame Repair Drawings**

# SHEET INDEX

SHEET #	SHEET DESCRIPTION
GENERAL	COVERSHEET
S0.00	GENERAL NOTES, DESIGN LOADS, DESIGN CRITERIA & LEGEND
S1.00	EXIST BLDG. A ROOF & EXTERIOR WALL FRAMING LAYOUT
S1.01	EXIST. BLDG. A ROOF & EXTR. WALL FRMG. ELEVATIONS (SHT. 1 OF 2)
S1.02	EXIST. BLDG. A ROOF & EXTR. WALL FRMG. ELEVATIONS (SHT. 2 OF 2)
S1.03	EXIST. BLDG. A TRUSS CONDITIONS & REPAIRS (SHT. 1 OF 11)
S1.04	EXIST. BLDG. A TRUSS CONDITIONS & REPAIRS (SHT. 2 OF 11)
S1.05	EXIST. BLDG. A TRUSS CONDITIONS & REPAIRS (SHT. 3 OF 11)
S1.06	EXIST. BLDG. A TRUSS CONDITIONS & REPAIRS (SHT. 4 OF 11)
S1.07	EXIST. BLDG. A TRUSS CONDITIONS & REPAIRS (SHT. 5 OF 11)
S1.08	EXIST. BLDG. A TRUSS CONDITIONS & REPAIRS (SHT. 6 OF 11)
S1.09	EXIST. BLDG. A TRUSS CONDITIONS & REPAIRS (SHT. 7 OF 11)
S1.10	EXIST. BLDG. A TRUSS CONDITIONS & REPAIRS (SHT. 8 OF 11)
S1.11	EXIST. BLDG. A TRUSS CONDITIONS & REPAIRS (SHT. 9 OF 11)
S1.12	EXIST. BLDG. A TRUSS CONDITIONS & REPAIRS (SHT. 10 OF 11)
S1.13	EXIST. BLDG. A TRUSS CONDITIONS & REPAIRS (SHT. 11 OF 11)



# LONG CENTER NATATORIUM STRUCTURAL FRAME REPAIRS



Project Location

## CITY OFFICIALS

- |                  |               |
|------------------|---------------|
| Frank Hibbard    | Mayor         |
| Mark Bunker      | Councilmember |
| Kathleen Beckman | Councilmember |
| David Allbritton | Councilmember |
| Lina Teixeira    | Councilmember |
| Jon Jennings     | City Manager  |

Tara L. Kivett, P.E.  
City Engineer

Approved For  
Construction


CITY ENGINEER Tara L. Kivett, P.E. #86611

Date Approved

**FINAL DESIGN  
RELEASED FOR BID**

City Project No. 21-0026-PR  
City Plan Set No. 2021017





**FRAMING PLAN NOTES:**

- TRUE NORTH VARIES FROM PLAN NORTH INDICATED. COORDINATE W/ CIVIL & SITE RECORD DWG.'s AS REQUIRED FOR THE DIRECTION OF TRUE NORTH
- REFERENCE ELEVATION FOR BUILDING "A" OF THE LONG CENTER FACILITY IS THE POOL DECK SLAB T.O. CONC. "H.P." EL 0'-0" = EL 43'-0" (43.00'). CONTRACTOR SHALL VERIFY THE CORRESPONDING N.A.V.D. INDICATED AS REQUIRED. REFERENCE CIVIL AND / OR SITE RECORD DRAWINGS FOR ADDITIONAL INFORMATION.
- GRADE ELEVATION AROUND THIS STRUCTURE IS 42.50'(±)'. REFERENCE CIVIL AND / OR SITE RECORD DRAWINGS FOR ADDITIONAL INFORMATION.

CTD. ...

- EXISTING RECORD DRAWING'S REVIEWED INDICATED & SITE VISITS CONFIRMED THE EXISTING TRUSS ASSEMBLIES CONSTRUCTED OF HSS 6x6 STRUCTURAL STEEL & NOTE THE FOLLOWING:
  - DWG.'s INDICATED HSS's ARE EITHER  $\frac{3}{16}$ " OR  $\frac{1}{2}$ " THICK SECTIONS.
  - BASED UPON YEAR CONSTRUCTED IT IS ESTIMATED STEEL SECTIONS IN CONFORMANCE W/ ASTM A500.

- REFERENCE DWG. S0.00 FOR ADDITIONAL GENERAL NOTES, MATERIAL SPECIFICATIONS & REQUIREMENTS, DESIGN CRITERIA AND LEGEND.



NORTH  
(PLAN)  
[REF. NOTE 1]

**1 - PLAN - EXIST. BUILDING "A" ROOF & EXTERIOR WALL FRAMING LAYOUT**

SCALE: 1/8" = 1'-0"

REV. NO.	DESCRIPTION	DATE
D	FINAL DESIGN - RELEASED FOR BID	23 MAY 2022
C	FINAL DESIGN - FINAL REVIEW NOT FOR CONSTRUCTION	09 MAY 2022
B	100% DESIGN - NOT FOR CONSTRUCTION	18 MAR 2022
A	90% DESIGN - NOT FOR CONSTRUCTION	02 MAR 2022

WILLIAM F. BAND, P.E.  
No. 67836



1365 Hamlet Avenue  
Clearwater, Florida 33756-3331  
Phone: (727) 442-7196, Fax: (727) 461-3827

CA Lic. No. 29588  
www.mckimcreed.com



**LONG CENTER NATATORIUM  
STRUCTURAL FRAME REPAIRS**

**STRUCTURAL  
EXIST BLDG. A ROOF & EXTERIOR WALL  
FRAMING LAYOUT**



PROJ. START DATE:	2021.NOV
MCE PROJ. #	00992-0261
DRAWN	WFB
DESIGNED	WFB
CHECKED	WFB / AEA
PROJ. MGR.	AAM

SCALE	HORIZONTAL: AS NOTED	VERTICAL: NA	<b>\$1.00</b>
DRAWING NUMBER			
REVISION	D		

STATUS: **FINAL DESIGN SUBMITTAL  
RELEASED FOR BID**


**NOTES:**

- REGARDING THE EXISTING SLAB-ON-GRADE FLOOR CONSTRUCTION RECORD DRAWING'S REVIEWED INDICATED THE FOLLOWING:
  - SLAB CONSTRUCTED 4" THK. (MIN.).
  - SLAB REINFORCED W/ 6x6 - W1.4 x W1.4 WELDED WIRE FABRIC @ MID-DEPTH OF THE SLAB.
- RECORD DRAWINGS REVIEWED INDICATED EXISTING C.I.P. REINFORCED CONCRETE PIER ASSEMBLIES TRANSFER LOADS FROM THE EXISTING VERTICAL TRUSS COLUMNS TO EXISTING SHALLOW FOUNDATION C.I.P. REINFORCED CONCRETE FOOTINGS. REGARDING THE EXISTING PIER ASSEMBLIES CONSTRUCTION NOTE THE FOLLOWING:
  - PIER DIM.'s = 1'-4" SQUARE.
  - PIER REINF. = (8) #7 VERT. BARS INSTALLED (3) EA. FACE & #3 TIES SPA. @ 1'-0" O.C..
- REGARDING THE EXISTING MASONRY KNEE WALL AROUND THE NORTH, SOUTH & WEST SIDE EXTERIOR WALLS. RECORD DRAWINGS REVIEWED INDICATED THE FOLLOWING:
  - EXTERIOR SIDE FINISHES = 4" THK. SPLIT-FACE TYPE CMU.
  - INTERIOR SIDE FINISHES = 4" THK. SMOOTH FACED TYPE CMU.
  - TOP FINISHES = 4" THK. SOLID CMU COPING BLOCK.
  - WALL THK. = 1'-8" THK. ASSEMBLY CONSISTING OF (1) 12" THK. INTERIOR COURSE BLOCK, (1) INTERIOR COURSE BLOCK & (1) EXTERIOR COURSE BLOCK AS PREVIOUSLY NOTED.
  - MASONRY THICKNESS DIM.'s INDICATED ARE NOMINAL.
- EXISTING ROOF DECK & ROOFING ASSEMBLIES NOT SHOWN FOR CLARITY. FIELD COORDINATE EXISTING MATERIALS AND DIMENSIONAL INFORMATION AS REQUIRED.
- REGARDING THE EXISTING STRUCTURAL STEEL TRUSS ASSEMBLIES RECORD DWG.'s REVIEWED INDICATED THE FOLLOWING:
  - VERTICAL COLUMN SECTIONS @ COL. LINES "B" & "D" = HSS 6x6x $\frac{5}{8}$ .
  - HORIZONTAL BEAM SECTIONS BTWN. TRUSSES = HSS 6x6x $\frac{5}{8}$ .
  - DIAGONAL X-BRACE SECTIONS = HSS 6x6x $\frac{5}{8}$ .
  - ROOF TRUSS CHORD SECTIONS = HSS 6x6x $\frac{5}{8}$ .
- REGARDING THE EXISTING STRUCTURAL STEEL SECONDARY FRAMING SPANNING BETWEEN THE TRUSSES AND THE BUILDING COL.'s AT THE EAST AND WEST WALLS, RECORD DRAWINGS REVIEWED INDICATED THE FOLLOWING:
  - HSS BEAM SECTIONS BETWEEN THE TRUSS PAIRINGS = HSS 6x6x $\frac{5}{8}$ .
  - HSS BEAM SECTIONS BETWEEN THE TRUSSES / COLUMNS = HSS 6x4x $\frac{5}{8}$  (LLH).
- "X" SYMBOL ON STEEL FRAMING ELEVATIONS INDICATES THE HEIGHT LEVEL IN THE REPAIR MARK #'s TO BE COORDINATED W/ THE REPAIR PROCEDURES ON DWG.'s S-1.03 TO S1.13.
- REGARDING THE STRUCTURAL STEEL W12 COL. ASSEMBLIES RECORD DWG.'s DID NOT APPEAR TO INDICATE A SEPARATE STEEL SECTION CONNECTING TO THE OF OF THE EXTR. FLANGE OF THE W12. SITE REVIEWS APPEARED TO INDICATE THIS SECTION MAY BE AN HSS. FIELD COORDINATE AS REQUIRED FOR REPAIRING STEEL SECTIONS AT THESE COLUMN LOCATIONS.
- REFERENCE DWG. S0.00 FOR ADDITIONAL GENERAL NOTES, MATERIAL SPECIFICATIONS & REQUIREMENTS, DESIGN CRITERIA AND LEGEND.



**1 - ELEVATION - TRUSS "T1" & "T2" SUPPT. FRMG. @ COL. LINE "D"**  
SCALE: 3/16" = 1'-0"

**2 - ELEVATION - TRUSS "T1" & "T2" SUPPT. FRMG. @ COL. LINE "D"**  
SCALE: 3/16" = 1'-0"



**3 - ELEVATION - TRUSS "T2" SUPPT. FRMG. @ COL. LINE "1"**  
SCALE: 3/16" = 1'-0"

REV. NO.	DESCRIPTION	DATE
D	FINAL DESIGN - RELEASED FOR BID	23 MAY 2022
C	FINAL DESIGN - FINAL REVIEW NOT FOR CONSTRUCTION	09 MAY 2022
B	100% DESIGN - NOT FOR CONSTRUCTION	18 MAR 2022
A	90% DESIGN - NOT FOR CONSTRUCTION	02 MAR 2022

WILLIAM F. BAND, P.E.  
No. 67836

FOR REPAIRS TO EXIST. FRMG.  
REF. DETAIL 1-S1.10

FOR REPAIRS TO EXIST. FRMG.  
REF. DETAIL 2-S1.10

FOR REPAIRS TO EXIST. FRMG.  
REF. DETAIL 3-S1.10

FOR REPAIRS TO EXIST. FRMG.  
REF. DETAIL 1-S1.11

FOR REPAIRS TO EXIST. FRMG.  
REF. DETAIL 2-S1.11

FOR REPAIRS TO EXIST. FRMG.  
REF. DETAIL 3-S1.11

**LONG CENTER NATATORIUM  
STRUCTURAL FRAME REPAIRS**

STRUCTURAL

**EXIST. BLDG. A ROOF & EXTR. WALL  
FRMG. ELEVATIONS (SHT. 1 OF 2)**

**MCKIM & CREED**


1365 Hamlet Avenue  
Clearwater, Florida 33756-3331  
Phone: (727) 442-7196, Fax: (727) 461-3827

CA Lic. No. 29588  
www.mckimcreed.com


**CLEARWATER**  
BRIGHT AND BEAUTIFUL · BAY TO BEACH

PROJ. START DATE: 2021.NOV	SCALE	<b>\$1.01</b>
MCE PROJ. # 00992-0261	HORIZONTAL: AS NOTED	
DRAWN WFB	VERTICAL: NA	D
DESIGNED WFB		REVISION
CHECKED WFB / AEA		
PROJ. MGR. AAM		

STATUS: **FINAL DESIGN SUBMITTAL  
RELEASED FOR BID**



1 - ELEVATION - TRUSS "T2" SUPPT. FRMG. @ COL. LINE "10.3"  
SCALE: 3/16" = 1'-0"




2 - ELEVATION - TRUSS "T1" & TRUSS "T2" SUPPT. FRMG. @ COL. LINE "B"  
SCALE: 1/8" = 1'-0"

- NOTES:**
- FOR ELEVATION CALL-OUTS REFERENCING NOTES COORDINATE w/ THE DRAWING NOTES ON DRAWING S-1.01 FOR INFORMATION.
  - REFERENCE DWG. S0.00 FOR ADDITIONAL GENERAL NOTES, MATERIAL SPECIFICATIONS & REQUIREMENTS, DESIGN CRITERIA AND LEGEND.

REV. NO.	DESCRIPTION	DATE
D	FINAL DESIGN - RELEASED FOR BID	23 MAY 2022
C	FINAL DESIGN - FINAL REVIEW NOT FOR CONSTRUCTION	09 MAY 2022
B	100% DESIGN - NOT FOR CONSTRUCTION	18 MAR 2022
A	90% DESIGN - NOT FOR CONSTRUCTION	02 MAR 2022

REVISIONS

WILLIAM F. BAND, P.E.  
No. 67836




**MCKIM & CREED**  
1365 Hamlet Avenue  
Clearwater, Florida 33756-3331  
Phone: (727) 442-7196, Fax: (727) 461-3827  
CA Lic. No. 29588  
www.mckimcreed.com




**LONG CENTER NATATORIUM  
STRUCTURAL FRAME REPAIRS**

STRUCTURAL  
**EXIST. BLDG. A ROOF & EXTR. WALL  
FRMG. ELEVATIONS (SHT. 2 OF 2)**


PROJ. START DATE: 2021.NOV	SCALE	<b>\$1.02</b>
MCE PROJ. # 00992-0261	HORIZONTAL: AS NOTED	
DRAWN: WFB	DESIGNED: WFB	DRAWING NUMBER
CHECKED: WFB/AEA	PROJ. MGR: AAM	REVISION
STATUS: FINAL DESIGN SUBMITTAL		D
RELEASED FOR BID		




1 - DETAIL - TRUSS "T1" & "T2" @ COL. LINE "D"  
SCALE: 1/4" = 1'-0"




2 - DETAIL - D-1.3-T1-4 REPAIR  
SCALE: 3/4" = 1'-0"




3 - DETAIL - D-1-T2-4 REPAIR  
SCALE: 3/4" = 1'-0"




4 - DETAIL - D-1-T2-3 REPAIR  
SCALE: 3/4" = 1'-0"



5 - DETAIL - D-1-T2-2 REPAIR  
SCALE: 3/4" = 1'-0"



6 - DETAIL - D-1.3-T1-1 REPAIR  
SCALE: 3/4" = 1'-0"



7 - DETAIL - D-1-T2-1 REPAIR  
SCALE: 3/4" = 1'-0"

**NOTES:**

- IN GENERAL REPAIR OF THE EXISTING STRUCTURAL STEEL TRUSSES AND THE SECONDARY EXTERIOR WALL BEAMS INVOLVES REPAIRS TO INTERIOR VERTICAL, HORIZONTAL & DIAGONAL SURFACES OF THE TRUSSES, COLUMNS, CONNECTION PLATES OR ANGLES, BASE PLATES AND ANCHOR BOLTS AND HARDWARE U.N.O.. IN GENERAL REPAIR WORK INCLUDES THE FOLLOWING:
  - REMOVING EXISTING COATINGS TO BARE METAL.
  - REMOVING SURFACE RUST OR THRU WALL RUST AND CLEANING SURFACES TO BARE METAL.
  - PREPARING BARE METAL SURFACES TO SSPC-SP6 'COMMERCIAL BLAST CLEANING' CRITERIA.
  - WELDING NEW STEEL PLATE OR ANGLE SECTIONS TO THE EXISTING STEEL SECTIONS. REGARDING FIELD WELDING AND PREPARATION TO SSPC-SP6 CRITERIA, THE MAXIMUM BASE METAL TEMPERATURE AT DEMARCATION BETWEEN BRIGHT METAL AND THE EXISTING COATINGS TO BE CONFIRMED w/ THE USE OF 182° F TEMPILSTIK'S BETWEEN WELD PASSES.
  - INSTALL NEW COATING SYSTEM ON THE REPAIRED AREAS TO MATCH
- CODE FOR UTILIZING TRUSS CONNECTION LOCATIONS MARK NUMBERS AS FOLLOWS:
  - COL. ID E/W DIRECTION - COL. ID N/S DIRECTION - TRUSS TYPE - ELEVATION ABOVE BASE PLATE.
  - COORDINATE w/ TRUSS ELEVATIONS DWG.'S S-1.01 & S-1.02 FOR HEIGHT CODES 0 TO 5.
  - COORDINATE w/ THE 'TRUSS CONN. LOCATION MK. # LEGEND EXAMPLE' THIS DWG. FOR ADDITIONAL INFORMATION.

**NOTES CTD. ...**

- REGARDING VERIFYING CONDITION OF EXISTING STEEL, NOTE THE FOLLOWING:
  - DURING SITE VISITS NOT ALL AREAS OF THE EXISTING FACILITY COULD BE EASILY ACCESSED SAFELY w/ THE LIFT.
  - CONTRACTOR TO VERIFY IF EXISTING TOP CHORDS EXHIBITING SIGNS OF RUST, CORROSION OR LOSS OF COATING.
  - NOTIFY ENGINEER OF AREAS THAT ARE NOT CURRENTLY INDICATED BUT DISPLAY RUST, CORROSION, AND / OR COATING PEELING OR LOSS FOR DIRECTIONS HOW TO PROCEED.
- COORDINATE w/ DETAILS REFERENCED FOR ANGLE / PLATE LAYOUT DIM.'S & WELD REQ.'S, U.N.O..
- IN GENERAL REPAIR THE EXISTING HOLE BY PREPARING THE HOLE EDGES TO NON-CORRODED STEEL, FILLING THE INTERNAL VOLUME OF THE HSS w/ GROUT & INSTALLING STEEL PLATE REPAIRS. NOTE THE FOLLOWING:
  - REMOVE ALL LOOSE SURFACE RUST & CORROSION FROM THE HSS BEAM.
  - ENLARGE EXISTING HOLE BY GRINDING EXIST. HSS WALL BACK TO FULL THK. OF THE HSS WALL.
  - CUT CARDBOARD GROUT DAM SECTIONS TO THE INTERIOR PROFILE OF THE HSS BEAMS & COLUMN RESPECTIVELY. USE THE CARDBOARD GROUT DAMS w/ EXPANSION FOAM TO SEAL THE INTERNAL VOLUME OF THE BEAMS & COLUMN TO BE GROUTED. POSITION DAMS TO 4" (MIN.) FROM THE EDGE OF THE HOLE. FILL THE INTERNAL VOLUME BETWEEN THE DAMS w/ NON-SHRINK GROUT, CURE & FINISH SMOOTH TO THE O/F OF THE HSS STEEL WALLS.
  - INSTALL THE PLATE REPAIRS INDICATED.

**NOTES CTD. ...**

- PLATE OR ANGLE ASSEMBLIES NOT REQUIRED PROVIDED REMOVAL OF THE EXISTING COATING / CORROSION & SURFACE PREP DOES NOT YIELD UNEXPECTED RESULTS & REPAIRS CANNOT BE INSTALLED AS NOTED.
- 'X' SYMBOL ON DRAWING INDICATES MARK NO. FOR BASE PLATE REPAIRS. REFERENCE DRAWING S-1.09 'KEY NOTES - COLUMN BASE PLATE REPAIRS' AND APPLICABLE SECTIONS & DETAILS AS REQUIRED.
- REFERENCE DWG. S0.00 FOR ADDITIONAL GENERAL NOTES, MATERIAL SPECIFICATIONS & REQUIREMENTS, DESIGN CRITERIA AND LEGEND.

**TRUSS CONN. LOCATION MK. # LEGEND EXAMPLE:**

TRUSS CONNECTION LOCATION MK. # = D-1.3-T1-4


D = EAST / WEST ORIENTED COLUMN LINE DIRECTION ON PLAN 1-S1.00.  
 1.3 = NORTH / SOUTH ORIENTED COLUMN LINE DIRECTION ON PLAN 1-S1.00.  
 T1 = EXISTING TRUSS TYPE T1 OR T2 AS NOTED ON PLAN 1-S1.00 & TRUSS DETAIL ELEVATIONS.  
 4 = ELEVATION ABOVE THE EXISTING SLAB-ON-GRADE AS INDICATED w/ 'X' SYMBOL ON DWG.'S S1.01 & S1.02.  
 S / N = SOUTH / NORTH SIDE OF THE EXISTING COLUMN.

ESTIMATED BILL OF MATERIALS ... S1.03				
ITEM #	COMPONENT	DESCRIPTION	QTY.	NOTES
01	ANGLE SECTION	L5x5x1/2 x 41/2	2	
02	BENT PLATE	1'-3"x9"x1/2 x 41/2	1	
03	BENT PLATE	0'-9"x5"x1/2 x 41/2	2	
04	WING PLATE	0'-4"x0'-3"x1/2	7	
05	FILLET WELD	3/16" EFF. THROAT	225'	
06	BUTT WELD	COMPLETE PEN.	20'	
07	FLARE BEVEL WELD	PARTIAL PEN.	30'	

REV. NO.	DESCRIPTION	DATE
D	FINAL DESIGN - RELEASED FOR BID	23 MAY 2022
C	FINAL DESIGN - FINAL REVIEW NOT FOR CONSTRUCTION	09 MAY 2022
B	100% DESIGN - NOT FOR CONSTRUCTION	18 MAR 2022
A	90% DESIGN - NOT FOR CONSTRUCTION	02 MAR 2022

REVISIONS

WILLIAM F. BAND, P.E.  
No. 67836



**MCKIM & CREED**  
 1365 Hamlet Avenue  
 Clearwater, Florida 33756-3331  
 Phone: (727) 442-7196, Fax: (727) 461-3827  
 CA Lic. No. 29588  
 www.mckimcreed.com



**LONG CENTER NATATORIUM  
 STRUCTURAL FRAME REPAIRS**

STRUCTURAL

**EXIST. BLDG. A TRUSS CONDITIONS &  
 REPAIRS (SHT. 1 OF 11)**



PROJ. START DATE: 2021.NOV  
 MCE PROJ. # 00992-0261  
 DRAWN: WFB  
 DESIGNED: WFB  
 CHECKED: WFB / AEA  
 PROJ. MGR: AAM

SCALE: HORIZONTAL: AS NOTED, VERTICAL: NA

**\$1.03**  
DRAWING NUMBER  
D  
REVISION







STATUS: FINAL DESIGN SUBMITTAL  
RELEASED FOR BID

ESTIMATED BILL OF MATERIALS ... S1.04				
ITEM #	COMPONENT	DESCRIPTION	QTY.	NOTES
01	ANGLE SECTION	L5x5x $\frac{1}{2}$ x 4 $\frac{1}{2}$	2	
02	PLATE	0'-8 $\frac{1}{2}$ "x2 $\frac{1}{2}$ "x $\frac{1}{2}$ "	7	
03	BENT PLATE	0'-9"x5"x $\frac{1}{2}$ " x 4 $\frac{1}{2}$ "	1	
04	BENT PLATE	0'-6"x2 $\frac{1}{2}$ "x $\frac{1}{2}$ " x 2 $\frac{1}{2}$ "	1	
05	BENT PLATE	0'-6"x2 $\frac{1}{2}$ "x $\frac{1}{2}$ " x 5 $\frac{1}{2}$ "	6	
06	WING PLATE	0'-4"x3 $\frac{1}{2}$ "x $\frac{1}{2}$ "	6	
07	WING PLATE	0'-4"x1 $\frac{1}{2}$ "x $\frac{1}{2}$ "	10	
08	FILLET WELD	$\frac{3}{8}$ " EFF. THROAT	335'	
09	FILLET WELD	$\frac{1}{4}$ " EFF. THROAT	15'	
10	FILLET WELD	$\frac{3}{8}$ " EFF. THROAT	20'	
11	BUTT WELD	COMPLETE PEN.	40'	
12	FLARE BEVEL WELD	PARTIAL PEN.	80'	



1 - DETAIL - TRUSS "T1" & "T2" @ COL. LINE "B"  
SCALE: 1/4" = 1'-0"

2 - DETAIL - TRUSS "T1" @ COL. LINE "B"  
SCALE: 1/4" = 1'-0"



3 - DETAIL - B-1-T2-5 REPAIR  
SCALE: 3/4" = 1'-0"

4 - DETAIL - B-1.3-T1-4 REPAIR  
SCALE: 3/4" = 1'-0"

5 - DETAIL - B-1.3-T1-3 REPAIR  
SCALE: 3/4" = 1'-0"

6 - DETAIL - B-1-T2-3 REPAIR  
SCALE: 3/4" = 1'-0"

7 - DETAIL - B-1-T2-2 REPAIR  
SCALE: 3/4" = 1'-0"

8 - DETAIL - B-1-T2-1 REPAIR  
SCALE: 3/4" = 1'-0"

**NOTES:**

- IN GENERAL REPAIR OF THE EXISTING STRUCTURAL STEEL TRUSSES AND THE SECONDARY EXTERIOR WALL BEAMS INVOLVES REPAIRS TO INTERIOR VERTICAL, HORIZONTAL & DIAGONAL SURFACES OF THE TRUSSES, COLUMNS, CONNECTION PLATES OR ANGLES, BASE PLATES AND ANCHOR BOLTS AND HARDWARE U.N.O. IN GENERAL REPAIR WORK INCLUDES THE FOLLOWING:
  - REMOVING EXISTING COATINGS TO BARE METAL.
  - REMOVING SURFACE RUST OR THRU WALL RUST AND CLEANING SURFACES TO BARE METAL.
  - PREPARING BARE METAL SURFACES TO SSPC-SP6 'COMMERCIAL BLAST CLEANING' CRITERIA.
  - WELDING NEW STEEL PLATE OR ANGLE SECTIONS TO THE EXISTING STEEL SECTIONS.
 REGARDING FIELD WELDING AND PREPARATION TO SSPC-SP6 CRITERIA, THE MAXIMUM BASE METAL TEMPERATURE AT DEMARCATION BETWEEN BRIGHT METAL AND THE EXISTING COATINGS TO BE CONFIRMED w/ THE USE OF 182° F TEMPISTIK'S BETWEEN WELD PASSES.
- INSTALL NEW COATING SYSTEM ON THE REPAIRED AREAS TO MATCH
- CODE FOR UTILIZING TRUSS CONNECTION LOCATIONS MARK NUMBERS AS FOLLOWS:
  - COL. ID, EW DIRECTION - COL. ID N/S DIRECTION - TRUSS TYPE - ELEVATION ABOVE BASE PLATE.
  - COORDINATE w/ TRUSS ELEVATIONS DWG.'S S-1.01 & S-1.02 FOR HEIGHT CODES 0 TO 5.
  - COORDINATE w/ THE 'TRUSS CONN. LOCATION MK. # LEGEND EXAMPLE' DWG. S1.03 FOR ADDITIONAL INFORMATION.

**NOTES CTD. ...**

- REGARDING VERIFYING CONDITION OF EXISTING STEEL, NOTE THE FOLLOWING:
  - DURING SITE VISITS NOT ALL AREAS OF THE EXISTING FACILITY COULD BE EASILY ACCESSED SAFELY w/ THE LIFT.
  - CONTRACTOR TO VERIFY IF EXISTING TOP CHORDS EXHIBITING SIGNS OF RUST, CORROSION OR LOSS OF COATING.
  - NOTIFY ENGINEER OF AREAS THAT ARE NOT CURRENTLY INDICATED BUT DISPLAY RUST, CORROSION, AND / OR COATING PEELING OR LOSS FOR DIRECTIONS HOW TO PROCEED.
- COORDINATE w/ DETAILS REFERENCED FOR ANGLE / PLATE LAYOUT DIM.'S & WELD REQ.'S, U.N.O.
- IF COATING REMOVAL YIELDS SURFACE PITTING GRIND SMOOTH & TO SURFACE PREP. REQ.'S.
- PLATE OR ANGLE ASSEMBLIES NOT REQUIRED PROVIDED REMOVAL OF THE EXISTING COATING / CORROSION & SURFACE PREP DOES NOT YIELD UNEXPECTED RESULTS & REPAIRS CANNOT BE INSTALLED AS NOTED.
- REMOVE & REINSTALL EXIST. WINDOW GLASS & FRAME TO REPAIR IF REQ'D.
- REFERENCE DWG. S1.09 FOR 'ESTIMATED BILL OF MATERIALS' TABLE.
- 'X' SYMBOL ON DRAWING INDICATES MARK NO. FOR BASE PLATE REPAIRS. REFERENCE DRAWING S-1.09 'KEY NOTES - COLUMN BASE PLATE REPAIRS' AND APPLICABLE SECTIONS & DETAILS AS REQUIRED.
- REFERENCE DWG. S0.00 FOR ADDITIONAL GENERAL NOTES, MATERIAL SPECIFICATIONS & REQUIREMENTS, DESIGN CRITERIA AND LEGEND.

REV. NO.	DESCRIPTION	DATE
D	FINAL DESIGN - RELEASED FOR BID	23 MAY 2022
C	FINAL DESIGN - FINAL REVIEW NOT FOR CONSTRUCTION	09 MAY 2022
B	100% DESIGN - NOT FOR CONSTRUCTION	18 MAR 2022
A	90% DESIGN - NOT FOR CONSTRUCTION	02 MAR 2022

WILLIAM F. BAND, P.E.  
No. 67836

**MCKIM & CREED**  
1365 Hamlet Avenue  
Clearwater, Florida 33756-3331  
Phone: (727) 442-7196, Fax: (727) 461-3827  
CA Lic. No. 29588  
www.mckimcreed.com

**CLEARWATER**  
BRIGHT AND BEAUTIFUL BAY TO BEACH

**LONG CENTER NATATORIUM  
STRUCTURAL FRAME REPAIRS**

STRUCTURAL

**EXIST. BLDG. A TRUSS CONDITIONS &  
REPAIRS (SHT. 2 OF 11)**


PROJ. START DATE: 2021.NOV  
MCE PROJ. # 00992-0261  
DRAWN WFB  
DESIGNED WFB  
CHECKED WFB/AEA  
PROJ. MGR. AAM

SCALE: HORIZONTAL: AS NOTED  
VERTICAL: NA


**\$1.04**  
DRAWING NUMBER: D  
REVISION:

STATUS: FINAL DESIGN SUBMITTAL  
RELEASED FOR BID







1 - DETAIL - TRUSS "T1" COL. LINE "B"  
SCALE: 1/4" = 1'-0"




2 - DETAIL - TRUSS "T1" @ COL. LINE "B"  
SCALE: 1/4" = 1'-0"



3 - DETAIL - B-5-T1-5 REPAIR  
SCALE: 3/4" = 1'-0"



4 - DETAIL - B-6.3-T1-5 REPAIR  
SCALE: 3/4" = 1'-0"



5 - DETAIL - B-6.3-T1-4 REPAIR  
SCALE: 3/4" = 1'-0"

NOTES:

- IN GENERAL REPAIR OF THE EXISTING STRUCTURAL STEEL TRUSSES AND THE SECONDARY EXTERIOR WALL BEAMS INVOLVES REPAIRS TO INTERIOR VERTICAL, HORIZONTAL & DIAGONAL SURFACES OF THE TRUSSES, COLUMNS, CONNECTION PLATES OR ANGLES, BASE PLATES AND ANCHOR BOLTS AND HARDWARE. IN GENERAL REPAIR WORK INCLUDES THE FOLLOWING:
  - REMOVING EXISTING COATINGS TO BARE METAL.
  - REMOVING SURFACE RUST OR THRU WALL RUST AND CLEANING SURFACES TO BARE METAL.
  - PREPARING BARE METAL SURFACES TO SSPC-SP6 "COMMERCIAL BLAST CLEANING" CRITERIA.
  - WELDING NEW STEEL PLATE OR ANGLE SECTIONS TO THE EXISTING STEEL SECTIONS. REGARDING FIELD WELDING AND PREPARATION TO SSPC-SP6 CRITERIA, THE MAXIMUM BASE METAL TEMPERATURE AT DEMARCATION BETWEEN BRIGHT METAL AND THE EXISTING COATINGS TO BE CONFIRMED w/ THE USE OF 182° F TEMPLSTIK'S BETWEEN WELD PASSES.
  - INSTALL NEW COATING SYSTEM ON THE REPAIRED AREAS TO MATCH.
- CODE FOR UTILIZING TRUSS CONNECTION LOCATIONS MARK NUMBERS AS FOLLOWS:
  - COL. ID EW DIRECTION - COL. ID NS DIRECTION - TRUSS TYPE - ELEVATION ABOVE BASE PLATE.
  - COORDINATE w/ TRUSS ELEVATIONS DWG.'S S-1.01 & S-1.02 FOR HEIGHT CODES 0 TO 5.
  - COORDINATE w/ THE 'TRUSS CONN. LOCATION MK. # LEGEND EXAMPLE' DWG. S1.03 FOR ADDITIONAL INFORMATION.

NOTES CTD. ...

- REGARDING VERIFYING CONDITION OF EXISTING STEEL, NOTE THE FOLLOWING:
  - DURING SITE VISITS NOT ALL AREAS OF THE EXISTING FACILITY COULD BE EASILY ACCESSED SAFELY w/ THE LIFT.
  - CONTRACTOR TO VERIFY IF EXISTING TOP CHORDS EXHIBITING SIGNS OF RUST, CORROSION OR LOSS OF COATING.
  - NOTIFY ENGINEER OF AREAS THAT ARE NOT CURRENTLY INDICATED BUT DISPLAY RUST, CORROSION, AND / OR COATING PEELING OR LOSS FOR DIRECTIONS HOW TO PROCEED.
  - COORDINATE w/ DETAILS REFERENCED FOR ANGLE / PLATE LAYOUT DIM.'S & WELD REQ.'S, U.N.O.
  - IF COATING REMOVAL YIELDS SURFACE PITTING GRIND SMOOTH & TO SURFACE PREP. REQ.'S.
  - PLATE OR ANGLE ASSEMBLIES NOT REQUIRED PROVIDED REMOVAL OF THE EXISTING COATING / CORROSION & SURFACE PREP DOES NOT YIELD UNEXPECTED RESULTS & REPAIRS CANNOT BE INSTALLED AS NOTED.
  - REMOVE & REINSTALL EXIST. WINDOW GLASS & FRAME TO REPAIR IF REQ'D.
  - WELD L5'S TO HSS TRUSS CHORD, COL. & HORZ. BM. REF. DETAIL 2-S1.03 FOR WELD REQ.'S & INFO.
  - TRUSS WEB DIAGONAL SHOWN UNDERSIDE OF TOP CHORD FOR CLARITY.

NOTES CTD. ...

- SYMBOL ON DRAWING INDICATES MARK NO. FOR BASE PLATE REPAIRS. REFERENCE DRAWING S-1.09 "KEY NOTES - COLUMN BASE PLATE REPAIRS" AND APPLICABLE SECTIONS & DETAILS AS REQUIRED.
- REFERENCE DWG. S0.00 FOR ADDITIONAL GENERAL NOTES, MATERIAL SPECIFICATIONS & REQUIREMENTS, DESIGN CRITERIA AND LEGEND.

ESTIMATED BILL OF MATERIALS ... S1.06

ITEM #	COMPONENT	DESCRIPTION	QTY.	NOTES
01	ANGLE SECTION	L5x5x2" x 4'	9	
02	PLATE	0'-8 1/2" x 2 1/2" x 1/2"	12	
03	BENT PLATE	0'-6" x 2 1/2" x 1/2" x 5'	8	
04	WING PLATE	0'-4" x 1 1/2" x 1/2"	22	
05	FILLET WELD	3/8" EFF. THROAT	675'	
06	FILLET WELD	1/2" EFF. THROAT	210"	
07	FILLET WELD	5/8" EFF. THROAT	20"	
08	BUTT WELD	COMPLETE PEN.	40"	
09	FLARE BEVEL WELD	PARTIAL PEN.	50"	

REV. NO.	DESCRIPTION	DATE
D	FINAL DESIGN - RELEASED FOR BID	23 MAY 2022
C	FINAL DESIGN - FINAL REVIEW NOT FOR CONSTRUCTION	09 MAY 2022
B	100% DESIGN - NOT FOR CONSTRUCTION	18 MAR 2022
A	90% DESIGN - NOT FOR CONSTRUCTION	02 MAR 2022


WILLIAM F. BAND, P.E.  
No. 67836

**MCKIM & CREED**  
1365 Hamlet Avenue  
Clearwater, Florida 33756-3331  
Phone: (727) 442-7196, Fax: (727) 461-3827  
CA Lic. No. 29588  
www.mckimcreed.com


**CLEARWATER**  
BRIGHT AND BEAUTIFUL BAY TO BEACH

**LONG CENTER NATATORIUM  
STRUCTURAL FRAME REPAIRS**  
STRUCTURAL  
**EXIST. BLDG. A TRUSS CONDITIONS &  
REPAIRS (SHT. 4 OF 11)**

PROJ. START DATE: 2021.NOV  
MCE PROJ. # 00992-0261  
DRAWN WFB  
DESIGNED WFB  
CHECKED WFB / AEA  
PROJ. MGR. AAM  
SCALE: HORIZONTAL: AS NOTED, VERTICAL: NA  
**\$1.06**  
DRAWING NUMBER: D  
REVISION: D  
STATUS: FINAL DESIGN SUBMITTAL RELEASED FOR BID



1 - DETAIL - TRUSS "T1" COL. LINE "B"  
SCALE: 1/4" = 1'-0"



2 - DETAIL - TRUSS "T1" @ COL. LINE "B"  
SCALE: 1/4" = 1'-0"

**NOTES:**

- IN GENERAL REPAIR OF THE EXISTING STRUCTURAL STEEL TRUSSES AND THE SECONDARY EXTERIOR WALL BEAMS INVOLVES REPAIRS TO INTERIOR VERTICAL, HORIZONTAL & DIAGONAL SURFACES OF THE TRUSSES, COLUMNS, CONNECTION PLATES OR ANGLES, BASE PLATES AND ANCHOR BOLTS AND HARDWARE. IN GENERAL REPAIR WORK INCLUDES THE FOLLOWING:
  - REMOVING EXISTING COATINGS TO BARE METAL.
  - REMOVING SURFACE RUST OR THRU WALL RUST AND CLEANING SURFACES TO BARE METAL.
  - PREPARING BARE METAL SURFACES TO SSPC-SP6 "COMMERCIAL BLAST CLEANING" CRITERIA.
  - WELDING NEW STEEL PLATE OR ANGLE SECTIONS TO THE EXISTING STEEL SECTIONS.
 REGARDING FIELD WELDING AND PREPARATION TO SSPC-SP6 CRITERIA, THE MAXIMUM BASE METAL TEMPERATURE AT DEMARCATION BETWEEN BRIGHT METAL AND THE EXISTING COATINGS TO BE CONFIRMED w/ THE USE OF 182° F TEMPLITS™s BETWEEN WELD PASSES.
- INSTALL NEW COATING SYSTEM ON THE REPAIRED AREAS TO MATCH
- CODE FOR UTILIZING TRUSS CONNECTION LOCATIONS MARK NUMBERS AS FOLLOWS:
  - COL. ID E/W DIRECTION - COL. ID N/S DIRECTION - TRUSS TYPE - ELEVATION ABOVE BASE PLATE.
  - COORDINATE w/ TRUSS ELEVATIONS DWG.'s S-1.01 & S-1.02 FOR HEIGHT CODES 0 TO 5.
  - COORDINATE w/ THE "TRUSS CONN. LOCATION MK. # LEGEND EXAMPLE" DWG. S1.03 FOR ADDITIONAL INFORMATION.

**NOTES CTD. ...**

- REGARDING VERIFYING CONDITION OF EXISTING STEEL, NOTE THE FOLLOWING:
  - DURING SITE VISITS NOT ALL AREAS OF THE EXISTING FACILITY COULD BE EASILY ACCESSED SAFELY w/ THE LIFT.
  - CONTRACTOR TO VERIFY IF EXISTING TOP CHORDS EXHIBITING SIGNS OF RUST, CORROSION OR LOSS OF COATING.
  - NOTIFY ENGINEER OF AREAS THAT ARE NOT CURRENTLY INDICATED BUT DISPLAY RUST, CORROSION, AND / OR COATING PEELING OR LOSS FOR DIRECTIONS HOW TO PROCEED.
- COORDINATE w/ DETAILS REFERENCED FOR ANGLE / PLATE LAYOUT DIM.'s & WELD REQ.'s, U.N.O..
- IF COATING REMOVAL YIELDS SURFACE PITTING GRIND SMOOTH & TO SURFACE PREP. REQ.'s.
- PLATE OR ANGLE ASSEMBLIES NOT REQUIRED PROVIDED REMOVAL OF THE EXISTING COATING / CORROSION & SURFACE PREP DOES NOT YIELD UNEXPECTED RESULTS & REPAIRS CANNOT BE INSTALLED AS NOTED.
- REMOVE & REINSTALL EXIST. WINDOW GLASS & FRAME TO REPAIR IF REQ'D.
- WELD L5's TO HSS TRUSS CHORD, COL. & HORZ. BM. REF. DETAIL 2-S1.03 FOR WELD REQ.'s & INFO.
- TRUSS WEB DIAGONAL SHOWN UNDERSIDE OF TOP CHORD FOR CLARITY.

**NOTES CTD. ...**

- SYMBOL ON DRAWING INDICATES MARK NO. FOR BASE PLATE REPAIRS. REFERENCE DRAWING S-1.09 "KEY NOTES - COLUMN BASE PLATE REPAIRS" AND APPLICABLE SECTIONS & DETAILS AS REQUIRED.
- REFERENCE DWG. S0.00 FOR ADDITIONAL GENERAL NOTES, MATERIAL SPECIFICATIONS & REQUIREMENTS, DESIGN CRITERIA AND LEGEND.

ESTIMATED BILL OF MATERIALS ... S1.07				
ITEM #	COMPONENT	DESCRIPTION	QTY.	NOTES
01	ANGLE SECTION	L5x5x $\frac{1}{2}$ " x 4 $\frac{1}{2}$ "	11	
02	PLATE	0'-8 $\frac{1}{2}$ "x2 $\frac{1}{2}$ "x $\frac{1}{2}$ "	12	
03	BENT PLATE	0'-6"x2 $\frac{1}{2}$ "x $\frac{1}{2}$ " x 5 $\frac{1}{2}$ "	8	
04	WING PLATE	0'-4"x1 $\frac{1}{2}$ "x $\frac{1}{2}$ "	9	
05	FILLET WELD	$\frac{3}{8}$ " EFF. THROAT	520'	
06	FILLET WELD	$\frac{1}{2}$ " EFF. THROAT	210'	
07	FILLET WELD	$\frac{5}{16}$ " EFF. THROAT	20'	
08	BUTT WELD	COMPLETE PEN.	20'	
09	FLARE BEVEL WELD	PARTIAL PEN.	50'	

REV. NO.	DESCRIPTION	DATE
D	FINAL DESIGN - RELEASED FOR BID	23 MAY 2022
C	FINAL DESIGN - FINAL REVIEW NOT FOR CONSTRUCTION	09 MAY 2022
B	100% DESIGN - NOT FOR CONSTRUCTION	18 MAR 2022
A	90% DESIGN - NOT FOR CONSTRUCTION	02 MAR 2022

WILLIAM F. BAND, P.E.  
No. 67836

**MCKIM & CREED**  
1365 Hamlet Avenue  
Clearwater, Florida 33756-3331  
Phone: (727) 442-7196, Fax: (727) 461-3827  
CA Lic. No. 29588  
www.mckimcreed.com

**CLEARWATER**  
BRIGHT AND BEAUTIFUL BAY TO BEACH

**LONG CENTER NATATORIUM  
STRUCTURAL FRAME REPAIRS**

STRUCTURAL


**EXIST. BLDG. A TRUSS CONDITIONS &  
REPAIRS (SHT. 5 OF 11)**

PROJ. START DATE: 2021.NOV  
MCE PROJ. # 00992-0261  
DRAWN WFB  
DESIGNED WFB  
CHECKED WFB / AEA  
PROJ. MGR. AAM


SCALE: HORIZONTAL: AS NOTED  
VERTICAL: NA

**\$1.07**  
DRAWING NUMBER  
D  
REVISION


STATUS: FINAL DESIGN SUBMITTAL  
RELEASED FOR BID




1 - DETAIL - TRUSS "T1" COL. LINE "B"  
SCALE: 1/4" = 1'-0"




2 - DETAIL - TRUSS "T1" & "T2" @ COL. LINE "B"  
SCALE: 1/4" = 1'-0"




3 - DETAIL - B-9-T1-2 REPAIR  
SCALE: 3/4" = 1'-0"



4 - DETAIL - B-10-T1-4 REPAIR  
SCALE: 3/4" = 1'-0"



5 - DETAIL - B-10-T1-3 REPAIR  
SCALE: 3/4" = 1'-0"



6 - DETAIL - B-10.3-T2-4 REPAIR  
SCALE: 3/4" = 1'-0"

**NOTES:**

- IN GENERAL REPAIR OF THE EXISTING STRUCTURAL STEEL TRUSSES AND THE SECONDARY EXTERIOR WALL BEAMS INVOLVES REPAIRS TO INTERIOR VERTICAL, HORIZONTAL & DIAGONAL SURFACES OF THE TRUSSES, COLUMNS, CONNECTION PLATES OR ANGLES, BASE PLATES AND ANCHOR BOLTS AND HARDWARE. IN GENERAL REPAIR WORK INCLUDES THE FOLLOWING:
  - REMOVING EXISTING COATINGS TO BARE METAL.
  - REMOVING SURFACE RUST OR THRU WALL RUST AND CLEANING SURFACES TO BARE METAL.
  - PREPARING BARE METAL SURFACES TO SSPC-SP6 "COMMERCIAL BLAST CLEANING" CRITERIA.
  - WELDING NEW STEEL PLATE OR ANGLE SECTIONS TO THE EXISTING STEEL SECTIONS.
 REGARDING FIELD WELDING AND PREPARATION TO SSPC-SP6 CRITERIA, THE MAXIMUM BASE METAL TEMPERATURE AT DEMARCATION BETWEEN BRIGHT METAL AND THE EXISTING COATINGS TO BE CONFIRMED w/ THE USE OF 182° F TEMPLSTIK'S BETWEEN WELD PASSES.
  - INSTALL NEW COATING SYSTEM ON THE REPAIRED AREAS TO MATCH
- CODE FOR UTILIZING TRUSS CONNECTION LOCATIONS MARK NUMBERS AS FOLLOWS:
  - COL. ID E/W DIRECTION - COL. ID N/S DIRECTION - TRUSS TYPE - ELEVATION ABOVE BASE PLATE.
  - COORDINATE w/ TRUSS ELEVATIONS DWG.'S S-1.01 & S-1.02 FOR HEIGHT CODES 0 TO 5.
  - COORDINATE w/ THE "TRUSS CONN. LOCATION MK. # LEGEND EXAMPLE" DWG. S1.03 FOR ADDITIONAL INFORMATION.

**NOTES CTD. ...**

- REGARDING VERIFYING CONDITION OF EXISTING STEEL, NOTE THE FOLLOWING:
  - DURING SITE VISITS NOT ALL AREAS OF THE EXISTING FACILITY COULD BE EASILY ACCESSED SAFELY w/ THE LIFT.
  - CONTRACTOR TO VERIFY IF EXISTING TOP CHORDS EXHIBITING SIGNS OF RUST, CORROSION OR LOSS OF COATING.
  - NOTIFY ENGINEER OF AREAS THAT ARE NOT CURRENTLY INDICATED BUT DISPLAY RUST, CORROSION, AND / OR COATING PEELING OR LOSS FOR DIRECTIONS HOW TO PROCEED.
- COORDINATE w/ DETAILS REFERENCED FOR ANGLE / PLATE LAYOUT DIM.'S & WELD REQ.'S, U.N.O.
- IF COATING REMOVAL YIELDS SURFACE PITTING GRIND SMOOTH & TO SURFACE PREP. REQ.'S.
- PLATE OR ANGLE ASSEMBLIES NOT REQUIRED PROVIDED REMOVAL OF THE EXISTING COATING / CORROSION & SURFACE PREP DOES NOT YIELD UNEXPECTED RESULTS & REPAIRS CANNOT BE INSTALLED AS NOTED.
- REMOVE & REINSTALL EXIST. WINDOW GLASS & FRAME TO REPAIR IF REQ'D.
- WELD L5'S TO HSS TRUSS CHORD, COL. & HORZ. BM. REF. DETAIL 2-S1.03 FOR WELD REQ.'S & INFO.


**NOTES CTD. ...**

9. "X" SYMBOL ON DRAWING INDICATES MARK NO. FOR BASE PLATE REPAIRS. REFERENCE DRAWING S-1.09 "KEY NOTES - COLUMN BASE PLATE REPAIRS" AND APPLICABLE SECTIONS & DETAILS AS REQUIRED.
- REFERENCE DWG. S0.00 FOR ADDITIONAL GENERAL NOTES, MATERIAL SPECIFICATIONS & REQUIREMENTS, DESIGN CRITERIA AND LEGEND.

ESTIMATED BILL OF MATERIALS ... S1.08				
ITEM #	COMPONENT	DESCRIPTION	QTY.	NOTES
01	ANGLE SECTION	L5x5x1/2" x 4 1/2"	15	
02	PLATE	0'-8 1/2" x 2 1/2" x 1/2"	8	
03	PLATE	0'-8 1/2" x 4 1/2" x 1/2"	1	
04	BENT PLATE	1'-9" x 5" x 1/2" x 4 1/2"	1	
05	BENT PLATE	0'-6" x 2 1/2" x 1/2" x 5 1/2"	6	
06	BENT PLATE	0'-6" x 2 1/2" x 1/2" x 2 1/2"	1	
07	WING PLATE	0'-4" x 1 1/2" x 1/2"	17	
08	WING PLATE	0'-4" x 3 3/8" x 1/2"	6	
09	FILLET WELD	3/8" EFF. THROAT	870"	
10	FILLET WELD	1/2" EFF. THROAT	180"	
11	FILLET WELD	3/8" EFF. THROAT	25"	
12	BUTT WELD	COMPLETE PEN.	50"	
13	FLARE BEVEL WELD	PARTIAL PEN.	70"	

REV. NO.	DESCRIPTION	DATE
D	FINAL DESIGN - RELEASED FOR BID	23 MAY 2022
C	FINAL DESIGN - FINAL REVIEW NOT FOR CONSTRUCTION	09 MAY 2022
B	100% DESIGN - NOT FOR CONSTRUCTION	18 MAR 2022
A	90% DESIGN - NOT FOR CONSTRUCTION	02 MAR 2022

WILLIAM F. BAND, P.E.  
No. 67836




1365 Hamlet Avenue  
Clearwater, Florida 33756-3331  
Phone: (727) 442-7196, Fax: (727) 461-3827  
CA Lic. No. 29588  
www.mckimcreed.com




**LONG CENTER NATATORIUM  
STRUCTURAL FRAME REPAIRS**

STRUCTURAL  
**EXIST. BLDG. A TRUSS CONDITIONS &  
REPAIRS (SHT. 6 OF 11)**


PROJ. START DATE: 2021 NOV	MCE PROJ. # 0092-0261	SCALE: HORIZONTAL: AS NOTED	<b>\$1.08</b>
DRAWN: WFB	DESIGNED: WFB	VERTICAL: NA	
CHECKED: WFB / AEA	PROJ. MGR: AAM	DRAWING NUMBER: D	REVISION:
STATUS: FINAL DESIGN SUBMITTAL			RELEASED FOR BID



1 - DETAIL - TRUSS "T1" & "T2" @ COL. LINE "D"  
SCALE: 1/4" = 1'-0"



3 - DETAIL - D-10.3-T2-4 REPAIR  
SCALE: 3/4" = 1'-0"



4 - DETAIL - D-10.3-T2-3 REPAIR  
SCALE: 3/4" = 1'-0"

**NOTES:**

- IN GENERAL REPAIR OF THE EXISTING STRUCTURAL STEEL TRUSSES AND THE SECONDARY EXTERIOR WALL BEAMS INVOLVES REPAIRS TO INTERIOR VERTICAL, HORIZONTAL & DIAGONAL SURFACES OF THE TRUSSES, COLUMNS, CONNECTION PLATES OR ANGLES, BASE PLATES AND ANCHOR BOLTS AND HARDWARE. IN GENERAL REPAIR WORK INCLUDES THE FOLLOWING:
  - REMOVING EXISTING COATINGS TO BARE METAL.
  - REMOVING SURFACE RUST OR THRU WALL RUST AND CLEANING SURFACES TO BARE METAL.
  - PREPARING BARE METAL SURFACES TO SSPC-SP6 'COMMERCIAL BLAST CLEANING' CRITERIA.
  - WELDING NEW STEEL PLATE OR ANGLE SECTIONS TO THE EXISTING STEEL SECTIONS.
 REGARDING FIELD WELDING AND PREPARATION TO SSPC-SP6 CRITERIA, THE MAXIMUM BASE METAL TEMPERATURE AT DEMARCATION BETWEEN BRIGHT METAL AND THE EXISTING COATINGS TO BE CONFIRMED w/ THE USE OF 182° F TEMPISTIK'S BETWEEN WELD PASSES.
- INSTALL NEW COATING SYSTEM ON THE REPAIRED AREAS TO MATCH
- CODE FOR UTILIZING TRUSS CONNECTION LOCATIONS MARK NUMBERS AS FOLLOWS:
  - COL. ID E/W DIRECTION - COL. ID N/S DIRECTION - TRUSS TYPE - ELEVATION ABOVE BASE PLATE.
  - COORDINATE w/ TRUSS ELEVATIONS DWG.'S S-1.01 & S-1.02 FOR HEIGHT CODES 0 TO 5.
  - COORDINATE w/ THE 'TRUSS CONN. LOCATION MK. # LEGEND EXAMPLE' DWG. S1.03 FOR ADDITIONAL INFORMATION.

**NOTES CTD. ...**


- REGARDING VERIFYING CONDITION OF EXISTING STEEL, NOTE THE FOLLOWING:
  - DURING SITE VISITS NOT ALL AREAS OF THE EXISTING FACILITY COULD BE EASILY ACCESSED SAFELY w/ THE LIFT.
  - CONTRACTOR TO VERIFY IF EXISTING TOP CHORDS EXHIBITING SIGNS OF RUST, CORROSION OR LOSS OF COATING.
  - NOTIFY ENGINEER OF AREAS THAT ARE NOT CURRENTLY INDICATED BUT DISPLAY RUST, CORROSION, AND / OR COATING PEELING OR LOSS FOR DIRECTIONS HOW TO PROCEED.
  - COORDINATE w/ DETAILS REFERENCED FOR ANGLE / PLATE LAYOUT DIM.'S & WELD REQ.'S, U.N.O.
  - IF COATING REMOVAL YIELDS SURFACE PITTING GRIND SMOOTH & TO SURFACE PREP. REQ.'S.
  - PLATE OR ANGLE ASSEMBLIES NOT REQUIRED PROVIDED REMOVAL OF THE EXISTING COATING / CORROSION & SURFACE PREP DOES NOT YIELD UNEXPECTED RESULTS & REPAIRS CANNOT BE INSTALLED AS NOTED.
  - REMOVE & REINSTALL EXIST. WINDOW GLASS & FRAME TO REPAIR IF REQ'D.

**NOTES CTD. ...**


8. "X" SYMBOL ON DRAWING INDICATES MARK NO. FOR BASE PLATE REPAIRS. REFERENCE DRAWING S-1.09 'KEY NOTES - COLUMN BASE PLATE REPAIRS' AND APPLICABLE SECTIONS & DETAILS AS REQUIRED.
9. REFERENCE DWG. S0.00 FOR ADDITIONAL GENERAL NOTES, MATERIAL SPECIFICATIONS & REQUIREMENTS, DESIGN CRITERIA AND LEGEND.

2 - KEYNOTES - COL. BASE PLATE REPAIRS


- SCALE: N/A
- REMOVE EXISTING COATING FROM EXPOSED PLATE TOP & SIDE SURFACES. REMOVE ALL RUST FROM PLATE & ANCHOR BOLTS & HARDWARE SURFACES TO BARE METAL. REMOVE & REPLACE SEVERELY CORRODED NUTS & WASHERS. PREP ALL PLATE, COLUMN, BOLTS & HARDWARE STEEL SURFACES AS REQUIRED. REPAIR ANCHOR BOLTS PER DETAIL 8-S1.09 IF BOLT OR THREADS DAMAGED BEYOND REPAIR. INSTALL NEW COATING SYSTEM.
  - REFERENCE KEYNOTE 1 FOR REMOVING EXISTING RUST, COATING & BOLT HARDWARE. REFERENCE KEYNOTE 1 FOR PREP OF EXISTING STEEL. REINFORCE PLATE AS INDICATED DETAIL 5-S1.09. REPAIR ANCHOR BOLTS PER DETAIL 8-S1.09 IF BOLT OR THREADS DAMAGED BEYOND REPAIR. INSTALL NEW COATING SYSTEM.
  - REFERENCE KEYNOTE 1 FOR REMOVING EXISTING RUST, COATING & BOLT HARDWARE. REFERENCE KEYNOTE 1 FOR PREP OF EXISTING STEEL. REINFORCE PLATE AS INDICATED DETAIL 6-S1.09. REPAIR ANCHOR BOLTS PER DETAIL 8-S1.09 IF BOLT OR THREADS DAMAGED BEYOND REPAIR. INSTALL NEW COATING SYSTEM.
  - REFERENCE KEYNOTE 1 FOR REMOVING EXISTING RUST, COATING & BOLT HARDWARE. REFERENCE KEYNOTE 1 FOR PREP OF EXISTING STEEL. REINFORCE PLATE AS INDICATED DETAIL 7-S1.09. REPAIR ANCHOR BOLTS PER DETAIL 8-S1.09 IF BOLT OR THREADS DAMAGED BEYOND REPAIR. INSTALL NEW COATING SYSTEM.




5 - DETAIL - EXIST. BASE PLATE MOD KEY NOTE 2  
SCALE: 1 1/2" = 1'-0"



6 - DETAIL - EXIST. BASE PLATE MOD KEY NOTE 3  
SCALE: 1 1/2" = 1'-0"



7 - DETAIL - EXIST. BASE PLATE MOD KEY NOTE 4  
SCALE: 1 1/2" = 1'-0"



8 - DETAIL - EXIST. BASE PLATE A.B. MOD  
SCALE: 3" = 1'-0"

ESTIMATED BILL OF MATERIALS ... S1.09

ITEM #	COMPONENT	DESCRIPTION	QTY.	NOTES
01	ANGLE SECTION	L5x5x1/2 x 4 1/2	2	
02	WING PLATE	0'-4"x3 1/2"x1/2	2	
03	FILLET WELD	3/8" EFF. THROAT	70"	
04	BUTT WELD	COMPLETE PEN.	5"	
05	FLARE BEVEL WELD	PARTIAL PEN.	10"	

REV. NO.	DESCRIPTION	DATE
D	FINAL DESIGN - RELEASED FOR BID	23 MAY 2022
C	FINAL DESIGN - FINAL REVIEW NOT FOR CONSTRUCTION	09 MAY 2022
B	100% DESIGN - NOT FOR CONSTRUCTION	18 MAR 2022
A	90% DESIGN - NOT FOR CONSTRUCTION	02 MAR 2022

WILLIAM F. BAND, P.E.  
No. 67836

**MCKIM & CREED**  
1365 Hamlet Avenue  
Clearwater, Florida 33756-3331  
Phone: (727) 442-7196, Fax: (727) 461-3827  
CA Lic. No. 29588  
www.mckimcreed.com

**CLEARWATER**  
BRIGHT AND BEAUTIFUL BAY TO BEACH

**LONG CENTER NATATORIUM  
STRUCTURAL FRAME REPAIRS**

STRUCTURAL


**EXIST. BLDG. A TRUSS CONDITIONS &  
REPAIRS (SHT. 7 OF 11)**

PROJ. START DATE: 2021.NOV  
MCE PROJ. # 00992-0261  
DRAWN WFB  
DESIGNED WFB  
CHECKED WFB / AEA  
PROJ. MGR. AAM

SCALE: HORIZONTAL: AS NOTED  
VERTICAL: NA

**\$1.09**  
DRAWING NUMBER  
D  
REVISION


STATUS: **FINAL DESIGN SUBMITTAL  
RELEASED FOR BID**



1 - DETAIL - TRUSS "2" & COL. LINE "1" FRMG.  
SCALE: 1/4" = 1'-0"

2 - DETAIL - TRUSS "2" & COL. LINE "1" FRMG.  
SCALE: 1/4" = 1'-0"

3 - DETAIL - TRUSS "2" & COL. LINE "1" FRMG.  
SCALE: 1/4" = 1'-0"



4 - DETAIL - B.9-1-T2-3 REPAIR  
SCALE: 3/4" = 1'-0"

TRUSS CONN. LOCATION MK. # LEGEND EXAMPLE:

- TRUSS CONNECTION LOCATION MK. # = B.9-1-T2-3S
- B.9 = EAST / WEST ORIENTED COLUMN LINE DIRECTION ON PLAN 1-S1.00.
  - 1 = NORTH / SOUTH ORIENTED COLUMN LINE DIRECTION ON PLAN 1-S1.00.
  - T1 = EXISTING TRUSS TYPE T1 OR T2 AS NOTED ON PLAN 1-S1.00 & TRUSS DETAIL ELEVATIONS.
  - 3 = ELEVATION ABOVE THE EXISTING SLAB-ON-GRADE AS INDICATED w/ "X" SYMBOL ON DWG.'s S1.01 & S1.02.
  - S = SOUTH / NORTH SIDE OF THE EXISTING COLUMN.

NOTES:

1. IN GENERAL REPAIR OF THE EXISTING STRUCTURAL STEEL TRUSSES AND THE SECONDARY EXTERIOR WALL BEAMS INVOLVES REPAIRS TO INTERIOR VERTICAL, HORIZONTAL & DIAGONAL SURFACES OF THE TRUSSES, COLUMNS, CONNECTION PLATES OR ANGLES, BASE PLATES AND ANCHOR BOLTS AND HARDWARE. IN GENERAL REPAIR WORK INCLUDES THE FOLLOWING:
  - a.) REMOVING EXISTING COATINGS TO BARE METAL.
  - b.) REMOVING SURFACE RUST OR THRU WALL RUST AND CLEANING SURFACES TO BARE METAL.
  - c.) PREPARING BARE METAL SURFACES TO SSPC-SP6 "COMMERCIAL BLAST CLEANING" CRITERIA.
  - d.) WELDING NEW STEEL PLATE OR ANGLE SECTIONS TO THE EXISTING STEEL SECTIONS.
- REGARDING FIELD WELDING AND PREPARATION TO SSPC-SP6 CRITERIA, THE MAXIMUM BASE METAL TEMPERATURE AT DEMARCATION BETWEEN BRIGHT METAL AND THE EXISTING COATINGS TO BE CONFIRMED w/ THE USE OF 182° F TEMPLSTIK'S BETWEEN WELD PASSES.
- e.) INSTALL NEW COATING SYSTEM ON THE REPAIRED AREAS TO MATCH
2. CODE FOR UTILIZING TRUSS CONNECTION LOCATIONS MARK NUMBERS AS FOLLOWS:
  - a.) COL. ID E/W DIRECTION - COL. ID N/S DIRECTION - TRUSS TYPE - ELEVATION ABOVE BASE PLATE.
  - b.) COORDINATE w/ TRUSS ELEVATIONS DWG.'s S-1.01 & S-1.02 FOR HEIGHT CODES 0 TO 5.
  - c.) COORDINATE w/ THE "TRUSS CONN. LOCATION MK. # LEGEND EXAMPLE" THIS DWG. FOR ADDITIONAL INFORMATION.

- NOTES CTD. ...
3. REGARDING VERIFYING CONDITION OF EXISTING STEEL, NOTE THE FOLLOWING:
    - a.) CONDITIONS OF STEEL MAY HAVE CHANGED SINCE SITE REVIEWS. NOTIFY THE ENGINEER OF AREAS THAT ARE NOT CURRENTLY INDICATED BUT DISPLAY RUST, CORROSION, AND / OR COATING PEELING OR LOSS FOR DIRECTIONS HOW TO PROCEED.
    4. COORDINATE w/ DETAILS REFERENCED FOR ANGLE / PLATE LAYOUT DIM.'s & WELD REQ.'s, U.N.O..
    5. IF COATING REMOVAL YIELDS SURFACE PITTING GRIND SMOOTH & TO SURFACE PREP. REQ.'s.
    6. PLATE OR ANGLE ASSEMBLIES NOT REQUIRED PROVIDED REMOVAL OF THE EXISTING COATING / CORROSION & SURFACE PREP DOES NOT YIELD UNEXPECTED RESULTS & REPAIRS CANNOT BE INSTALLED AS NOTED.
    7. REMOVE & REINSTALL EXIST. WINDOW GLASS & FRAME TO REPAIR IF REQ'D.
    8. THE W12 COL.'s INSTALLED w/ ADDITIONAL STEEL SECTION @ THE O/F OF THE W12 FLANGE. RECORD DWG.'s REVIEWED COULD NOT CONFIRM THE SECTION. SITE VISIT REVIEW APPEARED TO INDICATE (2) L6x3 SECTIONS INSTALLED w/ (1) L6x3 EACH SIDE OF THE WEB. FIELD VERIFY AS REQ. D & NOT SHOWN ELEVATIONS FOR CLARITY. REFERENCE DETAIL 5-S1.11 FOR CLARITY.

- NOTES CTD. ...
9. "X" SYMBOL ON DRAWING INDICATES MARK NO. FOR BASE PLATE REPAIRS. REFERENCE DRAWING S-1.09 "KEY NOTES - COLUMN BASE PLATE REPAIRS" AND APPLICABLE SECTIONS & DETAILS AS REQUIRED.
  10. REFERENCE DWG. S0.00 FOR ADDITIONAL GENERAL NOTES, MATERIAL SPECIFICATIONS & REQUIREMENTS, DESIGN CRITERIA AND LEGEND.

ESTIMATED BILL OF MATERIALS ... S1.10

ITEM #	COMPONENT	DESCRIPTION	QTY.	NOTES
01	BENT PLATE	0- $\frac{1}{8}$ " x $\frac{1}{8}$ " x $\frac{1}{8}$ " x $\frac{1}{8}$ "	2	
02	FILLET WELD	$\frac{3}{16}$ " EFF. THROAT	70'	

REV. NO.	DESCRIPTION	DATE
C	FINAL DESIGN - RELEASED FOR BID	23 MAY 2022
B	FINAL DESIGN - FINAL REVIEW NOT FOR CONSTRUCTION	09 MAY 2022
A	100% DESIGN - NOT FOR CONSTRUCTION	18 MAR 2022

REVISIONS

WILLIAM F. BAND, P.E.  
No. 67836



**MCKIM & CREED**  
1365 Hamlet Avenue  
Clearwater, Florida 33756-3331  
Phone: (727) 442-7196, Fax: (727) 461-3827

CA Lic. No. 29588  
www.mckimcreed.com

**CLEARWATER**  
BRIGHT AND BEAUTIFUL BAY TO BEACH

**LONG CENTER NATATORIUM  
STRUCTURAL FRAME REPAIRS**

STRUCTURAL


**EXIST. BLDG. A TRUSS CONDITIONS &  
REPAIRS (SHT. 8 OF 11)**

PROJ. START DATE: 2021.NOV  
MCE PROJ. # 00992-0261  
DRAWN: WFB  
DESIGNED: WFB  
CHECKED: WFB / AEA  
PROJ. MGR: AAM


SCALE: HORIZONTAL: AS NOTED, VERTICAL: NA

**\$1.10**  
DRAWING NUMBER  
REVISION: C


STATUS: FINAL DESIGN SUBMITTAL  
RELEASED FOR BID




1 - DETAIL - TRUSS "2" & COL. LINE "1" FRMG.  
SCALE: 1/4" = 1'-0"




2 - DETAIL - TRUSS "2" & COL. LINE "1" FRMG.  
SCALE: 1/4" = 1'-0"



3 - DETAIL - TRUSS "2" & COL. LINE "10.3" FRMG.  
SCALE: 1/4" = 1'-0"



4 - DETAIL - B.4-1-T2-1 REPAIR  
SCALE: 3/4" = 1'-0"



5 - DETAIL - B.2-10.3-T2-4 REPAIR  
SCALE: 3/4" = 1'-0"

NOTES:

- IN GENERAL REPAIR OF THE EXISTING STRUCTURAL STEEL TRUSSES AND THE SECONDARY EXTERIOR WALL BEAMS INVOLVES REPAIRS TO INTERIOR VERTICAL, HORIZONTAL & DIAGONAL SURFACES OF THE TRUSSES, COLUMNS, CONNECTION PLATES OR ANGLES, BASE PLATES AND ANCHOR BOLTS AND HARDWARE. IN GENERAL REPAIR WORK INCLUDES THE FOLLOWING:
  - REMOVING EXISTING COATINGS TO BARE METAL.
  - REMOVING SURFACE RUST OR THRU WALL RUST AND CLEANING SURFACES TO BARE METAL.
  - PREPARING BARE METAL SURFACES TO SSPC-SP6 "COMMERCIAL BLAST CLEANING" CRITERIA.
  - WELDING NEW STEEL PLATE OR ANGLE SECTIONS TO THE EXISTING STEEL SECTIONS.
- REGARDING FIELD WELDING AND PREPARATION TO SSPC-SP6 CRITERIA, THE MAXIMUM BASE METAL TEMPERATURE AT DEMARCATION BETWEEN BRIGHT METAL AND THE EXISTING COATINGS TO BE CONFIRMED w/ THE USE OF 182° F TEMPLSTIK'S BETWEEN WELD PASSES.
  - INSTALL NEW COATING SYSTEM ON THE REPAIRED AREAS TO MATCH
- CODE FOR UTILIZING TRUSS CONNECTION LOCATIONS MARK NUMBERS AS FOLLOWS:
  - COL. ID E/W DIRECTION - COL. ID N/S DIRECTION - TRUSS TYPE - ELEVATION ABOVE BASE PLATE.
  - COORDINATE w/ TRUSS ELEVATIONS DWG.'S S-1.01 & S-1.02 FOR HEIGHT CODES 0 TO 5.
  - COORDINATE w/ THE 'TRUSS CONN. LOCATION MK. # LEGEND EXAMPLE' DWG. S1.10 FOR ADDITIONAL INFORMATION.

NOTES CTD. ...

- REGARDING VERIFYING CONDITION OF EXISTING STEEL. NOTE THE FOLLOWING:
  - CONDITIONS OF STEEL MAY HAVE CHANGED SINCE SITE REVIEWS. NOTIFY THE ENGINEER OF SITE CONDITIONS THAT MAY BE DIFFERENT THAN INDICATED. IN ADDITION NOTIFY THE ENGINEER OF AREAS THAT ARE NOT CURRENTLY INDICATED BUT MAY DISPLAY RUST, CORROSION, AND / OR COATING PEELING OR LOSS FOR DIRECTIONS HOW TO PROCEED.
  - COORDINATE w/ DETAILS REFERENCED FOR ANGLE / PLATE LAYOUT DIM.'S & WELD REQ.'S. U.N.O.
  - IF COATING REMOVAL YIELDS SURFACE PITTING GRIND SMOOTH & TO SURFACE PREP. REQ.'S.
  - PLATE OR ANGLE ASSEMBLIES NOT REQUIRED PROVIDED REMOVAL OF THE EXISTING COATING / CORROSION & SURFACE PREP DOES NOT YIELD UNEXPECTED RESULTS & REPAIRS CANNOT BE INSTALLED AS NOTED
  - REMOVE & REINSTALL EXIST. WINDOW GLASS & FRAME TO REPAIR IF REQ'D.
  - THE W12 COL.'S INSTALLED w/ ADDITIONAL STEEL SECTION @ THE I/F OF THE W12 EXTR. FLANGE. RECORD DWG.'S REVIEWED COULD NOT CONFIRM THE SECTION. SITE VISIT REVIEW APPEARED TO INDICATE (2) L6x3 SECTIONS INSTALLED w/ (1) L6x3 EACH SIDE OF THE WEB. FIELD VERIFY AS REQ'D & NOT SHOWN ELEVATIONS FOR CLARITY. REFERENCE DETAIL 5-S1.11 FOR CLARITY.

NOTES CTD. ...

- SYMBOL ON DRAWING INDICATES MARK NO. FOR BASE PLATE REPAIRS. REFERENCE DRAWING S-1.09 "KEY NOTES - COLUMN BASE PLATE REPAIRS" AND APPLICABLE SECTIONS & DETAILS AS REQUIRED.
- REFERENCE DWG. S0.00 FOR ADDITIONAL GENERAL NOTES, MATERIAL SPECIFICATIONS & REQUIREMENTS, DESIGN CRITERIA AND LEGEND.

ESTIMATED BILL OF MATERIALS ... S1.11

ITEM #	COMPONENT	DESCRIPTION	QTY.	NOTES
01	BENT PLATE	0'-6 1/2" x 6 1/2" x 3/8" x 3/16"	2	
02	BENT PLATE	0'-9" x 4" x 3/8" x 3/16"	2	
03	FILLET WELD	3/16" EFF. THROAT	50'	
04	FILLET WELD	3/16" EFF. THROAT	70'	
05	FLARE BEVEL WELD	PARTIAL PEN.	20'	

REV. NO.	DESCRIPTION	DATE
C	FINAL DESIGN - RELEASED FOR BID	23 MAY 2022
B	FINAL DESIGN - FINAL REVIEW NOT FOR CONSTRUCTION	09 MAY 2022
A	100% DESIGN - NOT FOR CONSTRUCTION	18 MAR 2022


WILLIAM F. BAND, P.E.  
No. 67836

**MCKIM & CREED**  
1365 Hamlet Avenue  
Clearwater, Florida 33756-3331  
Phone: (727) 442-7196, Fax: (727) 461-3827  
CA Lic. No. 29588  
www.mckimcreed.com


**CLEARWATER**  
BRIGHT AND BEAUTIFUL BAY TO BEACH

**LONG CENTER NATATORIUM  
STRUCTURAL FRAME REPAIRS**  
STRUCTURAL  
**EXIST. BLDG. A TRUSS CONDITIONS &  
REPAIRS (SHT. 9 OF 11)**

PROJ. START DATE: 2021.NOV  
MCE PROJ. # 00992-0261  
DRAWN WFB  
DESIGNED WFB  
CHECKED WFB / AEA  
PROJ. MGR. AAM  
SCALE: HORIZONTAL: AS NOTED, VERTICAL: NA  
**S1.11**  
DRAWING NUMBER: C  
REVISION: C  
STATUS: FINAL DESIGN SUBMITTAL  
RELEASED FOR BID



1 - DETAIL - TRUSS "2" & COL. LINE "10.3" FRMG.  
SCALE: 1/4" = 1'-0"



2 - DETAIL - TRUSS "2" & COL. LINE "10.3" FRMG.  
SCALE: 1/4" = 1'-0"

NOTES:

- IN GENERAL REPAIR OF THE EXISTING STRUCTURAL STEEL TRUSSES AND THE SECONDARY EXTERIOR WALL BEAMS INVOLVES REPAIRS TO INTERIOR VERTICAL, HORIZONTAL & DIAGONAL SURFACES OF THE TRUSSES, COLUMNS, CONNECTION PLATES OR ANGLES, BASE PLATES AND ANCHOR BOLTS AND HARDWARE. IN GENERAL REPAIR WORK INCLUDES THE FOLLOWING:
  - REMOVING EXISTING COATINGS TO BARE METAL.
  - REMOVING SURFACE RUST OR THRU WALL RUST AND CLEANING SURFACES TO BARE METAL.
  - PREPARING BARE METAL SURFACES TO SSPC-SP6 'COMMERCIAL BLAST CLEANING' CRITERIA.
  - WELDING NEW STEEL PLATE OR ANGLE SECTIONS TO THE EXISTING STEEL SECTIONS.
 REGARDING FIELD WELDING AND PREPARATION TO SSPC-SP6 CRITERIA, THE MAXIMUM BASE METAL TEMPERATURE AT DEMARCATION BETWEEN BRIGHT METAL AND THE EXISTING COATINGS TO BE CONFIRMED w/ THE USE OF 182° F TEMPLSTIK'S BETWEEN WELD PASSES.
- INSTALL NEW COATING SYSTEM ON THE REPAIRED AREAS TO MATCH
- CODE FOR UTILIZING TRUSS CONNECTION LOCATIONS MARK NUMBERS AS FOLLOWS:
  - COL. ID EW DIRECTION - COL. ID N/S DIRECTION - TRUSS TYPE - ELEVATION ABOVE BASE PLATE.
  - COORDINATE w/ TRUSS ELEVATIONS DWG.'S S-1.01 & S-1.02 FOR HEIGHT CODES 0 TO 5.
  - COORDINATE w/ THE 'TRUSS CONN. LOCATION MK. # LEGEND EXAMPLE' DWG. S1.10 FOR ADDITIONAL INFORMATION.

- NOTES CTD. ...
- REGARDING VERIFYING CONDITION OF EXISTING STEEL, NOTE THE FOLLOWING:
    - DURING SITE VISITS NOT ALL AREAS OF THE EXISTING FACILITY COULD BE EASILY ACCESSED SAFELY w/ THE LIFT.
    - CONTRACTOR TO VERIFY IF EXISTING STEEL SECTIONS NOTED EXHIBITING SIGNS OF RUST, CORROSION OR LOSS OF COATING.
    - NOTIFY ENGINEER OF AREAS THAT ARE CURRENTLY INDICATED BUT MAY DISPLAY RUST, CORROSION, AND / OR COATING PEELING OR LOSS FOR DIRECTIONS HOW TO PROCEED.
  - COORDINATE w/ DETAILS REFERENCED FOR ANGLE / PLATE LAYOUT DIM.'S & WELD REQ.'S, U.N.O..
  - IF COATING REMOVAL YIELDS SURFACE PITTING GRIND SMOOTH & TO SURFACE PREP. REQ.'S.
  - PLATE OR ANGLE ASSEMBLIES NOT REQUIRED PROVIDED REMOVAL OF THE EXISTING COATING / CORROSION & SURFACE PREP DOES NOT YIELD UNEXPECTED RESULTS & REPAIRS CANNOT BE INSTALLED AS NOTED.
  - REMOVE & REINSTALL EXIST. WINDOW GLASS & FRAME TO REPAIR IF REQ'D.
  - THE W12 COL.'S INSTALLED w/ ADDITIONAL STEEL SECTION @ THE I/F OF THE W12 EXTR. FLANGE. RECORD DWG.'S REVIEWED COULD NOT CONFIRM THE SECTION. SITE VISIT REVIEW APPEARED TO INDICATE (2) L6x3 SECTIONS INSTALLED w/ (1) L6x3 EACH SIDE OF THE WEB. FIELD VERIFY AS REQ'D & NOT SHOWN ELEVATIONS FOR CLARITY. REFERENCE DETAIL 5-S1.11 FOR CLARITY.

- NOTES CTD. ...
- SYMBOL ON DRAWING INDICATES MARK NO. FOR BASE PLATE REPAIRS. REFERENCE DRAWING S-1.09 'KEY NOTES - COLUMN BASE PLATE REPAIRS' AND APPLICABLE SECTIONS & DETAILS AS REQUIRED.
  - REFERENCE DWG. S0.00 FOR ADDITIONAL GENERAL NOTES, MATERIAL SPECIFICATIONS & REQUIREMENTS, DESIGN CRITERIA AND LEGEND.

ESTIMATED BILL OF MATERIALS ... S1.12

ITEM #	COMPONENT	DESCRIPTION	QTY.	NOTES
01	BENT PLATE	0'-0 5/8" x 0'-0 3/8" x 3 1/2"	4	
02	BENT PLATE	0'-9" x 4" x 1/2"	1	
03	FILLET WELD	3/16" EFF. THROAT	25'	
04	FILLET WELD	3/16" EFF. THROAT	140'	
05	FLARE BEVEL WELD	PARTIAL PEN.	10"	

REV. NO.	DESCRIPTION	DATE
C	FINAL DESIGN - RELEASED FOR BID	23 MAY 2022
B	FINAL DESIGN - FINAL REVIEW NOT FOR CONSTRUCTION	09 MAY 2022
A	100% DESIGN - NOT FOR CONSTRUCTION	18 MAR 2022

REVISIONS

WILLIAM F. BAND, P.E.  
No. 67836

1365 Hamlet Avenue  
Clearwater, Florida 33756-3331  
Phone: (727) 442-7196, Fax: (727) 461-3827

CA Lic. No. 29588  
www.mckimcreed.com

BRIGHT AND BEAUTIFUL BAY TO BEACH

**LONG CENTER NATATORIUM  
STRUCTURAL FRAME REPAIRS**

STRUCTURAL

**EXIST. BLDG. A TRUSS CONDITIONS &  
REPAIRS (SHT. 10 OF 11)**

PROJ. START DATE: 2021.NOV	SCALE	<b>S1.12</b>
MCE PROJ. # 00992-0261	HORIZONTAL: AS NOTED	
DRAWN WFB	VERTICAL: NA	DRAWING NUMBER
DESIGNED WFB		C
CHECKED WFB / AEA		REVISION
PROJ. MGR. AAM		

STATUS: **FINAL DESIGN SUBMITTAL  
RELEASED FOR BID**



**LONG CENTER NATATORIUM**  
**1501 N BELCHER RD, CLEARWATER, FL 33765****HVAC DESIGN REPORT****DECEMBER 12, 2023****1.0 Purpose**

The existing Long Center Natatorium is in need of a renovation. The existing HVAC systems have surpassed their life span and are not operating properly. Recurring condensation on the interior of the glass walls is corroding the exterior wall steel frame structure. The Owner, the City of Clearwater, is considering two renovation options:

- Option 1: Remove the existing window glass, rehab the existing steel frame structure, build a new thermally-broke glass curtain wall structure on the exterior side of the existing steel frame, and provide all new HVAC systems.
- Option 2: Remove the existing window glass, rehab the existing steel frame structure, build new solid exterior walls with reduced glass area on the exterior side of the existing steel frame, and provide all new HVAC systems.

Emerald Engineering, Inc. has been commissioned by Wannemacher Jensen Architects, Inc. to provide a preliminary HVAC design and run an energy model for both options. This information will then be used in a life cycle cost analysis to determine which option is the most economical over the anticipated life span of the building.

This report documents our analysis and findings.

## **2.0 Option 1 HVAC Design**

Below is a brief rendering of the architectural design for Option 1. Please refer to Wannemacher Jensen Architect's reports and drawings for more information. We understand the new glass curtain wall structure will be completely thermally-broke from the existing steel structure, so that the outside temperature will not transfer to the inside steel and cause condensation (and eventually corrosion of the steel). The new glass values are Winter U-Value 0.24, Summer U-value 0.20, and Solar Heat Gain Coefficient 0.22.



The following are our HVAC design considerations:

- Large pool is kept at 80 degrees F
- Small pool is kept at 90 degrees F
- Interior design temperature of 82 degrees F (two degrees above large pool temperature)
- Interior design humidity of 55% RH
- Provide a minimum of 6 air changes per hour (ACH)
- 400 people in the pool area
- Additional 100 people in the spectator area

According to our HVAC load calculations, Option 1 will require two roof mounted de-humidifiers (approximately 70 tons each, 35,000 CFM of supply air each, and 19,000 CFM of outside air each) and two supply fan recirculating units (20,000 CFM each). The supply fan units do not contain cooling or heating elements; they are only used to provide the additional recirculation of air to achieve 6 ACH.

Refer to **Appendix A** for cut sheets and schedules of these four HVAC systems.

All four HVAC systems shall be mounted on the roof of the natatorium on a steel structure that is isolated to restrict transfer of vibration and noise from the units to the building. Main ductwork shall be roof mounted and drop down into the natatorium. Interior ductwork wrapping around the perimeter of the pool shall be exposed ductsox, to avoid corrosion.

Refer to **Appendix B** for a sketch of the HVAC system layout.

The equipment budget for the HVAC system is \$1.3 million. This only includes the equipment and not installation, ductwork, piping, controls, etc.

### **3.0 Option 2 HVAC Design**



Above is an architectural rendering of Option 2 provided by Wannemacher Jensen Architects. See their documentation for more information. The exterior glass area has been reduced.

We have modeled this Option 2 building in our HVAC load calculation software and determined that it will not reduce the HVAC equipment sizes from Option 1. The tonnage of the equipment is based largely on the pool's latent heat load (moisture removal load) and air exchanges. Both of those are the same in Option 1 and Option 2. A reduction of the exterior glass only reduces the sensible load (radiated heat load), and not by enough to reduce the overall tonnage of the equipment. The glass being specified has excellent insulation performance.

Therefore the HVAC systems for Option 2 match that of Option 1. Please refer to **Appendix A** for cut sheets and schedules of the four HVAC systems and **Appendix B** for a sketch of the HVAC system layout.

The equipment budget for the Option 2 HVAC systems is \$1.3 million. This only includes the equipment and not installation, ductwork, piping, controls, etc.

#### **4.0 Energy Model Results**

Separate energy models were completed for Option 1 and Option 2 using the same HVAC system, but different architectural building designs (the reduction in exterior glass). Refer to **Appendix C** for Option 1 and **Appendix D** for Option 2.

The comparison shows that the HVAC system in Option 2 used about 15% less energy than the HVAC system in Option 1 over the course of a year. This equates to about \$20,000 per year in energy cost savings.

It should be noted that these energy models include many assumptions, such as a blended energy rate, operating hours, lighting load, occupancy, etc. They also do not include plug loads (such as receptacles, computers, etc.), pool equipment loads (pumps, pool lights, etc.), or any other portion of the building except for the natatorium. Therefore, these energy costs cannot be compared to current energy bills or be used to predict future energy bills. The energy models have been constructed solely to determine the difference in energy consumption due to the difference in glass areas between the two options.

Please feel free to call me if you have any questions.

Sincerely,



**Michael Costello, PE**  
Director of Mechanical Division



9942 Currie Davis Dr., Ste. H  
Tampa, FL 33619  
813.995.0300  
emeraldme.com  
FL EB # 0027845

## **APPENDIX A**



## SELECTAIRE PLUS™ SERIES DEHUMIDIFIERS

# Next Generation Latent Enhancement Systems for Large Natatoriums & Water Parks




Natatoriums



Water Parks



School Aquatic Facilities



Desert Aire's patent pending SelectAire Plus™ (SP Series) dehumidification systems offer you complete humidity control solutions for large indoor pool applications and water parks. Building on our years of design, manufacture and applications expertise of natatorium-specific equipment, Desert Aire developed the SelectAire Plus™ Series to provide industry leading performance, efficiency and value. The SelectAire Plus™ Series incorporates the original SelectAire™ System energy recovery technology and adds features for applications that require the superior cabinetry, state-of-the-art fan design and next-generation control features for enhanced setup and serviceability. Best of all, an industry exclusive wrap-around heat pipe enhances the moisture removal capacity and efficiency of SelectAire Plus™ Series dehumidifiers, getting more work out of less energy throughout the year.

### MAJOR FEATURES AND BENEFITS

- Unique dual circuit design with enhanced dehumidification section and a separate enhanced cooling and energy recovery section is an industry-leading exclusive

- SelectAire Energy Recovery recovers more exhaust air energy than any other technology
- Automated control of ventilation air and exhaust air protects the occupants and the building
- Direct Expansion Technology with scroll compressors provides more dehumidification and higher energy efficiency than units with secondary glycol loops
- New optional air-cooled packaged and integrated gas heating solutions simplify installations
- Backward inclined airfoil plenum fans for both supply and exhaust are matched to the specific airflow and static pressure requested for the highest efficiency. All fans include electronically commutated (EC) motors or AC motors with variable speed drives in a fan-wall configuration

OPTIMIZING SOLUTIONS THROUGH SUPERIOR DEHUMIDIFICATION TECHNOLOGY



- 2" double-wall injected foam cabinet with hinged access doors ensure sealing even against high static pressure and provides excellent serviceability
- Single piece designs for large units and sectioned system options make installation simple - indoors or out

## ENHANCED LATENT DESIGN

SelectAire Plus™ Series uses a unique dual-circuit design to maximize the dehumidification capacity. A wrap-around heat pipe on one of the circuits enhances the moisture removal capabilities of the evaporator coil. The nature of the wrap-around heat pipe also tempers the air as it leaves the coil. This provides a more neutral leaving air condition and minimizes temperature fluctuations and drafts in the poolroom.

When warm air passes over the heat pipe assembly, the refrigerant within the heat pipe vaporizes, carrying heat to the second section of heat pipe assembly placed downstream. Because some heat has been removed from the air before encountering the evaporator coil, the incoming air stream section is called the pre-cool heat pipe.

Air entering the evaporator coil is assisted to a lower temperature, therefore coming closer to saturation and resulting in greater condensate removal by the coil. The "over-cooled" air is then reheated to a desirable temperature by the reheat heat pipe section, using the heat transferred from the pre-cool heat pipe. This entire process of pre-cool and reheat is accomplished with very little additional energy use.




Figure 1 - SelectAire Plus™ Series unique enhanced latent design with heat pipe assembly

The improved efficiency of this section is extremely important since most pools are inactive for a majority of their operating hours. This means only half of the capacity of the dehumidifier needs to be used. In addition cold, dry winter air also reduces the moisture loads of occupied active pools during much of the year. Thus a dehumidifier that maximizes its moisture removal efficiency for the majority of operating hours will yield the lowest operating cost system. This circuit on the SelectAire Plus™ Series will be approximately 25% more efficient than a conventional natatorium dehumidifier without this technology.

## COOLING AND ENERGY RECOVERY

In addition to the enhanced moisture removal circuit, the SelectAire Plus™ Series features a second circuit optimized for cooling the air and recovering energy from the exhaust air. This circuit has a higher velocity over the cooling coil than the dehumidification enhanced circuit.

When there is a call for cooling only or a call for more cooling than the dehumidification-enhanced circuit is providing while operational, the cooling circuit is enabled. The operation of the circuit is further enhanced through the use of refrigeration suction pressure controls and airflow monitoring. As moisture load is reduced in the space, airflow is increased even further until the space is cooled to the setpoint. When cooling is enabled the heat absorbed when cooling the air is rejected to the pool water circuit or an auxiliary heat sink such as a condenser located outdoors.

Even the relative capacity of the individual circuits has been thoughtfully designed. Extensive field research has shown that the vast majority of poolrooms require more total dehumidification capacity than sensible cooling capacity. SelectAire Plus™ Series circuit sizes have been specifically developed to ensure that the sensible cooling load on a design day is addressed, yet efficiency is extremely high.

When heating is required the SelectAire Plus™ System shifts dampers to reroute the air through this sensible cooling coil before exhausting it. The refrigeration system also re-routes the hot gas from the compressor so that it is rejected into the supply air. In this way, a significant amount of energy is recovered from the exhaust air. Desert Aire's use of this "heat-pump" technique has no equal in the industry. Where other passive-type recovery devices including run-around glycol loops and exhaust air heat pipes have significantly reduced capacity at part-load heating conditions, the SelectAire Plus™ System has a constant capacity. This system also recovers much more heat as the energy in the exhaust air, in the form of moisture, is converted to pure air heat energy.

## INTEGRATED AND AUTOMATED VENTILATION AND EXHAUST AIR

Ventilation air is critical for occupant comfort and safety. Also, maintaining negative static pressure relative to outdoors and adjacent spaces is a critical issue for the longevity of the structure. The standard outdoor air and exhaust air in the SelectAire Plus™ System has self balancing and monitoring capability. The design of the SelectAire Plus™ System helps to automate setup by directly monitoring the outdoor airflow rate and poolroom static pressure. Up to five modes of outdoor airflow rates can be programmed and controlled: Unoccupied; Occupied; Event; Alarm; and, Purge. The static pressure in the space is automatically controlled when modes are switched.




Figure 2 - Negative static pressure in the poolroom

Static pressure, outdoor airflow and exhaust flow are directly read by personnel at the user interface. This helps to ensure that setup is done properly and with minimal effort.

## FANS

The SelectAire Plus™ fans are custom designed for the application. Automated selection software evaluates available fan and motor systems for each application to optimize cost and efficiency. All fans modulate and are automatically controlled to ensure that correct flow rates are maintained through each component, regardless of filter loading or mode changes.

All fans include high-performance backwards-inclined airfoil blades. Electronically commutated (EC) external-rotor motors or direct drive NEMA Premium efficient motors with variable speed drives are used in a fan-wall configuration.

## CABINET

The cabinet is constructed of a 2" double wall panel with superior insulating properties and fabricated to withstand pool room corrosive environments. Exterior panels are galvanized steel with powder coating and G90 galvanized with architectural paint treatment. Interior cabinet panels are G90 galvanized steel.


The cabinet has double-bypass seals on all doors for superior weather resistance and tight sealing against high static pressures. Service doors are located at all regular maintenance and inspection points. Major mechanical components are located out of the airstream for accessibility. This also ensures that any high humidity or corrosive indoor air does not affect operation or longevity.

Indoor units contain a mechanical section for major components that is outside of the airstream. Lights and service outlet for this area are standard and can be powered by a 120 VAC 15A circuit supplied by the field.


## OPERATION

Desert Aire's indoor pool dehumidifier systems are flexible in their design options. This modular concept allows each system to be customized for specific dehumidification applications. Each module type is described below.


**REHEAT ONLY ...** This is the basic option which removes moisture from the air at the evaporator coil and reheats it before returning to the space as dehumidified air.




~~**REHEAT & WATER ...** In addition to the reheat coil, a water-condensing coil is added to the refrigeration circuit. Either condenser can become the primary heat sink allowing the circuit's latent and sensible heat to be directed to a water source or returned to the air.~~



**REHEAT & AIR REMOTE CONDENSER READY...** This option offers a reheat coil and an air cooled remote condenser connection.



**REHEAT & WATER & AIR COOLED REMOTE CONDENSER READY...** This is the combination of all heat sink options. The combination is used when only a partial water heatsink is available but full capacity dehumidification is required continuously, regardless of season. This is typical for large natatoriums and water parks.



## CONTROLS & MODES OF OPERATION

Each circuit is controlled by the integral microprocessor based controller. This control system includes an easy-to read user interface. A Remote Display Terminal (RDT) may be ordered separately for remote mounting. The use of basic control and staging sequences provides great flexibility in optimizing dehumidification and energy recovery capacity. The system features control of all dehumidification functions including auxiliary heating, occupancy schedules and ventilation air. The control system also provides diagnostic readouts and alarms. Optional communication cards are offered that allow the system controller to be connected to a building automation system. Communication is offered for BACnet™ MS/TP, BACnet™ Ethernet™, LonWorks® and Modbus®.

The system automatically controls the selection of the compressor set that should be operational. This depends on the internal loads such as humidity and temperature. With completely separate exhaust and ventilation air streams, the SelectAire Plus™ Series and its integrated dampers will provide the correct solution to the ever changing demands of natatorium internal space conditions.

In the dehumidification mode the system will capture the high energy content of the exhaust air and return this energy back to the air or pool water at an industry-leading coefficient of performance (COP) approaching 5. This helps to minimize the amount of new energy required to make up the ventilation load's heating requirement.




Figure 3 - Dehumidification in Energy Recovery Mode

Many conventional dehumidifiers exhaust the air after the evaporator coil for construction convenience. The SelectAire Plus™ System strategically configures its airflow arrangement to “Select” where the exhaust air is coming from. In the cooling mode the higher enthalpy return air is exhausted before the evaporator coil thus maintaining all of the cooling performed by the evaporator and delivering this cool air to the space. In the heating mode the energy of the high enthalpy containing return air is recovered by the evaporator coil and the cool air is exhausted after the coil. Refer to Desert Aire’s Technical Bulletin 6 – SelectAire Heat Recovery System, for more details.




Figure 4 - Dehumidification in Cooling Mode

## STANDARD SP SERIES REFRIGERATION DESIGN FEATURES

- Dual, independent refrigeration circuits operate independently or simultaneously
- Heavy-duty scroll compressors located in a separate vestibule
- Maximum of 38” coil height maximizes moisture removal
- Sloped, stainless steel drain pan for each circuit
- Minimum of 8” separation between evaporator and condenser coils prevents re-evaporation
- One circuit is designed for maximized latent removal using a wrap-around heat pipe
- One circuit is designed for sensible cooling and energy recovery R-410A refrigerant

## CABINET AND CONSTRUCTION

- Base rails and supports constructed of 12-gauge galvanized steel channels
- Interior is constructed of G90 galvanized steel

## BLOWER

- Backward-inclined airfoil plenum fans
- Electronically commutated (EC) or direct drive motors
- All fans arranged in a fan array

## FILTERS

- Return Air: 4” MERV 8, pleated filters
- Outdoor Air: 4” MERV 8, pleated filters

## ELECTRICAL SERVICE

- Hinged electrical panel with separate sections for high and low voltage components
- Single point power connection for all units

## CONTROLS

- Duct or wall mount temperature and humidity sensors
- Integrated Display with an optional remote display terminal
- BAS communication options
- Built in time clock for standalone operation
- Alarm Retention

## COIL COATING

- Coil ElectroFin E-Coat to resist chemicals and corrosion

## AUXILIARY HEAT OPTIONS

- Hot water coil supplied downstream from hot gas reheat coil
- Steam coil supplied downstream from hot gas reheat coil
- Electric SCR heat supplied downstream from hot gas reheat coil
- Gas heater supplied downstream of blowers
- Control outputs for field supplied auxiliary heating devices

## INSTALLATION LOCATION

- Indoor
- Outdoor
- Rooftop

## CONDENSER (Choose per circuit)

(All circuits reject the full THR - Total Heat of Rejection)

- Packaged air-cooled condenser (outdoor units only)
- Split air-cooled remote condenser
- Water condenser for water loops or fluid cooler

## POOL WATER HEAT

- Coaxial heat exchanger for recovery of heat to pool water

## WARRANTY

- 2-year parts warranty
- ElectroFin Coated coils include 5-year parts warranty

## OPTIMIZING SOLUTIONS THROUGH SUPERIOR DEHUMIDIFICATION TECHNOLOGY

N120 W18485 Friestadt Road, Germantown, WI 53022 sales@desert-aire.com

Ph: (262) 946-7400 - www.desert-aire.com

 **WARNING:** Cancer and Reproductive Harm - [www.P65Warnings.ca.gov](http://www.P65Warnings.ca.gov)

## AUXILIARY ELECTRIC HEAT

### OPTIONAL AUXILIARY ELECTRIC HEATING OPTIONS

Desert Aire provides auxiliary electric heating options for the SelectAire Plus™ Series that are sized to meet the winter heating requirements of the outside air.

These heating elements are utilized when the air temperature in the zone drops below the customer set point.

Desert Aire sizes the heating elements to precisely match the load requirement of the system. The heaters are automatically controlled by the units microprocessor to maintain zone temperature. An SCR controller is used for the electric heat option to vary the heat output.

#### Design Specifications

The following list highlights the noteworthy features of the SelectAire Plus™ Series electric heaters:

- System Single Point Power to Dehumidifier
- NiCr 60 Corrosion-Resistant Element
- Welded Construction Using 20 MSG Galvanized Steel
- Automatic Reset High Temperature Limit Safety Switch
- Manual Reset High Maximum Temperature Limit Safety Switch
- Air Flow Pressure Switch
- Fusing as Required for Each 48 Amp Circuit
- Fused Circuits per N.E.C., UL, and CSA
- SCR modulation



Figure 1 - Detail of Electric Heating Element for SelectAire Plus™ Series Unit

**OPTIMIZING SOLUTIONS THROUGH SUPERIOR DEHUMIDIFICATION TECHNOLOGY**

N120 W18485 Friestadt Road, Germantown, WI 53022 sales@desert-aire.com

**Ph: (262) 946-7400 - www.desert-aire.com**



**WARNING:** Cancer and Reproductive Harm - [www.P65Warnings.ca.gov](http://www.P65Warnings.ca.gov)

## AUXILIARY HOT WATER HEAT

HOT WATER HEAT

### OPTIONAL HOT WATER HEATING OPTIONS

Desert Aire provides auxiliary heating options for its SelectAire Plus™ Series product line that are sized to meet the winter heating requirements of the space.

These heating elements are utilized when the air temperature in the zone drops below the customer set point. Desert Aire sizes the heating elements to precisely match the load requirement of the system. The heaters are automatically controlled by the unit's microprocessor to maintain an exact leaving air temperature. A customer supplied hot water control valve is modulated from the controller with a 0 to 10 VDC direct acting signal. Please refer to figure 1 for a typical installation.

#### HWC Design Inputs

The coil is selected for each customer's particular application based on the following criteria:

- Entering water temperature (EWT), typically between 140° F and 180° F
- Leaving water temperature (LWT), typically 20 degrees less than the EWT
- Customer specified capacity required (MBH)
- Entering air temperature (EAT), (the mix temperature of outdoor air at winter design with return air)
- Specify fluid pressure drop maximum
- Type and concentration of glycol used, if applicable

For freeze protection Desert Aire uses a capillary type temperature sensor which is attached across the downstream face of the coil. Freezestat is set at 38 deg F with an auto reset switch. If engaged the unit controls would respond by closing the outdoor air damper, wait 5 minutes and if not reset, de-energize the fan, open the hot water coil valve 100%, and log the alarm on the controller.

To size the control valve, please provide a qualified vendor the water temperature, flow rate (gpm) and the requirement for a 0 to 10VDC signal and they will select the appropriate valve to purchase.

Desert Aire offers HW valve/actuators as an option. Please consult with your Desert Aire sales representative if you wish for Desert Aire to supply this component.

Optional ElectroFin coil coating for pool environments is available.




Figure 1 - Hot Water Piping Detail

**OPTIMIZING SOLUTIONS THROUGH SUPERIOR DEHUMIDIFICATION TECHNOLOGY**

N120 W18485 Friestadt Road, Germantown, WI 53022 sales@desert-aire.com

**Ph: (262) 946-7400 - www.desert-aire.com**



**WARNING:** Cancer and Reproductive Harm - [www.P65Warnings.ca.gov](http://www.P65Warnings.ca.gov)

### ElectroFin® E-coat Coil Coating

Desert Aire has partnered with Luvata ElectroFin for its coil coating because of its superior performance in eliminating corrosion and fin deterioration in the pool and coastal climate applications. ElectroFin® E-coat is a water-based, flexible epoxy polymer coating process engineered specifically for HVAC/R heat transfer coils. ElectroFin® uses a PPG POWERCRON® e-coat formulation specifically designed to provide excellent edge coverage of fins with a unique polymer that controls the flow characteristics of the coating.

Benefits of ElectroFin's factory-applied electrocoating process:

- The only process that can guarantee 100% coil coverage without bridging, including enhanced fin designs
- Excellent corrosion and UV resistance make it suitable for pool room and coastal environments

Electrocoating is the process by which a metallic work piece (coil) is submerged in a paint / water bath where electricity is used to deposit paint onto it.



Figure 1 - ElectroFin® E-coat Process

#### Corrosion Resistance

In the electrocoating process, the coil assembly acts in the same way as a magnet. The coating molecules are electrically attracted to the metallic coil surfaces, meaning the entire coil is completely and uniformly coated. When we mention the entire coil we are talking about the coil fins, end plates, copper tubing and copper return bends. In other words, the coating covers the entire coil assembly. The result is a finish which provides excellent resistance to pool chemical, coastal marine (salt-air), industrial and urban environments. When properly maintained, you can expect ElectroFin® e-coated coils to provide protection for years. Desert Aire provides a 5-year coil parts warranty as evidence of its superior protection.

#### Resistance to UV Degradation

When coils are to be subjected to ultraviolet exposure such as the remote condenser, they receive a spray-applied, UV-resistant urethane mastic topcoat. As a result, UV degradation of the epoxy e-coat polymer molecules is eliminated and the film integrity is maintained. This is offered as an option for our RC Series condensers.

**Proven Effective**

The electro-deposition process is the most automatic, controllable, and efficient method for applying a corrosion inhibiting coating to a metallic work piece. The process dictates that all metal surfaces are coated in an even, uniform finish. All coil surfaces reach an average e-coat dry film thickness of 1 mil (0.001”). It meets the 5B rating cross-hatch adhesion per ASTM B3359-93. Corrosion durability is confirmed through testing to no less than 5,000 hours salt spray resistance per ASTM B117-90 using scribed aluminum test coupons.

**Comparison to Fin Stock Coatings**

Not all coil coatings are the same. Many dehumidifier companies use a fin stock coating that is applied to the aluminum stock before the coil is manufactured. This means the edges of the fin, the copper tubes and the steel header remain uncoated.



Figure 2 - Photo of a coated coil




Figure 3 - Photo of an uncoated coil

CORROSION RESISTANT COILS

**OPTIMIZING SOLUTIONS THROUGH SUPERIOR DEHUMIDIFICATION TECHNOLOGY**

N120 W18485 Friestadt Road, Germantown, WI 53022 sales@desert-air.com

**Ph: (262) 946-7400 - www.desert-air.com**



 **WARNING:** Cancer and Reproductive Harm - [www.P65Warnings.ca.gov](http://www.P65Warnings.ca.gov)

## AUXILIARY GAS HEATING OPTION

### OPTIONAL GAS HEATING MODULE

Desert Aire provides auxiliary heating options for its SelectAire Plus™ Series product line that are available in several capacities to meet the winter specified heating requirements of the space.

These heating elements are utilized when the air temperature in the space drops below the customer set point. Desert Aire sizes the heating elements to precisely match the load requirement of the system. The heaters are automatically controlled by the unit's microprocessor to maintain an exact leaving air temperature. Desert Aire controls the heater output with a 0-10VDC control signal from the dehumidifier's operating controller.

Desert Aire combines different burner sizes to precisely match the load of the system. This may be in a single heater module or in multiple modules. A modulating gas valve is automatically controlled by the unit's microprocessor to maintain an exact leaving air temperature. If multiple burner sets are utilized, then a venier sequence is used where the base burner is modulated and the others are staged. The system's overall turn down ratio is a function of the number of heating modules and is summarized in the table below:

Input Capacity (MBH)	Output Capacity (MBH)	Gas Module Qty.	Effective Turndown Ratio	Gas Connection
800	640	2	10 to 1	One 2" NPT
1,000	800	2	10 to 1	One 2" NPT
1,200	960	2	10 to 1	One 2" NPT
1,600	1,280	4	20 to 1	Two 2" NPT
2,000	1,600	4	20 to 1	Two 2" NPT
2,400	1,920	4	20 to 1	Two 2" NPT




Figure 1 - Detail of Gas Heat Compartment on SelectAire Plus™ Series Unit

AUXILIARY GAS HEAT




Figure 2 - Detail of Gas Heat Burner Assembly

The gas module shall provide a minimum combustion efficiency of 80%, and listed for operation downstream of refrigeration or cooling system, and provide means for removal of condensate that occurs in the heat exchanger during cooling operation. They are listed for outdoor installation without the need for additional power ventilation.

Heat exchanger shall be tubular in design and constructed of Type 304L stainless steel and employ (integral formed dimple restrictors, formed turbulators) and provide for an unobstructed drainage path for condensate and provide a positive pitch to promote drainage.

Additionally the gas module shall employ:

- Patented inshot gas burners, with integral carryovers, capable of operation at 5:1 turndown with modulating controls
- A combustion blower to provide for positive venting of flue gases
- Pressure switch to prove air supply for combustion
- Direct spark ignition of gas burners with remote flame sensor to prove carryover across all burners
- An automatic reset type high limit switch to limit maximum outlet air temperature to less than 250° F
- Manual reset flame rollout switch
- Listed Combination Gas Valve incorporating redundant safety shut-off valve, manual shut-off , and gas regulator which regulates gas pressure to burner supply manifold.
- Direct Spark ignition control design certified by a Recognized National Testing Laboratory and incorporating a LED diagnostic light and alarm capable contact

The completed heater assembly shall be factory fire tested prior to shipment.

AUXILIARY GAS HEAT

**OPTIMIZING SOLUTIONS THROUGH SUPERIOR DEHUMIDIFICATION TECHNOLOGY**  
N120 W18485 Friestadt Road, Germantown, WI 53022 sales@desert-aire.com

**Ph: (262) 946-7400 - www.desert-aire.com**



 **WARNING:** Cancer and Reproductive Harm - [www.P65Warnings.ca.gov](http://www.P65Warnings.ca.gov)

**Exhaust Air Integration - Duct Mount**

Desert Aire's SelectAire Plus™ natatorium dehumidifier can vary the volume of outside air and exhaust air based on the level of contaminants within the pool room. The key to this integration is the use of a Volatile Organic Compounds (VOC) sensing element that can detect when interior levels of chemicals are present such as chloramines. This provides a similar methodology as the use of CO<sub>2</sub> sensors in general ventilation applications for the pool environment. Now there is the ability to optimize the volume of exhaust air required with the energy cost of doing so and insure a suitable pool environment for the occupants.

The VOC duct sensor samples duct air using an aspiration tube. Moving air from the duct enters the tube, is forced into the enclosure and exits through the other half of the tube. As long as there is air movement in the duct, air is continuously exchanged.

**Sensor Specifications**

- Power: 15 to 35 VDC @ 50 mA
- Power Sensing Element: VOCs: Micro-machined Metal Oxide Quick Response Sensor through Aspiration Tube
- Analog Outputs: 0 to 10VDC, (>10KΩ impedance)
- VOC Contaminants: 0 to 2,000 PPM CO<sub>2</sub> Equivalent
- VOC Detection Range: 0 to 100%
- Response Time: Less Than 60 Seconds
- Start-Up Time: 15 minutes
- Operating Environment: 32 to 122°F (0 to 50°C)  
0 to 95%RH non-condensing
- Dimension: 4.91"H x 3.21"W x 1.20"D  
(124.6 x 81.5 x 30.5 mm)
- Enclosure Rating: NEMA 4
- Enclosure Material: Polycarbonate, UL94 V-0
- VOC Duct Sensor
- Certifications: RoHS
- Warranty Period: Two years from manufacture date



Figure 1 - Duct Mounted VOC Sensor




Figure 2 - Duct Sensor Dimensions

### Exhaust Air Integration - Wall Mount

Desert Aire's SelectAire Plus™ natatorium dehumidifier can vary the volume of outside air and exhaust air based on the level of contaminants within the pool room. The key to this integration is the use of a Volatile Organic Compounds (VOC) sensing element that can detect when interior levels of chemicals are present such as chloramines. This provides a similar methodology as the use of CO<sub>2</sub> sensors in general ventilation applications for the pool environment. Now there is the ability to optimize the volume of exhaust air required with the energy cost of doing so and insure a suitable pool environment for the occupants.

### Sensor Specifications

Power: 15 to 35 VDC @ 50 mA

Power Sensing Element: VOCs: Micro-machined Metal Oxide

Analog Outputs: 0 to 10VDC, (>10KΩ impedance)

VOC Contaminants: 0 to 2,000 PPM CO<sub>2</sub> Equivalent

VOC Detection Range: 0 to 100%

Response Time: Less Than 2 Minutes

Start-Up Time: 15 minutes

Operating Environment: 32 to 122°F (0 to 50°C)

0 to 95%RH non-condensing

Dimension: 4.50"H x 2.86"W x 1.06"D

(114.3 x 72.7 x 26.9 mm)

Enclosure Material: ABS Plastic, UL94 V-0

Certifications: RoHS

Warranty Period: Two years from manufacture date



Figure 1 - Wall Mounted VOC Sensor




Figure 2 - Wall Sensor Dimensions

**OPTIMIZING SOLUTIONS THROUGH SUPERIOR DEHUMIDIFICATION TECHNOLOGY**

N120 W18485 Friestadt Road, Germantown, WI 53022 sales@desert-aire.com

**Ph: (262) 946-7400 - www.desert-aire.com**



**WARNING:** Cancer and Reproductive Harm - [www.P65Warnings.ca.gov](http://www.P65Warnings.ca.gov)



# CM3560 Series Controller for SP Dehumidifiers

ADVANCED COMMUNICATIONS CAPABILITIES EASY INSTALLATION AND OPERATION CONTINUOUS MONITORING

## Advanced SelectAire Plus™ Microprocessor Controller



CM3560 Controller Used on SP Series Dehumidifiers



Integral Return Temperature & Humidity Sensor



Wall Mount  
Temperature & Humidity Sensor

### FEATURES

- Standard integral return air sensor for control
- Optional wall mounted sensor
- LCD interface terminal in control panel
- Optional remote display terminal (RDT)
- Built-in cloud based remote monitoring



CM3560 Series Optional Remote Display Terminal (RDT)

### DESCRIPTION

The CM3560 controllers are uniquely programmed for each Desert Aire application providing energy efficient moisture removal and precise temperature & humidity control.

The CM3560 controller offers an easy interface with building management systems (BMS) with on-board or pre-configured gateway modules. Modbus RTU and TCP/IP are standard. BACnet® MS/TP and BACnet® Ethernet are onboard and can be activated with optional licences. A LonTalk gateway is available that can connect a LonWorks system to the controls.

A user interface to the CM3560 is supplied on each unit. This backlit LCD display provides easy to navigate screens for setpoint adjustment and unit monitoring. The optional remote display terminal can be connected to the controller and mounted at a more convenient location for user interface.

### ORDERING CODE

#### Accessories

- CA3560-WALL - Optional Wall Mount Sensor
- CA3560-OD - Optional Remote Display Terminal

All trademarks hereby referenced are the property of their respective owners.

### SYSTEM DISPLAY OPTIONS

The CM3560 controller is matched to SelectAire Plus™ Series systems based on the number of inputs and outputs; and by taking into account the accessibility of the controller and its user interface.

# CM3560 Controller for SP Dehumidifiers (cont.)

The SelectAire Plus™ Series uses the CM3560 controller with an integrated local display. The controller with local display is installed in the system electrical enclosure. All Inputs and Outputs along with alarm history can be viewed from the user interface to aid in unit or system diagnostics. When an integrated display and remote display terminal are connected to a controller, both display devices are fully functional.

## B MS COMMUNICATION

**LonWorks®**- Echelon's LonWorks® is a solution of control in industry, offices, homes and transport. The electric standard supported is FTT10. The SP dehumidifiers need to be configured with a gateway at the time of order for LonWorks® communication.

**Modbus®**- One of the most widely used protocols. The system supports Modbus Slave, RTU mode; communications standard RS485 without licenses or activation. Additionally supports Modbus TCP/IP as standard.

**BACnet® MS/TP and BACnet® Ethernet**- Based on EIA-485 and Ethernet standards. Ports are available for both BACnet MSTP and Ethernet as standard equipment, but licenses are required to be purchased at the time of order. Connection is possible through the following networks:

- SNMP v1, v2, v3 networks
- BACnet®, Ethernet, BACnet®/IP networks, BACnet® MS/TP
- LAN or Internet

## B MS COMMUNICATION - DETAILS

### BACnet® MS/TP

If the system was purchased with the BACnet MS/TP option, the BACnet Device Instance and Station Address will need to be set before connection to the control network. This is because the Station Address is set to 0 as a default, and will conflict with any device on the control network already set to 0.

Defining the station address prior to system shipment will allow Desert Aire to correctly set the address. If the value is not known prior to shipment, then the contractor must alter these default settings during system commissioning. A software utility program will need to be used, allowing access to these settings. For more information, refer to the controller manual shipped with the dehumidifier. Download the system BACnet Point List from the Desert Aire website ([www.desert-aire.com](http://www.desert-aire.com)).

### BACnet® Ethernet

If the system was purchased with the BACnet® Ethernet option, the licenses have been activated in the controller and the Ethernet port

can be used for connection to the BACnet network immediately. For the correct operation of the Ethernet network, a number of basic parameters need to be set, such as the IP address and Netmask. Each device connected to an Ethernet network must have a unique IP address.

The Ethernet port on the controller is set for DHCP. Therefore, in a network served by a DHCP server, the controller will automatically acquire the necessary parameters without requiring configuration. In the case of a network without DHCP, these parameters need to be configured manually. For more information, refer to the controller manual shipped with the dehumidifier. Download the SYSTEM BACnet Ethernet Point List from the Desert Aire website ([www.desert-aire.com](http://www.desert-aire.com)).

### LonWorks®

If the system was purchased with the LonWorks option, the unit will contain a gateway that allows for communication to the LonWorks network. Documentation, including points list and connection information will be included with the dehumidifier.

### Modbus®

If the Modbus network is to be used, the network address needs to be set in the controller for proper communication operation. If Modbus® RTU is used, a baud rate must also be specified.

Refer to the system controller manual for address and baud rate setting instructions. For more information, refer to the controller manual shipped with the dehumidifier. Download the Modbus® Point List from the Desert Aire website ([www.desert-aire.com](http://www.desert-aire.com)).

### AireGuard™ Remote Monitoring Tool

The SP Series controller is equipped with an Ethernet connection to the internet. The owner must provide the Ethernet cable connection from their network router to the controller in order for data to transmit to a secure cloud storage location. A 2-year AireGuard™ subscription is included with systems shipped with this controller.

For those users with more than one dehumidifier, this configuration can act as their local building management system where all of the units are available with the same login credentials. All that is required is an Ethernet cable to be connected between your network router with internet access and the AireGuard™ interface located on the controller. The connection communicates without opening additional ports in the systems firewall or requiring a virtual private network.

Please refer to the AireGuard™ brochure for additional details.

## OPTIMIZING SOLUTIONS THROUGH SUPERIOR DEHUMIDIFICATION TECHNOLOGY

N120 W18485 Friestadt Road, Germantown, WI 53022 [sales@desert-aire.com](mailto:sales@desert-aire.com)

Ph: (262) 946-7400 - [www.desert-aire.com](http://www.desert-aire.com)



**WARNING:** Cancer and Reproductive Harm - [www.P65Warnings.ca.gov](http://www.P65Warnings.ca.gov)



# SelectAire Plus™ Dehumidifiers

---

## SEQUENCE OF OPERATION

---

**Supply Blower Runs Continuously.**

### **CIRCUIT HEAT SINK CONFIGURATION:**

Compressor Starts On a Call for dehumidification and or cooling. The system has two configurable circuits as follows:

**Circuit “A” Priority:** Packaged Condenser

**Circuit “B” Priority:** Packaged Condenser

### **Dehumidification**

First Stage: Circuit “A” starts and runs in respective order listed in the “Circuit Heat Sink Configuration Section”.

Second Stage: Circuit “B” starts and runs in respective order listed in the “Circuit Heat Sink Configuration Section”.

### **Cooling**

First Stage: The exhaust damper before the evaporator coils opens. Circuit “A” will start and operate with the air reheat off reject its heat to following condenser(s), in respective order, listed in the “Circuit Heat Sink Configuration Section”.

Second Stage: Circuit “B” will start and operate with the air reheat off reject its heat to following condenser(s), in respective order, listed in the “Circuit Heat Sink Configuration Section”.

### **Air Heating**

Occupied Times:

First Stage: The cold air exhaust damper (damper after evaporator) will open to maximize heating capacity. Circuit “A” will start and operate in the air reheat mode.

Second Stage: The auxiliary heater is activated by a 0-10 VDC control signal from the dehumidifier.

Unoccupied Times:

First Stage: The auxiliary heater is controlled by a 0-10VDC control signal from the dehumidifier.



# SelectAire Plus™ Dehumidifiers

---

## Pool Water Heating

### Circuit A

An auxiliary pool/spa heater dry contactor will be closed, to activate the pool heater by others.

### Circuit B

An auxiliary pool/spa heater dry contactor will be closed, to activate the pool heater by others.

## Exhaust and Outside Air

The operation of the SelectAire Plus™ system's exhaust fan is to maintain the negative pressure of the poolroom by controlling the exhaust fan motor speed using inputs from the differential pressure transducer input signal.

The dehumidifier controls the flow rate of the outdoor air in each mode by measuring the pressure differential across the calibration plate in the intake section to vary the outside air damper. This provides a direct measure of outdoor air volume.

The system provides five individual settings for outdoor air flow rates that are field programmable:

- Unoccupied – Controlled via time clock
- Occupied – Controlled via time clock
- Event – Controlled via time clock
- Max OA – Controlled via VOC sensor set point
- Purge – Controlled via contact closure

## EMERGENCY SYSTEM SHUTDOWN

Terminal points are available for a binary contact closure by others to control unit shutdown by smoke detector or other similar device. An open contact in the 24 VAC circuit will deactivate motors, fans and compressors.



# SelectAire Plus™ Dehumidifiers

---

## DEHUMIDIFIER SPECIFICATIONS

---

### Standard Unit Features

#### Enclosure:

- 2" double wall panel with injected polyurethane foam rated at R13.5
- Cabinet material
  - Exterior panels shall be galvanized steel with powder coating or G90 galvanized with architectural paint treatment
  - Base rails and supports shall be 12-gauge G90 galvanized steel channels
- Hinged access doors shall allow easy access to internal components within each section
  - Doors shall be mounted with adjustable compression cam operated latches.
  - Double sealing bypass gaskets on frame and door
- The electrical control box and switch panel is enclosed in a separate compartment, complete with a hinged door

#### Exterior Paint and Finish:

- Powder coat technique
- High yield polyester paint
- Meets 1,000 hour salt spray test
- Beige color

**Refrigerant:** R-410A

#### Compressors:

- Heavy-duty scroll-type
- Equipped with high- and low- pressure safety devices
- Externally vibration isolated

#### Receiver:

- Sized for full-system refrigerant capacity up to 50' line set
- Service ball valves included

#### Evaporator Dehumidifier Coils:

- Aluminum fins
- Copper tubes, hydraulically expanded
- One circuited with a wrap-around heat pipe for optimized moisture removal

#### Internal Air-Cooled Condenser (Reheat Coil):

- Aluminum fins
- Copper tubes, hydraulically expanded
- Coil is positioned with a minimum of 5" clearance from the DX coil to help prevent water re-evaporation



# SelectAire Plus™ Dehumidifiers

---

## Ventilation and Exhaust Air:

### SelectAire Plus™ with Auto Balancing Control:

The unit will include the SelectAire Plus™ Energy Recovery Ventilation Air and Exhaust Assembly with up to 50% of the supply air volume for ventilation air. Exact amount of ventilation and exhaust air is as listed on the specification schedule.

The integral control system will maintain the correct proportions of return air, supply air, exhaust air and ventilation air. The system will monitor the static pressure difference at three locations; the ventilation air intake, evaporator coil and the zone vs ambient.

By monitoring the pressure differential across the ventilation air orifice plate, the unit controller will modulate the ventilation air damper to ensure the correct amount of ventilation air during occupied times. The amount of ventilation air can be set through the unit controller.

The system will monitor the pressure differential across the evaporator coil and will modulate the evaporator by-pass damper to ensure the proper amount of evaporator cfm; therefore, optimizing the moisture removal capacity of the system at all times.

The system will monitor the pressure difference between the zone pressure and the ambient pressure once the initial field air balance has been completed and setup values entered into the controller. This will vary the exhaust fan volume via the fan motor speed to help guarantee the negative pressure within the space.

The exhaust fan includes a velocity pressure measurement transducer that allows direct readout of the current exhaust fan flow rate and an adjustable maximum flow rate for each occupancy mode.

### SelectAire Plus™ Recovery System:

The unit will be supplied with an integral fresh air/exhaust air heat recovery system for introduction of outside air, to comply with ASHRAE Ventilation Standards 62.1 and local health codes.

The exhaust air can be exhausted either before or after the evaporator coil, providing the ability to extract energy from the return air if heating is required. The control decision will be determined by the controls heating and cooling set points.

On a call for heating, it is desirable to extract as much heat as possible from the exhaust air. Energy is recovered from the exhaust air by first passing it through the circuit "A" evaporator coil in a cooling / heat pump operation. The cooled air is exhausted and the "Heat Pipe" energy plus the heat of rejection is returned to the air stream. The minimum COP of this operation is 4.0.

On a call for cooling, warm return air from the space is exhausted before the evaporator coil when it is desirable to remove as much heat as possible from the building. The refrigeration system serves to dehumidify and/or air condition the return air from the space.



# SelectAire Plus™ Dehumidifiers

---

Exhaust will be provided with plenum fan(s) and motor(s) in direct drive arrangement on a frame independent of the unit base, properly sized for all exhaust modes listed in the unit schedule.

The ventilation air is brought in through the integral plenum and mixed with the bypass airstream. The air shall be filtered by 4" extended surface type filters with a minimum MERV 8 rating. A motorized, proportional control damper assembly shall be used.

The warm exhaust, cold exhaust, and ventilation air dampers each will be a motorized, proportional control type.

In addition, a motorized, proportional damper assembly will be included to bypass the evaporator coils to ensure proper face velocity and system efficiency in all occupancy modes of operation.

The controller will automatically adjust these dampers to maintain the specified flow rates (R/A, O/A and E/A) through the use of integral flow measurement devices.

The SelectAire Plus™ heat recovery system will use the "heat pump" principle to recover energy on a call for heating by operating one of the dual refrigeration circuits in conjunction with exhaust air.

The unit shall be supplied with an outdoor rain hood and bird screen.

## **Electrical Control Panel:**

- Easily accessible on one side
- Single point power connection to serve controls, fans, electric auxiliary heater (if provided)
- Rated in compliance with NEC® 110.10 and UL 1995

## **Control System:**

- A digital control system using a 16 bit microprocessor
- Three (3) levels of password protection
- Easy-to-read display which indicates actual operating and set points
- The display will be remote mountable up to 1,640 feet from the unit
- Built-in occupancy timer

## **Temperature Sensor:**

- The unit includes a temperature sensor to be field installed on the wall

## **Relative Humidity Sensor:**

The unit includes a relative humidity sensor to be field installed on the wall

## **Airflow Switch:**

- The dehumidifier is equipped with an airflow switch to prevent the compressors from starting or operating on loss of airflow.

## **Refrigerant Pressure Transducers:**



# SelectAire Plus™ Dehumidifiers

---

- The dehumidifier shall have internal transducers for monitoring refrigerant pressures

## **Condensate Drain Pan:**

- 20-gauge stainless steel, sloped, and positioned under the dehumidifier coil
- Fitted with a minimum 1" MPT non-corrosive plastic drain connection

## **Dampers and Damper Actuators:**

Dampers controlling outdoor air or separating the exhaust air from recirculating air to be low leakage thermally insulated galvanized airfoil blade dampers blades and frame.

Control dampers for bypass air will be galvanized airfoil blades and frame. Linkage to consist of plated steel and axle with synthetic bearings.

All damper actuators will be proportional control connected to unit microprocessor and positions adjusted automatically based on sequence of operation. All fasteners, brackets and shaft clamps will be plated steel.

## **Supply Fan:**

Supply fan will either be a plenum fan array with direct drive EC motors or a single plenum airfoil fan with VFD controlled motor.

- All bearings are selected for a minimum of a L50 Lifetime of 100,000 hours
- All fans shall be dynamically and statically balanced
- Blower Discharge: The unit's air discharge will be as shown on the drawing

VFD Option: The fan housing shall be made of galvanized steel. The high performance impeller is manufactured in corrosion resistant steel, with backward curved, true airfoil shaped blades, welded into position. All wheels are coated with an anticorrosive primer and a final layer of synthetic paint. The driver pulley and the blower pulley will be made of cast iron. The motor sheave will be a variable pitch type to allow for field adjustment of CFM and external static. VFD controller located out of air stream to control motor's speed.

## **Exhaust Fan:**

Exhaust fan will either be a plenum fan array with direct drive EC motors or a single plenum airfoil fan with VFD controlled motor.

VFD Option: The fan housing shall be made of galvanized steel. The high performance impeller is manufactured in corrosion resistant steel, with backward curved, true airfoil shaped blades, welded into position. All wheels are coated with an anticorrosive primer and a final layer of synthetic paint. The driver pulley and the blower pulley will be made of cast iron. The motor sheave will be a variable pitch type to allow for field adjustment of CFM and external static. VFD controller located out of air stream to control motor's speed.

## **Return Air Filters:**

- Return air will have a 4", pleated MERV 8 disposable filters
- Optional Return air filters are washable aluminum
- Outside air, when supplied with the Full OSA Assembly, will have a 2", extended surface MERV 7 filters



# SelectAire Plus™ Dehumidifiers

---

## Approvals/Listings:

- The unit is labeled and listed by ETL or UL

## Selected Unit Options

### Unit Location:

- The unit shall be designed for outdoor (concrete slab or equipment rail) installation

**Disconnect:** Not Selected

## Selected Refrigeration Options

### ElectroFin® E-Coating:

- All airside coils protected with ElectroFin® E-Coat. The Electro-deposition process applies a dry film thickness 0.6 to 1.2 mils which meets 6,000 hour salt spray test

### Packaged Condenser:

The dehumidifier shall be equipped with an integral, full-size, air-cooled condenser to reject excess heat to the outside. The system shall be able to reject all the recovered heat (T.H.R.) outdoors.

- Aluminum fins
- Copper tubes, hydraulically expanded
- Axial condenser fans shall be of one-piece construction with an integral motor
- Fan Cycling: Fans shall be cycled based on internal head pressure
- Fan Guards: Guards shall be heavy-gauge, close-meshed steel wire with vinyl coating
- E-Fin Coating installed

## Auxiliary Heater Options

### Electric Heater:

The capacity shall be in accordance with the schedule. The heater shall be integral to the unit and wired to the unit as a single point power connection.

The heater coils shall be constructed of High Grade Nickel-Chrome alloy and will be insulated by floating ceramic bushings from the galvanized steel frame.

## Control System Options

### BMS Compatibility:

The unit's controller will have the following BMS compatibility: BACnet MS/TP

## Other Options



# SelectAire Plus™ Dehumidifiers

---

## SYSTEM WARRANTY

---

### Dehumidification Equipment Standard Limited Warranty

---

Desert Aire warrants the dehumidifying unit to be free from defects in materials and workmanship subject to the terms, conditions and limitations stated herein.

#### TERMS

Desert Aire warrants all components (except as noted) for a period of two (2) years from the date of shipment. This warranty shall be limited to the supply of new or rebuilt parts for the part which has failed because of defects in workmanship or material, and does not include the cost for labor, transportation or other costs not herein provided for. Replaced parts are warranted only for the remaining portion of the original warranty period.

#### CONDITIONS

**The warranty is subject to the following conditions:**

1. The unit must be properly installed and maintained in accordance with the Desert Aire "Installation and Operation Manual" provided with each unit and/or other documentation provided.
2. The Start-Up Report must be completed and returned to Desert Aire within 30 days of the start-up.
3. This warranty shall not apply to any part that has been tampered with, or has been subject to misuse, negligence or accident. A warranty can be obtained for altered equipment but only with written consent from Desert Aire.
4. The following parts and components are excluded from the warranty: belts, filters, driers, fuses and refrigerant.
5. Refrigerant coils or other components that corrode due to improperly balanced pool chemistry or corrosive air quality will not be warranted.
6. All replacements or repairs will be FOB Germantown, WI.
7. This warranty shall be null and void if defects or damages result from unauthorized opening of the refrigerant circuit, tampering with factory set controls, or operating outside the original design conditions.
8. Desert Aire shall not be liable for labor costs incurred in diagnosing the problem, or the removal or replacement of the part or parts being repaired.
9. Desert Aire must preauthorize all warranty coverage described herein.



## SelectAire Plus™ Dehumidifiers

---

### **Extended Warranty:**

Your Desert Aire unit may have extended warranties beyond this Standard Limited Warranty document. Extended warranties are only available at the time of the purchase of the original equipment. These extended warranties are covered under a separate document and their terms and conditions are separate from this document. It is mentioned in this document for informational purposes only.

*Any and all incidental or consequential damages are expressly excluded from this warranty. Some states do not allow the exclusion of incidental or consequential damages for personal injury, so the above limitations may not apply to you for certain damages. This warranty gives you specific legal rights, and you may also have other rights, which vary from state to state. No person or representative is authorized to make any warranty or assume any liability not strictly in accordance with the aforementioned.*

Inquiries regarding warranty matters should be addressed to:

Desert Aire LLC  
c/o Service Manager  
N120 W18485 Freistadt Road  
Germantown, WI 53022

PH: (262) 946-7400

FAX: (262) 946-7401

E-MAIL: [service@desert-aire.com](mailto:service@desert-aire.com)



# SelectAire Plus™ Dehumidifiers

---

## Dehumidification Components Optional Extended Warranty

---

Desert Aire warrants the following components to be free from defects in materials and workmanship subject to the terms, conditions and limitations stated on the standard warranty form. (Provided if Displayed)

### **COMPRESSOR THREE (3)-YEAR EXTENDED WARRANTY TERMS**

For an additional fee (contact your local representative for cost), Desert Aire offers an extended three (3)-year warranty for compressors. This extended warranty begins after the system's standard two (2)-year warranty ends. This warranty will be limited to the supply of new or rebuilt parts for the part which has failed because of defects in workmanship or material, and does not include the cost for labor, transportation or other costs not herein provided for. Replaced parts are warranted only for the remaining portion of the original warranty period.

### **COIL THREE (3)-YEAR EXTENDED WARRANTY TERMS**


For an additional fee (contact your local representative for cost), Desert Aire offers an extended three (3)-year warranty for coils. Upon special request, the coils will be coated with an Electro Fin® E-Coating. This extended warranty is only available for coated coils and begins after the system's standard two (2)-year warranty ends. This warranty will be limited to the supply of new or rebuilt parts for the part which has failed because of defects in workmanship or material, and does not include the cost of labor, transportation or other costs not herein provided for. Replaced parts are warranted only for the remaining portion of the original warranty period. Extended warranties do not apply to remote condenser coils.

### **COIL EIGHT (8)-YEAR EXTENDED WARRANTY TERMS**


For an additional fee (contact your local representative for cost), Desert Aire offers an extended eight (8)-year warranty for coils. Upon special request, the coils will be coated with an Electro Fin® E-Coating. This extended warranty is only available for coated coils and begins after the system's standard two (2)-year warranty ends. This warranty will be limited to the supply of new or rebuilt parts for the part which has failed because of defects in workmanship or material, and does not include the cost for labor, transportation or other costs not herein provided for. Replaced parts are warranted only for the remaining portion of the original warranty period. Extended warranties do not apply to remote condenser coils.

GENERAL NOTES FOR APPLICABLE SHEETS:


LEFT HAND ACCESS SHOWN IN ALL VIEWS  
 RIGHT HAND ACCESS OPTIONS LOCATED WITH SAME DIMENSIONS ON OPPOSITE SIDE UNLESS OTHERWISE SPECIFIED  
 WEIGHTS SHOWN REFLECT FULLY OPTIONED ESTIMATED UNIT WEIGHT



LEFT SIDE VIEW



BACK VIEW



454 5/16"  
(OVERALL LENGTH)

421 5/16"  
(BASE LENGTH)

OUTDOOR AIR  
INTAKE HOOD

INTAKE  
AIRFLOW

UNIT SIZE	ESTIMATED WEIGHT (lbs.)
60 - 80 TONS	18500

Desert Aire has a policy of continuous product and quality improvement. Specifications and dimensions are subject to change without notice. This drawing and information contained herein are the exclusive property of the Desert Aire Corporation. Any use detrimental to the interests of Desert Aire is prohibited.

All Dimensions in Inches  
 All Angles 90°  
 All outside corners 0.125" fillet  
 Unless Otherwise Specified

Tolerance Unless  
 Otherwise Specified  
 X.X ±.125  
 X.XX ±.060  
 X.XXX ±.030  
 Angles ±1°



N120 W18485 FREISTADT RD  
 GERMANTOWN, WI 53022  
 Tel: (262) 946-7400  
 Fax: (262) 946-7401




Third Angle Projection

Part weight

Drawn	ASV	Date Released	1/19/2018	Description	SP 60-80 TON PKG ELECT HEAT	
Sheet	1/8			Page Title	GENERAL ARRANGEMENT	
Scale	NTS		Rev.	5	Drawing Number	G1000-011

ALL DIMENSIONS ARE IN INCHES  
 TOLERANCE ± 1/8"

CUSTOMER CONNECTION LINE SIZE (in.)		
UNIT SIZE	60 TONS	70-80 TONS
CONDENSATE (PVC)	1 1/2	1 1/2
POOL WATER LINE CIRCUIT A (CPVC)	2	3
POOL WATER LINE CIRCUIT B (CPVC)	3	3





BACK CONNECTIONS VIEW  
(NO ORIENTATION CHANGE FOR RH OR LH ACCESS)

LEFT SIDE CONNECTION VIEW  
(LEFT HAND ACCESS SHOWN)

BACK POOL WATER CONNECTION LOCATION OPTION  
(NO ORIENTATION CHANGE FOR RH OR LH ACCESS)

SIDE ELECTRICAL CONNECTION LOCATION OPTION  
(NO ORIENTATION CHANGE FOR RH OR LH ACCESS)



NOTES:  
REFER TO SHEET 1 FOR GENERAL NOTES  
LEFT HAND ACCESS SHOWN IN ALL VIEWS  
RIGHT HAND ACCESS OPTIONS LOCATED WITH SAME DIMENSIONS ON OPPOSITE SIDE UNLESS OTHERWISE SPECIFIED


Desert Aire has a policy of continuous product and quality improvement. Specifications and dimensions are subject to change without notice. This drawing and information contained herein are the exclusive property of the Desert Aire Corporation. Any use detrimental to the interests of Desert Aire is prohibited.	All Dimensions in Inches All Angles 90° All outside corners 0.125" fillet Unless Otherwise Specified	Tolerance Unless Otherwise Specified X.X ±.125 X.XX ±.060 X.XXX ±.030 Angles ±1°	N120 W18485 FREISTADT RD GERMANTOWN, WI 53022 Tel: (262) 946-7400 Fax: (262) 946-7401
ALL DIMENSIONS ARE IN INCHES TOLERANCE ± 1/8"	Third Angle Projection	Sheet: <b>2/8</b>	Page Title: <b>CUSTOMER INTERFACE GA</b>
		Scale: <b>NTS</b>	Rev: <b>5</b> Drawing Number: <b>G1000-011</b>

FILTER INFORMATION


UNIT SIZE	OA QTY	OA SIZE	REPLACEMENT PART NUMBER	RA QTY	RA SIZE	REPLACEMENT PART NUMBER
60-80 TONS	15	18 X 24 X 4	870-056	15	18 X 24 X 4	870-056

G1000-011


HORIZONTAL RETURN AIR OPTION  
(INTAKE VIEW)



SIDE RETURN AIR OPTION  
(SIDE VIEW)



BOTTOM RETURN AIR OPTION  
(VIEW FROM ABOVE)



NOTES:  
REFER TO SHEET 1 FOR GENERAL NOTES  
HOODS REMOVED FOR CLARITY  
ACCESS SIDE RETURN AIR OPTION WILL SHIFT FILTER SECTION DOORS TO NON-ACCESS SIDE  
OUTSIDE AIR INTAKE LOCATED IN THE SAME POSITION REGARDLESS OF OPTIONS

Desert Aire has a policy of continuous product and quality improvement. Specifications and dimensions are subject to change without notice. This drawing and information contained herein are the exclusive property of the Desert Aire Corporation. Any use detrimental to the interests of Desert Aire is prohibited.

ALL DIMENSIONS ARE IN INCHES  
TOLERANCE ± 1/8"

All Dimensions in Inches  
All Angles 90°  
All outside corners 0.125" fillet  
Unless Otherwise Specified



Part weight


Tolerance Unless Otherwise Specified  
X.X ±.125  
X.XX ±.060  
X.XXX ±.030  
Angles ±1°

Drawn	ASV	Date Released	1/19/2018
Sheet	3/8		
Scale	NTS		

N120 W18485 FREISTADT RD  
GERMANTOWN, WI 53022  
Tel: (262) 946-7400  
Fax: (262) 946-7401


Description	SP 60-80 TON PKG ELECT HEAT
Page Title	INTAKE OPTIONS GA
Drawing Number	G1000-011

BOTTOM SUPPLY OPTION  
 (VIEW FROM ABOVE)  
 (NO ORIENTATION CHANGE FOR RH OR LH ACCESS)



NOTES:  
 REFER TO SHEET 1 FOR GENERAL NOTES  
 LEFT HAND ACCESS SHOWN IN ALL VIEWS UNLESS OTHERWISE SPECIFIED  
 RIGHT HAND ACCESS OPTIONS LOCATED WITH SAME DIMENSIONS ON OPPOSITE SIDE UNLESS OTHERWISE SPECIFIED  
 HOODS REMOVED FOR CLARITY

Desert Aire has a policy of continuous product and quality improvement. Specifications and dimensions are subject to change without notice. This drawing and information contained herein are the exclusive property of the Desert Aire Corporation. Any use detrimental to the interests of Desert Aire is prohibited.	All Dimensions in Inches All Angles 90° All outside corners 0.125" fillet Unless Otherwise Specified	Tolerance Unless Otherwise Specified X.X ±.125 X.XX ±.060 X.XXX ±.030 Angles ±1°	N120 W18485 FREISTADT RD GERMANTOWN, WI 53022 Tel: (262) 946-7400 Fax: (262) 946-7401
ALL DIMENSIONS ARE IN INCHES TOLERANCE ± 1/8"	Third Angle Projection	Sheet <b>4/8</b>	Page Title <b>DISCHARGE OPTIONS GA</b>
		Scale <b>NTS</b>	Rev. <b>5</b>



1 96" RECOMMENDED FOR FILTER ACCESS.

2 120" CLEARANCE ON ACCESS SIDE RECOMMENDED FOR FAN AND COIL SERVICE




NOTES:  
 REFER TO SHEET 1 FOR GENERAL NOTES  
 LEFT HAND ACCESS SHOWN IN ALL VIEWS  
 RIGHT HAND ACCESS OPTIONS LOCATED WITH SAME DIMENSIONS ON OPPOSITE SIDE UNLESS OTHERWISE SPECIFIED

Desert Aire has a policy of continuous product and quality improvement. Specifications and dimensions are subject to change without notice. This drawing and information contained herein are the exclusive property of the Desert Aire Corporation. Any use detrimental to the interests of Desert Aire is prohibited.	All Dimensions in Inches All Angles 90° All outside corners 0.125" fillet Unless Otherwise Specified	Tolerance Unless Otherwise Specified X.X ±.125 X.XX ±.060 X.XXX ±.030 Angles ±1°	N120 W18485 FREISTADT RD GERMANTOWN, WI 53022 Tel: (262) 946-7400 Fax: (262) 946-7401
ALL DIMENSIONS ARE IN INCHES TOLERANCE ± 1/8"	Third Angle Projection	Sheet <b>5/8</b> Page Title <b>UNIT CLEARANCE GA</b>	Scale <b>NTS</b> Rev. <b>5</b> Drawing Number <b>G1000-011</b>
		Part weight	

NOTES:  
REFER TO SHEET 1 FOR GENERAL NOTES

UNIT TON	18" CURB	24" CURB
60-80	CB-80PEBN-18	CB-80PEBN-24

- 14 GA GALVANIZED STEEL CONSTRUCTION
- PRIME PAINTED AFTER FABRICATION
- PRESSURE TREATED WOOD NAILERS
- 1-1/2" THICK 3LB/FT<sup>3</sup> FIBERGLASS PERIMETER INSULATION
- INTERNAL ANGLE REINFORCEMENT
- CURB TO BE SHIPPED KNOCKED DOWN



NUMBER AND LOCATION OF CROSS SUPPORTS IS DEPENDANT UPON THE GUAGE OF MATERIAL USED TO CONSTRUCT THE CURB, DUCT SUPPORT CONFIGURATION LENGTH OF CURB, AND WIDTH OF CURB. INSTALLATION INSTRUCTIONS INCLUDED WITH CURB SHIPMENT INDICATE THE REQUIRED POSITION FOR FIELD ASSEMBLED CURBS.

Desert Aire has a policy of continuous product and quality improvement. Specifications and dimensions are subject to change without notice. This drawing and information contained herein are the exclusive property of the Desert Aire Corporation. Any use detrimental to the interests of Desert Aire is prohibited.

All Dimensions in Inches  
All Angles 90°  
All outside corners 0.125" fillet  
Unless Otherwise Specified

Tolerance Unless Otherwise Specified  
X.X ±.125  
X.XX ±.060  
X.XXX ±.030  
Angles ±1°

**DESERT AIRE**  
N120 W18485 FREISTADT RD  
GERMANTOWN, WI 53022  
Tel: (262) 946-7400  
Fax: (262) 946-7401



Third Angle Projection

ALL DIMENSIONS ARE IN INCHES  
TOLERANCE ± 1/8"

Part weight

Drawn	ASV	Date Released	1/19/2018	Description	SP 60-80 TON PKG ELECT HEAT
Sheet	6/8		Page Title		
Scale	NTS		Rev.	5	
Drawing Number			G1000-011		

CURB MOUNT PAD MOUNT



1 ALL EXPOSED METAL TO BE SPRAY FOAM INSULATION AFTER INSTALLATION

NOTES:  
REFER TO SHEET 1 FOR GENERAL NOTES  
SEE SHEET 6 NOTES FOR CURB SPECIFICATIONS

Desert Aire has a policy of continuous product and quality improvement. Specifications and dimensions are subject to change without notice. This drawing and information contained herein are the exclusive property of the Desert Aire Corporation. Any use detrimental to the interests of Desert Aire is prohibited.

All Dimensions in Inches  
All Angles 90°  
All outside corners 0.125" fillet  
Unless Otherwise Specified

Tolerance Unless Otherwise Specified  
X.X ±.125  
X.XX ±.060  
X.XXX ±.030  
Angles ±1°

**DESERT AIRE**  
N120 W18485 FREISTADT RD  
GERMANTOWN, WI 53022  
Tel: (262) 946-7400  
Fax: (262) 946-7401

Third Angle Projection


Drawn	ASV	Date Released	1/19/2018	Description	SP 60-80 TON PKG ELECT HEAT
Sheet	7/8			Page Title	MOUNTING DETAILS GA
Scale	NTS		Rev.	5	Drawing Number
					G1000-011

ALL DIMENSIONS ARE IN INCHES  
TOLERANCE ± 1/8"


# SHIP LOOSE ITEMS

## EXHAUST HOOD

DA PART NO	DESCRIPTION	QTY
HOOD	EXHAUST ASSEMBLY	1
807-023	SCREW #8-18X1/2 SS	36
990-105	CAULK WHITE	1



LUG DETAIL



Desert Aire has a policy of continuous product and quality improvement. Specifications and dimensions are subject to change without notice. This drawing and information contained herein are the exclusive property of the Desert Aire Corporation. Any use detrimental to the interests of Desert Aire is prohibited.

ALL DIMENSIONS ARE IN INCHES  
TOLERANCE  $\pm 1/8"$

All Dimensions in Inches  
All Angles 90°  
All outside corners 0.125" fillet  
Unless Otherwise Specified



Third Angle Projection

Part weight

Tolerance Unless Otherwise Specified  
X.X  $\pm .125$   
X.XX  $\pm .060$   
X.XXX  $\pm .030$   
Angles  $\pm 1^\circ$



N120 W18485 FREISTADT RD  
GERMANTOWN, WI 53022  
Tel: (262) 946-7400  
Fax: (262) 946-7401

Drawn	ASV	Date Released	1/19/2018	Description	SP 60-80 TON PKG ELECT HEAT	
Sheet	8/8			Page Title	SHIPPING/LIFTING DETAILS GA	
Scale	NTS		Rev.	5	Drawing Number	G1000-011

**NOTES:**  
REFER TO SHEET 1 FOR GENERAL NOTES AND HOOD DETAILS

<b>SP Pool Dehumidifier</b>	
UNIT TAG	DH-1,2
UNIT MANUFACTURE	DESERT AIRE
MODEL NO	SP70
LOCATION	Outdoor
UNIT WEIGHT	20,500 lbs.
<b>FAN DATA</b>	
SUPPLY AIR FLOW - CFM	35,000
TOTAL ESP (in. W.C.)	3.50
S/A FAN TSP (in. W.C.)	6.51
S/A FAN HP	Qty 4   60
OUTSIDE AIR FLOW - CFM (MAX)	19,000
EXHAUST AIR FLOW - CFM (MAX)	20,000
E/A ESP AT MAXIMUM FLOW (in. W.C.)	0.00
E/A FAN TSP (in. W.C.)	3.96
E/A FAN HP	Qty 2   30
<b>PERFORMANCE</b>	
EAT DB   WB (°F)   %RH	84.0   73.1   60
MOISTURE REMOVAL CAPACITY - LB/HR	387.3
TOTAL COOLING CAPACITY BTUH	793.8
SENSIBLE COOLING CAPACITY BTUH	385
THR BTUH	1,016
COMPRESSOR Circuit A	30
COMPRESSOR Circuit B	35
<b>UNIT ELECTRICAL</b>	
VOLTAGE	460/3/60
MOPD	400
MCA	341
SHORT CIRCUIT CURRENT RATING (SCCR)	5kA or greater
<b>AUXILIARY HEATING</b>	
TYPE	Electric
kW	070
HWC FLUID pD	#DIV/0!
HWC # ROWS	#DIV/0!
<b>POOL WATER HEAT RECOVERY</b>	
<b>REMOTE COOLING DATA</b>	
INTEGRAL PACKAGED CONDENSER	
AMBIENT TEMPERATURE (°F)	105
NO. OF FANS	4
HORSEPOWER (EA)	4
POWER (kW EA)	2.8
<b>COIL SECTION LEAVING AIR CONDITIONS*</b>	
FULL COOLING MODE (°F)	74.1



### Job Summary

Project Name:	Ocala Aquatics		
Unit Tag(s):	SF-1&2		
Quantity:	1	Environment:	Outdoor

### Unit Overview

Model	Cabinet Performance	Airflow (CFM)	Altitude (ft)	Weight (lbs)
XTO-69x123	Solution	20,000	10	5,869



### Segment Sequence

(DP)(FS)(XA FM)

### Unit Construction

Casing Details							
Segment(s)	Thickness (in)	Exterior Paint	Exterior Gauge and Material	Interior Gauge and Material	Insulation Thickness and Material	Bulkhead Material	
FM , XA , FS , DP	2	STD Exterior Paint	STD Ga. G-90 Galvanized	STD Ga. G-90 Galvanized	2" Foam	Galvanized	
Base Details							
Segment(s)	Base		Floor				
	Gauge and Material	Paint	Gauge and Material	Paint	Insulation	Attachment	Tread Plate
FM, XA, FS, DP	Standard Formed Steel	None	STD Ga. G-90 Galvanized	None	N/A	-	Aluminum Diamond Plate

### Unit Electrical

Circuit Details					
Circuit #	Component(s)	V/Ph/Hz	Full Load Amps (FLA)	Minimum Current Ampacity (MCA)	Maximum Overcurrent Protection (MOP)
1	Supply Fan Motor Control, Supply Fan Motor Control	460/3/60	36.2	40.7	50.0
Electrical Details					
Minimum Unit SCCR	-	ETL Label (UL1995/NEC-2002)			Yes
Unit Light Type			Unit Light Switch		
-			-		

### Supply Fan(s)

Performance Details												
Fan Manufacturer	Model	Class	Size	% Wheel Width	% Wheel Diameter	Quantity	Total Airflow (CFM)	Altitude (ft)	TSP (in w.g)	ESP (in w.g)	Fan Speed (RPM)	Fan Power (BHP)
Lau	DDPG2	II	222-9	120	100	2	20,000	10	4.02	2.50	1,989	9.64

Performance Details												
Fan Manufacturer	Model	Class	Size	% Wheel Width	% Wheel Diameter	Quantity	Total Airflow (CFM)	Altitude (ft)	TSP (in w.g)	ESP (in w.g)	Fan Speed (RPM)	Fan Power (BHP)
Drive Type	Wheel Type	Blade Type	Wheel Material	Base Material	Fan Flow Isolation	AirFlow Monitoring	Isolation Type	Total Efficiency (%)	Outlet Velocity (ft/s)	Max Speed (RPM)		
Direct Drive	SWSI	Airfoil	Aluminum	Galvanized Steel	Back-Draft Counter Balance	Yes (K=2649.00)	2" Spring	65.64	671	2,454		

Motor Details										
Type	Manufacturer	Motor Power (HP)	V/Ph/Hz	Quantity	Insulation Class	Motor Speed (RPM)	Frame Size	Full Load Amps (Amps)	Efficiency	Location
TEFC	Baldor	15.0	460/3/60	2	H	1,800	254	18.10	Premium	Direct Drive

At Motor Synchronous Details					
TSP (in w.g.)	Total Air Flow (CMF)	Fan Speed (RPM)	Motor Correction Factor(%)	Fan Power (BHP)	Total Efficiency (%)
4.02	10,000	1,989	92.4	9.64	65.64

### Filter(s)

Details							
Segment	Type	Depth	Filter Loading	Media/MERV	# of Spares	Spare Filter Media	Frame Material
FM	Primary Filter	4" Mini-Pleat	Side	60-65% Eff, (MERV 11)	1	60-65% Eff, (MERV 11)	Galvanized

Sizes				Filter Gauge Details				
Segment	Filter	1 <sup>st</sup> Filter Size W x H (in)	1 <sup>st</sup> Qty	2 <sup>nd</sup> Filter Size W x H (in)	2 <sup>nd</sup> Qty	Location	Type	Range (in w.g)
FM	Primary Filter	24x20	16	16x20	4	Door	Magnehelic with Flag	0 - 1

### Damper(s)

Details												
Segment	Air Path	H x W (in)	Total Face Velocity (ft/min)	CFM	Minimum Allowable OA CFM	Damper Type	Damper Config	Model	Material	Blade Orientation	Actuator Type	Fail Position
FM	Return Air	26.75 x 105.00	1,025	20,000	-	Control	100%	CD50	Aluminum	Parallel	-	-

## Door(s)

Details										
Segment(s)	Location	Swing	Hinge Location	H x W x T (in)	View Port	Test Port	Spare Gasket	Thermal Break	Safety Latch	Noncontact Safety Interlock
FM	Left	Outward	Upstream Side	63 x 39 x 2	None	-	-	Yes	-	-
XA	Left	Outward	Downstream Side	63 x 36 x 2	None	Yes	-	Yes	-	-
FS	Left	Outward	Downstream Side	63 x 18 x 2	None	-	-	Yes	Yes	-
FS	Right	Outward	Downstream Side	63 x 18 x 2	None	-	-	Yes	Yes	-
DP	Left	Outward	Upstream Side	63 x 24 x 2	None	-	-	Yes	Yes	-

## Motor Control(s)

Details										
Segment	Type	MMP	V/Ph/Hz	Input/Output Amps*	Efficiency	Heat Loss (at 100% load)	Enclosure	Bypass	Disconnect Type	RFI/EMI EMC Filter
FS	ABB VFD - Airmod AYK	-	460/3/60	23.0/23.0	92 %	337	NEMA 3R	-	Fused	Yes

### Notes

\*Drives are rated for use below 3,000 ft and 104°F. Use Derating Charts in Air-Mod Engineering Guide Form 100.42-EGI (212) for use above these limits.

Storage Temperature: -40°F to 158°F

Humidity: MAX 95% RH non-condensing

Altitude: 3,300 ft. without derate (1% derate for each additional 330 ft.)

Overload Current Rating: 100% for 1 minute every 10 minutes.

The Class 10 trip rating of the MMP device will not withstand an across-the-line start of a fan and should not be used with VFDs with bypass circuits.

The customer must provide a platform or catwalk for accessing the power-disconnect.

Copper Conductors Only.

FS: Contains the following option: Swinging DC Line Choke (Equivalent to 5% Input Line Reactor)

## Face Velocity and Static Pressure

Summary						
Segment	Description	Face Area (sq. ft)	Airflow (CFM)	Face Velocity (ft/min)	Supply Fan Static Pressure (in w.g.)	Exhaust/Return Fan Static Pressure (in w.g.)
FM	Opening	19.5	20,000	1,025	0.18	0.00
FM	Control Aluminum (CD50)	0.0	20,000	0	0.03	0.00
FM	4" Mini-Pleat 60-65% Eff, (MERV 11)	62.2	20,000	321	0.20	0.00
FM	Dirty Filter Allowance	0.0	20,000	0	0.30	0.00
FS	Backdraft Aluminum (CBD6)	0.0	20,000	0	0.18	0.00
FS	External Static - User Entered	0.0	20,000	0	2.50	0.00
DP	Opening	11.3	20,000	1,773	0.63	0.00
<b>Total</b>					<b>4.02</b>	<b>0.00</b>

## Dimensions and Weight

Details					
Segment	Description	Length <sup>1</sup> (in)	Width <sup>2</sup> (in)	Height (in)	Weight (lbs)
FM	Filter / Mixing Box	45	123	69	1,086
XA	Variable Length Access	42	123	69	827
FS	Supply Fan - SWSI	69	123	69	2,913
DP	Discharge Plenum	38	123	69	1,043
<b>Overall</b>		<b>194</b>			<b>5,869</b>

### Notes

<sup>1</sup>The length includes bottom tier segments only

<sup>2</sup>The width does not include coil connection extensions or door latches that extend beyond the unit casing. The width does not include the depth of any pipe chases.

## Statement of Compliance

### Details

YORK® Solution XT AHU's meet IBC seismic requirements for non-critical equipment ( $I_p = 1.0$ ) for locations with design spectral response  $S_d \leq 0.43$ . Units must be rigid mounted.


The anchorage of the unit to the ground or building structure needs to be evaluated by and is the responsibility of the engineer of record. Specification of seismic requirements is the responsibility of the project design engineer. If formal certification is required, please contact your sales representative and/or application engineer for review. Certain application and site requirements may require additional cost and/or lead time.

Component locations are listed as Segment Hand (Unit Hand): ex. Left (Right). See SubmittalDrawing for additional details

Air handling unit parameters vary depending on conditions. Parameters such as airflows, air pressure drops, and coil capacities are shown for design conditions.

**Shipping Summary**

Details				
Skid	Skid Length (in)	Skid Height (in)	Skid Width (in)	Skid Weight (lbs)
(DP)	48	81	128	1,043
(FS)	69	81	141	2,913
(XA FM)	87	81	128	1,913




**Notes**

- Skid Width: Total width of the shipping skid, including any items that may extend beyond the cabinet (this includes any door handles, coil connections, drain connections, lifting lugs, mounted pipe-chases, electrical/control components, tie-down brackets, side dampers).
- Skid Height: Total height of the shipping skid, including any items that may extend beyond the cabinet (this includes any base-rails, shipping wood-blocks, roof peak, discharge flanges, mounted gas-furnace flue pipes).
- Skid Length: Total length of the shipping skid, including any items that may extend beyond the cabinet (this includes any mounted rain-hoods, discharge flanges, tie-down brackets, shipping wood-blocks, front dampers, split connectors, electrical/control components, outrigging extensions, isolation dampers, inlet baskets).



9942 Currie Davis Dr., Ste. H  
Tampa, FL 33619  
813.995.0300  
emeraldmep.com  
FL EB # 0027845

## **APPENDIX B**




**HVAC OPTION 1 - ROOF PLAN**  
 SCALE: 1/16" = 10"



9942 Currie Davis Dr., Ste. H  
Tampa, FL 33619  
813.995.0300  
emeraldmep.com  
FL EB # 0027845




## **APPENDIX C**




<b>Project:</b>	Long Center Option#1
<b>Address:</b>	1501 N Belcher Rd. Clearwater, FL 33765
<b>Climate File:</b>	USA_FL_St.Petersburg-Clearwater.Intl.AP.722116_TMY3.epw
<b>Simulation:</b>	Natorium Option1_1206.aps

<b>Design Team:</b>	Wannemacher Jensen Architects
<b>Energy Analyst:</b>	REAL Building Consultants LLC
<b>Owner:</b>	City of Clearwater
<b>Conditioned Area (ft²):</b>	34959.4935

Annual Energy Consumption (kBtu/ft²/year) & CO2 KgCO2/ft²/yr			
Energy End Use	Site Energy	Source Energy	CO2 Emissions
Heating Fossil Fuel	0.0	0.0	0.0
Heating Electricity	56.7	178.7	10.0
Space Cooling	27.3	86.0	4.8
Fans Interior	11.0	34.5	1.9
Heat Rejection	1.7	5.5	0.3
Pumps	0.0	0.0	0.0
DHW Fossil Fuel	0.0	0.0	0.0
DHW Electricity	0.0	0.0	0.0
Interior Lighting	4.8	15.0	0.8
Exterior Lighting	0.0	0.0	0.0
Receptacle	1.9	6.1	0.3
Data Center	0.0	0.0	0.0
Cooking Fossil Fuel	0.0	0.0	0.0
Cooking Electricity	0.0	0.0	0.0
Elevators & Escalators	0.0	0.0	0.0
Refrigeration	0.0	0.0	0.0
Process	0.0	0.0	0.0
<b>TOTAL (ex renewables)</b>	<b>103</b>	<b>325</b>	<b>18</b>



Annual Fuel Costs and Peak Demands				
Fuels	Cost (\$)	Peak Day	Peak Time	Peak Demand
Electricity	111,256.00	05-Feb	7:00	465.9 kW
Fossil Fuel	0.00	01-Jan	0:00	0.0 kBtu/h
<b>Total</b>	<b>111,256.00</b>	<b>01-Jan</b>	<b>0:00</b>	



Option#1 Energy Consumption HVAC					
Month	Space Heating (MBtu)	Space Cooling (MBtu)	Heat Rejection (MBtu)	Interior Central Fans (MBtu)	Total HVAC Energy
Jan 01-31	379.087	5.339	0.341	57.006	441.773
Feb 01-28	219.084	13.777	0.879	38.886	272.626
Mar 01-31	193.059	27.613	1.763	37.006	259.441
Apr 01-30	115.621	57.216	3.652	26.226	202.715
May 01-31	145.87	118.285	7.55	27.1	298.805
Jun 01-30	136.54	130.917	8.356	26.086	301.899
Jul 01-31	152.938	163.198	10.417	28.028	354.581
Aug 01-31	146.876	149.818	9.563	26.923	333.18
Sep 01-30	141.646	137.782	8.795	26.369	314.592
Oct 01-31	127.867	98.849	6.309	27.257	260.282
Nov 01-30	83.918	39.798	2.54	25.602	151.858
Dec 01-31	141.068	11.364	0.725	36.332	189.489
Summed total	1983.572	953.954	60.891	382.822	3,381.24

Option#1 Electricity (\$0.105/kWh) blended rate		
Month	Net electricity usage [kWh]	Total net charges [\$]
January	135,404.65	\$ 14,217.49
February	85,161.14	\$ 8,941.92
March	81,717.52	\$ 8,580.34
April	65,119.75	\$ 6,837.57
May	93,387.46	\$ 9,805.68
June	94,054.85	\$ 9,875.76
July	109,851.25	\$ 11,534.38
August	103,328.22	\$ 10,849.46
September	97,907.63	\$ 10,280.30
October	82,214.91	\$ 8,632.57
November	49,964.51	\$ 5,246.27
December	61,467.63	\$ 6,454.10
Total year	1,059,579.53	\$ 111,255.84



Use global inputs for oversizing (yes/no): **no**  
 Cooling (Sensible) Load Oversizing Factor: 10%  
 Cooling (Latent) Load Oversizing Factor: 10%  
 Heating Load Oversizing Factor: 10%

Date: **2023-12-06**

Loads reported below are non-coincident room- and zone-level loads

Zone group	Zone	Room	Template	Floor area (ft <sup>2</sup> )	Volume (ft <sup>3</sup> )	Cooling occupied setpoint (°F)	Sensible cooling load (without oversizing)		Cooling design load oversizing factor	Cooling design load with oversizing (kBtu/h)	Cooling supply air temperature (°F)	Cooling design airflow (sensible cooling maximum)			Max RH setpoint (%)	Latent cooling load without oversizing (kBtu/h)	Design latent cooling load with oversizing (kBtu/h)	Cooling design load oversizing factor from room level loads	
							Month/time	(kBtu/h)				(Btu/h.ft <sup>2</sup> )	(cfm)	(ACH)					(cfm/ft <sup>2</sup> )
DH-1	DH-1	29 DH-1 Pool area North Circulation	SPACE: Corridor - All Other Corridors	1,853.3	53,109.4	82.0	Jun 14:30	70.72	38.16	1.10	77.79	55.0	2,633.7	2.98	1.42	60.0	3.15	3.46	1.1
		DH-1 Pool Area	SPACE: Gymnasium/ Fitness center - Exercise area	10,647.6	106,238.4	82.0	Jun 10:30	56.88	5.34	1.10	62.57	55.0	2,118.4	1.20	0.20	55.0	344.65	379.11	1.1
		DH-1 Pool Area (upper 1)	SPACE: Corridor - All Other Corridors	10,647.6	150,037.4	82.0	Jun 10:30	21.56	2.02	1.10	23.71	55.0	802.8	0.32	0.08	60.0	10.10	11.11	1.1
DH-2	DH-2	DH-1 Pool Area (upper 2)	SPACE: Corridor - All Other Corridors	10,647.6	150,037.4	82.0	Jun 11:30	27.38	2.57	1.10	30.12	55.0	1,019.8	0.41	0.10	60.0	10.53	11.58	1.1
		23 Spectator Area	SPACE: Audience Seating Area - Exercise Center	9,175.0	191,146.9	82.0	Jun 7:30	55.43	6.04	1.10	60.98	55.0	2,064.3	0.65	0.22	60.0	14.00	15.40	1.1
		30 Vestibule	SPACE: Corridor - All Other Corridors	251.6	9,596.6	82.0	Aug 17:30	20.41	81.11	1.10	22.45	55.0	759.9	4.75	3.02	60.0	0.70	0.77	1.1
		31 Vestibule	SPACE: Corridor - All Other Corridors	264.5	10,094.0	82.0	Sep 10:30	30.96	117.08	1.10	34.06	55.0	1,153.1	6.85	4.36	60.0	0.67	0.74	1.1
		32 DH-2 Pool Area Circulation	SPACE: Corridor - All Other Corridors	1,187.8	44,412.8	82.0	Jun 8:30	17.65	14.86	1.10	19.41	55.0	657.2	0.89	0.55	60.0	3.25	3.58	1.1
		DH-2 Pool Area	SPACE: Gymnasium/ Fitness center - Exercise area	11,579.7	115,538.8	82.0	Jun 10:30	86.32	7.45	1.10	94.95	55.0	3,214.7	1.67	0.28	55.0	377.47	415.22	1.1
		DH-2 Pool Area (upper 1)	SPACE: Corridor - All Other Corridors	11,579.7	163,172.2	82.0	Aug 10:30	23.00	1.99	1.10	25.30	55.0	856.6	0.31	0.07	60.0	11.95	13.15	1.1
		DH-2 Pool Area (upper 2)	SPACE: Corridor - All Other Corridors	11,579.7	163,172.2	82.0	Jun 10:30	27.21	2.35	1.10	29.93	55.0	1,013.4	0.37	0.09	60.0	11.52	12.68	1.1

Zone group	Zone	Room	Template	Floor area (ft <sup>2</sup> )	Volume (ft <sup>3</sup> )	Heating occupied setpoint (°F)	Heating load (without oversizing)		Heating design load oversizing factor	Heating design load with oversizing (kBtu/h)	Heating supply air temperature (°F)	Heating design airflow (maximum)		Min RH setpoint (%)	Humidification load (kBtu/h)
							(kBtu/h)	(Btu/h.ft <sup>2</sup> )				(cfm)	(cfm/ft <sup>2</sup> )		
DH-1	DH-1	29 DH-1 Pool area North Circulation	SPACE: Corridor - All Other Corridors	1,853.3	53,109.4	70.00	78.39	42.30	0.00	0.00	90.0	0.0	0.00	0.0	0.00
		DH-1 Pool Area	SPACE: Gymnasium/ Fitness center - Exercise area	10,647.6	106,238.4	70.00	32.84	3.08	0.00	0.00	90.0	0.0	0.00	0.0	0.00
		DH-1 Pool Area (upper 1)	SPACE: Corridor - All Other Corridors	10,647.6	150,037.4	70.00	20.94	1.97	0.00	0.00	90.0	0.0	0.00	0.0	0.00
DH-2	DH-2	DH-1 Pool Area (upper 2)	SPACE: Corridor - All Other Corridors	10,647.6	150,037.4	70.00	27.45	2.58	0.00	0.00	90.0	0.0	0.00	0.0	0.00
		23 Spectator Area	SPACE: Audience Seating Area - Exercise Center	9,175.0	191,146.9	70.00	44.69	4.87	0.00	0.00	90.0	0.0	0.00	0.0	0.00
		30 Vestibule	SPACE: Corridor - All Other Corridors	251.6	9,596.6	70.00	7.25	28.80	0.00	0.00	90.0	0.0	0.00	0.0	0.00
		31 Vestibule	SPACE: Corridor - All Other Corridors	264.5	10,094.0	70.00	10.48	39.63	0.00	0.00	90.0	0.0	0.00	0.0	0.00
		32 DH-2 Pool Area Circulation	SPACE: Corridor - All Other Corridors	1,187.8	44,412.8	70.00	17.28	14.55	0.00	0.00	90.0	0.0	0.00	0.0	0.00
		DH-2 Pool Area	SPACE: Gymnasium/ Fitness center - Exercise area	11,579.7	115,538.8	70.00	33.20	2.87	0.00	0.00	90.0	0.0	0.00	0.0	0.00
		DH-2 Pool Area (upper 1)	SPACE: Corridor - All Other Corridors	11,579.7	163,172.2	70.00	19.40	1.68	0.00	0.00	90.0	0.0	0.00	0.0	0.00
		DH-2 Pool Area (upper 2)	SPACE: Corridor - All Other Corridors	11,579.7	163,172.2	70.00	25.35	2.19	0.00	0.00	90.0	0.0	0.00	0.0	0.00

Zone group	Zone	Room	Template	Floor area (ft <sup>2</sup> )	Volume (ft <sup>3</sup> )	Design occupancy (People)	Required minimum ventilation airflow			
							(cfm)	(cfm/person)	(cfm/ft <sup>2</sup> )	(ACH)
DH-1	DH-1	29 DH-1 Pool area North Circulation	SPACE: Corridor - All Other Corridors	1,853.3	53,109.4	0.0	111.2	0.0	0.06	0.13
		DH-1 Pool Area	SPACE: Gymnasium/ Fitness center - Exercise area	10,647.6	106,238.4	25.0	1,138.9	45.6	0.11	0.64
		DH-1 Pool Area (upper 1)	SPACE: Corridor - All Other Corridors	10,647.6	150,037.4	0.0	0.0	0.0	0.00	0.00
DH-2	DH-2	DH-1 Pool Area (upper 2)	SPACE: Corridor - All Other Corridors	10,647.6	150,037.4	0.0	0.0	0.0	0.00	0.00
		23 Spectator Area	SPACE: Audience Seating Area - Exercise Center	9,175.0	191,146.9	10.0	625.5	62.6	0.07	0.20
		30 Vestibule	SPACE: Corridor - All Other Corridors	251.6	9,596.6	0.0	15.1	0.0	0.06	0.09
		31 Vestibule	SPACE: Corridor - All Other Corridors	264.5	10,094.0	0.0	15.9	0.0	0.06	0.09
		32 DH-2 Pool Area Circulation	SPACE: Corridor - All Other Corridors	1,187.8	44,412.8	0.0	71.3	0.0	0.06	0.10
		DH-2 Pool Area	SPACE: Gymnasium/ Fitness center - Exercise area	11,579.7	115,538.8	25.0	1,194.8	47.8	0.10	0.62
		DH-2 Pool Area (upper 1)	SPACE: Corridor - All Other Corridors	11,579.7	163,172.2	0.0	0.0	0.0	0.00	0.00
		DH-2 Pool Area (upper 2)	SPACE: Corridor - All Other Corridors	11,579.7	163,172.2	0.0	0.0	0.0	0.00	0.00



<b>Project and Climate</b>			2		
<b>Zone Conditioning Loads Reports</b>					
DH-1	05 a VAV - Reheat [DX cool -...	DH-1	3		
DH-2	05 a VAV - Reheat [DX cool -...	Dh-2	4		
<b>Room Conditioning Loads Reports</b>					
DH-1	DH-1	29 DH -1 Pool area North...	5		
		DH-1 Pool Area	6		
		DH-1 Pool Area (upper 1)	7		
		DH-1 Pool Area (upper 2)	8		
		DH-2	Dh-2	30 Vestibule	9
				31 Vestibule	10
				32 DH-2 Pool Area...	11
				DH-2 Pool Area	12
				DH-2 Pool Area (upper 1)	13
				DH-2 Pool Area (upper 2)	14

Model Data	
Project file	Long Center Option1.mit
Source HVAC file	Natatorium_Option1_HVAC.asp
HVAC file snapshot	Vista\Long Center Option1 Rooms loads rev1.asp
Model floor area	34,959.5 ft <sup>2</sup>
Building conditioned floor area	34,959.5 ft <sup>2</sup>
Building conditioned volume	1,156,556.0 ft <sup>3</sup>
Number of conditioned rooms	11
Load analysis methodology	ASHRAE Heat Balance Method
Calculated	2023/12/06 16:02
Version No.	2023.2.1.0


Location Data	
Location	St Pete-Clearwater, Florida
Latitude	27.91 N
Longitude	82.69 W
Altitude	9.8 ft
Time Zone	5.0 hours behind GMT

Design Weather Data	
Source	ASHRAE design weather database
Monthly percentile:	
For heating loads design weather	99.60 %
For cooling loads design weather	0.40 %
Barometric pressure	29.9109 inHg
Air density	0.0749 lb/ft <sup>3</sup>
Air specific heat	0.2434 Btu/lb·°F
Density-specific heat product	0.0591 Btu/ft <sup>3</sup> ·°F
Summer ground reflectance	0.2
Winter ground reflectance	0.2
Carbon dioxide (ambient)	400.00 ppm

Cooling Calculation Data	
Results file	Long Center Option1 Rooms loads rev1.clg
Calculated	2023/12/06 16:02
Profile Month	May - Sep
Max outdoor temp. dry bulb	93.7 °F
Max outdoor temp. wet bulb	78.4 °F

Heating Calculation Data	
Results file	Long Center Option1 Rooms loads rev1.htg
Calculated	2023/12/06 16:02
Profile Month	Jan
Outdoor winter design temp	42.1 °F

Project Loads Summary		
Cooling loads:	kBtu/h	Btu/h-ft <sup>2</sup>
Coincident peak space load	391.21	11.19
Heating loads:		
Coincident peak space load	317.27	9.08



# Zone Loads Report

System: 05 a VAV - Reheat

# Long Center Option1

## DH-1

IES VIRTUAL ENVIRONMENT  
VE 2023



COOLING ZONE PEAK					
Time of Peak (Mo/Hr:Mn)					6 / 11:30
Outside Air (DBT/WBT/RH) °F and %RH					90.3 / 75.7 / 51.3
Zone	Zone Sensible	Zone Latent	Net Value	Per Floor Area	Percent of Total
<b>Envelope Gains/Losses</b>	Btu/h	Btu/h	Btu/h	Btu/h-ft²	%
External Walls	-3,913	-	-3,913	-0.3	-0.8
Roofs	1,385	-	1,385	0.1	0.3
Ground/Exposed Floors	-4,562	-	-4,562	-0.4	-0.9
External Doors	0	-	0	0.0	0.0
Windows Conduction	34,424	-	34,424	2.8	6.8
Skylights Conduction	0	-	0	0.0	0.0
Solar	103,955	-	103,955	8.3	20.5
Infiltration	5,971	5,826	11,797	0.9	2.3
Nat/Aux Vent	0	0	0	0.0	0.0
<b>Internal Building Gains/Losses</b>					
Internal Walls/Openings	75	-	75	0.0	0.0
Internal Floors	797	-	797	0.1	0.2
Internal Air & Furniture	0	-	0	0.0	0.0
Ceilings	0	-	0	0.0	0.0
Sub Total	138,133	5,826	143,959	11.5	
<b>Internal Gains</b>					
Lights	3,162	-	3,162	0.3	0.6
People	17,750	27,250	45,000	3.6	8.9
Misc, Computers, Equip	1,265	313,755	315,020	25.2	62.1
Sub Total	22,177	341,005	363,182	29.1	
<b>TOTAL</b>	<b>160,310</b>	<b>346,831</b>	<b>507,141</b>	<b>40.6</b>	<b>100</b>

COOLING SUMMARY	
Sensible cooling load (Btu/h):	160,310
Latent cooling load (Btu/h):	346,831
Sensible heat ratio:	0.32
Design Supply Airflow calculated per:	Sensible Loads
Design zone air temp for Supply Airflow calculation (°F):	82.0

HEATING ZONE PEAK					
Time of Peak (Mo/Hr:Mn)					Heating Design
Outside Air (DBT/WBT/RH) °F and %RH					42.1 / 35.4 / 49.6
Zone	Net Value	Per Floor Area	Percent of Total		
<b>Envelope Gains/Losses</b>	Btu/h	Btu/h	Btu/h-ft²	%	
External Walls	-21,014	-21,014	-1.7	13.2	
Roofs	-8,635	-8,635	-0.7	5.4	
Ground/Exposed Floors	-16,241	-16,241	-1.3	10.2	
External Doors	0	0	0.0	0.0	
Windows Conduction	-77,794	-77,794	-6.2	48.7	
Skylights Conduction	0	0	0.0	0.0	
Solar	0	0	0.0	0.0	
Infiltration	-23,387	-23,387	-1.9	14.7	
Nat/Aux Vent	0	0	0.0	0.0	
<b>Internal Building Gains/Losses</b>					
Internal Walls/Openings	1,777	1,777	0.1	-1.1	
Internal Floors	-14,327	-14,327	-1.1	9.0	
Internal Air & Furniture	0	0	0.0	0.0	
Ceilings	0	0	0.0	0.0	
Sub Total	-159,621	-159,621	-12.8		
<b>Internal Gains</b>					
Lights	0	0	0.0	0.0	
People	0	0	0.0	0.0	
Misc, Computers, Equip	0	0	0.0	0.0	
Sub Total	0	0	0.0		
<b>TOTAL</b>	<b>-159,621</b>	<b>-159,621</b>	<b>-12.8</b>	<b>100</b>	

HEATING SUMMARY	
Sensible heating load (Btu/h):	159,621
Design zone air temp for Supply Airflow calculation (°F):	70.0

AREAS & THERMAL TRANSMITTANCE				
	Total Area	Glazing	Glazing	U-value <sup>1</sup>
	ft²	ft²	%	Btu/h-ft²-°F
<b>External</b>				
Wall (above grade)	15,437.1	6,260.1	40.6	0.25
Below Grade Walls	-	-	-	-
Windows <sup>2</sup>	6,260.1	6,260.1	100.0	0.48
Doors	-	-	-	-
Floors	6,979.8	-	-	0.09
Roofs <sup>3</sup>	12,392.2	-	-	0.02
<b>COMBINED</b>	<b>34,809.1</b>	<b>6,260.1</b>	<b>18.0</b>	<b>0.14</b>
<b>Internal</b>				
Ceilings	-	-	-	-
Floors	5,521.2	-	-	0.19
Partitions <sup>4</sup>	3,695.6	-	-	0.33

<sup>1</sup> Area-weighted U-value; <sup>2</sup> Windows/glazing include glass and frames; <sup>3</sup> Roofs incl. skylights; <sup>4</sup> Partitions incl. internal windows and doors.

TEMPERATURES & SETPOINTS		
	Cooling	Heating
	°F	°F
Supply Air (design)	55.0	80.0
Master Room Setpoint (design)	82.0	70.0
Master Room (actual)	82.0	70.0
Mean Radiant Temperature	179.7	163.5
Dry Resultant Temperature	178.9	164.7
RH (Design Max Setpoint) (%)	-	-

AIRFLOW		
	Cooling	Heating
	cfm	cfm
Supply (design)	20,626	24,967
Reheat Minimum (design)	20,626	20,626
Leakage at Design Flow	0	0
Ventilation (requirement)	20,626	20,626
Exhaust (requirement)	15,469	15,469
Infiltration	766	766

CHECKS	
Number of People	25.00
ft²/Person	500.04
Average Ceiling Height (ft)	18.38
Btu/h/ft² - Cooling (sensible)	12.82
Btu/h/ft² - Heating	12.77
ft²/ton - Cooling (sensible)	935.76
ft²/ton - Heating	939.79
cfm/ft² - Cooling	1.65
cfm/ft² - Heating	2.00
% Outside Air - Cooling	100.00
% Outside Air - Heating	82.61
Outdoor Air cfm/ft²	1.65
Outdoor Air cfm/person	825.03

# Zone Loads Report

System: 05 a VAV - Reheat

# Long Center Option1

## Dh-2



COOLING ZONE PEAK					
Time of Peak (Mo/Hr:Mn)					8 / 10:30
Outside Air (DBT/WBT/RH) °F and %RH					88.2 / 76.5 / 58.6
Zone	Zone Sensible	Zone Latent	Net Value	Per Floor Area	Percent of Total
<b>Envelope Gains/Losses</b>	Btu/h	Btu/h	Btu/h	Btu/h-ft²	%
External Walls	-1,069	-	-1,069	0.0	-0.2
Roofs	4,693	-	4,693	0.2	0.8
Ground/Exposed Floors	-6,480	-	-6,480	-0.3	-1.1
External Doors	0	-	0	0.0	0.0
Windows Conduction	9,305	-	9,305	0.4	1.6
Skylights Conduction	0	-	0	0.0	0.0
Solar	123,653	-	123,653	5.5	21.9
Infiltration	4,642	11,000	15,642	0.7	2.8
Nat/Aux Vent	0	0	0	0.0	0.0
<b>Internal Building Gains/Losses</b>					
Internal Walls/Openings	-4,807	-	-4,807	-0.2	-0.9
Internal Floors	-2,436	-	-2,436	-0.1	-0.4
Internal Air & Furniture	0	-	0	0.0	0.0
Ceilings	14	-	14	0.0	0.0
Sub Total	127,514	11,000	138,514	6.2	
<b>Internal Gains</b>					
Lights	38,467	-	38,467	1.7	6.8
People	17,750	27,250	45,000	2.0	8.0
Misc, Computers, Equip	1,163	341,222	342,385	15.2	60.7
Sub Total	57,380	368,472	425,852	19.0	
<b>TOTAL</b>	<b>184,894</b>	<b>379,473</b>	<b>564,367</b>	<b>25.1</b>	<b>100</b>

COOLING SUMMARY	
Sensible cooling load (Btu/h):	184,894
Latent cooling load (Btu/h):	379,473
Sensible heat ratio:	0.33
Design Supply Airflow calculated per:	Sensible Loads
Design zone air temp for Supply Airflow calculation (°F):	82.0

HEATING ZONE PEAK					
Time of Peak (Mo/Hr:Mn)					Heating Design
Outside Air (DBT/WBT/RH) °F and %RH					42.1 / 35.4 / 49.6
Zone	Net Value	Per Floor Area	Percent of Total		
<b>Envelope Gains/Losses</b>	Btu/h	Btu/h	Btu/h-ft²	%	
External Walls	-18,277	-18,277	-0.8	16.2	
Roofs	-9,424	-9,424	-0.4	8.3	
Ground/Exposed Floors	-15,445	-15,445	-0.7	13.7	
External Doors	0	0	0.0	0.0	
Windows Conduction	-24,650	-24,650	-1.1	21.8	
Skylights Conduction	0	0	0.0	0.0	
Solar	0	0	0.0	0.0	
Infiltration	-25,758	-25,758	-1.1	22.8	
Nat/Aux Vent	0	0	0.0	0.0	
<b>Internal Building Gains/Losses</b>					
Internal Walls/Openings	-502	-502	0.0	0.4	
Internal Floors	-18,913	-18,913	-0.8	16.7	
Internal Air & Furniture	0	0	0.0	0.0	
Ceilings	0	0	0.0	0.0	
Sub Total	-112,969	-112,969	-5.0		
<b>Internal Gains</b>					
Lights	0	0	0.0	0.0	
People	0	0	0.0	0.0	
Misc, Computers, Equip	0	0	0.0	0.0	
Sub Total	0	0	0.0		
<b>TOTAL</b>	<b>-112,969</b>	<b>-112,969</b>	<b>-5.0</b>	<b>100</b>	

HEATING SUMMARY	
Sensible heating load (Btu/h):	112,969
Design zone air temp for Supply Airflow calculation (°F):	70.0

AREAS & THERMAL TRANSMITTANCE				
	Total Area	Glazing	Glazing	U-value <sup>1</sup>
	ft²	ft²	%	Btu/h-ft²-°F
<b>External</b>				
Wall (above grade)	16,317.1	2,667.5	16.3	0.13
Below Grade Walls	-	-	-	-
Windows <sup>2</sup>	2,667.5	2,667.5	100.0	0.33
Doors	-	-	-	-
Floors	15,266.9	-	-	0.07
Roofs <sup>3</sup>	22,414.2	-	-	0.02
<b>COMBINED</b>	<b>53,998.2</b>	<b>2,667.5</b>	<b>4.9</b>	<b>0.07</b>
<b>Internal</b>				
Ceilings	22.0	-	-	0.05
Floors	7,169.6	-	-	0.19
Partitions <sup>4</sup>	6,690.0	-	-	0.33

<sup>1</sup> Area-weighted U-value; <sup>2</sup> Windows/glazing include glass and frames; <sup>3</sup> Roofs incl. skylights; <sup>4</sup> Partitions incl. internal windows and doors.

TEMPERATURES & SETPOINTS		
	Cooling	Heating
	°F	°F
Supply Air (design)	55.0	90.0
Master Room Setpoint (design)	82.0	70.0
Master Room (actual)	82.0	70.0
Mean Radiant Temperature	229.6	218.3
Dry Resultant Temperature	228.9	219.0
RH (Design Max Setpoint) (%)	-	-

AIRFLOW		
	Cooling	Heating
	cfm	cfm
Supply (design)	20,789	20,789
Reheat Minimum (design)	20,789	20,789
Leakage at Design Flow	0	0
Ventilation (requirement)	18,914	18,914
Exhaust (requirement)	14,453	14,453
Infiltration	843	843

CHECKS	
Number of People	25.00
ft²/Person	531.34
Average Ceiling Height (ft)	24.67
Btu/h/ft² - Cooling (sensible)	13.92
Btu/h/ft² - Heating	8.50
ft²/ton - Cooling (sensible)	862.13
ft²/ton - Heating	1,411.02
cfm/ft² - Cooling	1.57
cfm/ft² - Heating	1.57
% Outside Air - Cooling	90.98
% Outside Air - Heating	90.98
Outdoor Air cfm/ft²	1.42
Outdoor Air cfm/person	756.58

# Room Loads Report

Zone: DH-1  
System: 05 a VAV - Reheat

# Long Center Option1 29 DH -1 Pool area North Circulation HVAC Methodology: ApacheHVAC

IES VIRTUAL ENVIRONMENT

VE 2023



COOLING ROOM PEAK					
Time of Peak (Mo/Hr:Mn)					6 / 14:30
Outside Air (DBT/WBT/RH) °F and %RH					93.7 / 77.0 / 47.0
Room	Room Sensible	Room Latent	Net Value	Per Floor Area	Percent of Total
<b>Envelope Gains/Losses</b>	Btu/h	Btu/h	Btu/h	Btu/h-ft²	%
External Walls	1,672	-	1,672	0.9	2.3
Roofs	-1,764	-	-1,764	-1.0	-2.5
Ground/Exposed Floors	-1,652	-	-1,652	-0.9	-2.3
External Doors	0	-	0	0.0	0.0
Windows Conduction	40,772	-	40,772	22.0	57.1
Skylights Conduction	0	-	0	0.0	0.0
Solar	37,866	-	37,866	20.4	53.0
Infiltration	1,100	720	1,820	1.0	2.5
Nat/Aux Vent	0	0	0	0.0	0.0
<b>Internal Building Gains/Losses</b>					
Internal Walls/Openings	-11,699	-	-11,699	-6.3	-16.4
Internal Floors	0	-	0	0.0	0.0
Internal Air & Furniture	0	-	0	0.0	0.0
Ceilings	0	-	0	0.0	0.0
Sub Total	66,296	720	67,015	36.2	
<b>Internal Gains</b>					
Lights	3,162	-	3,162	1.7	4.4
People	0	0	0	0.0	0.0
Misc, Computers, Equip	1,265	0	1,265	0.7	1.8
Sub Total	4,427	0	4,427	2.4	
<b>TOTAL</b>	<b>70,722</b>	<b>720</b>	<b>71,442</b>	<b>38.5</b>	<b>100</b>

COOLING SUMMARY	
Sensible cooling load (Btu/h):	70,722
Latent cooling load (Btu/h):	720
Sensible heat ratio:	0.99
Design Supply Airflow calculated per:	Sensible Loads
Design zone air temp for Supply Airflow calculation (°F):	82.0

HEATING ROOM PEAK					
Time of Peak (Mo/Hr:Mn)					Heating Design
Outside Air (DBT/WBT/RH) °F and %RH					42.1 / 35.4 / 49.6
Room	Room Value	Net Value	Per Floor Area	Percent of Total	
<b>Envelope Gains/Losses</b>	Btu/h	Btu/h	Btu/h-ft²	%	
External Walls	-15,300	-15,300	-8.3	19.5	
Roofs	-1,114	-1,114	-0.6	1.4	
Ground/Exposed Floors	-9,221	-9,221	-5.0	11.8	
External Doors	0	0	0.0	0.0	
Windows Conduction	-67,040	-67,040	-36.2	85.5	
Skylights Conduction	0	0	0.0	0.0	
Solar	0	0	0.0	0.0	
Infiltration	-2,704	-2,704	-1.5	3.4	
Nat/Aux Vent	0	0	0.0	0.0	
<b>Internal Building Gains/Losses</b>					
Internal Walls/Openings	16,989	16,989	9.2	-21.7	
Internal Floors	0	0	0.0	0.0	
Internal Air & Furniture	0	0	0.0	0.0	
Ceilings	0	0	0.0	0.0	
Sub Total	-78,390	-78,390	-42.3		
<b>Internal Gains</b>					
Lights	0	0	0.0	0.0	
People	0	0	0.0	0.0	
Misc, Computers, Equip	0	0	0.0	0.0	
Sub Total	0	0	0.0		
<b>TOTAL</b>	<b>-78,390</b>	<b>-78,390</b>	<b>-42.3</b>	<b>100</b>	

HEATING SUMMARY	
Sensible heating load (Btu/h):	78,390
Design zone air temp for Supply Airflow calculation (°F):	70.0

AREAS & THERMAL TRANSMITTANCE				
	Total Area	Glazing	Glazing	U-value <sup>1</sup>
	ft²	ft²	%	Btu/h-ft²-°F
<b>External</b>				
Wall (above grade)	11,823.4	4,985.9	42.2	0.27
Below Grade Walls	-	-	-	-
Windows <sup>2</sup>	4,985.9	4,985.9	100.0	0.53
Doors	-	-	-	-
Floors	1,853.3	-	-	0.19
Roofs <sup>3</sup>	1,744.7	-	-	0.02
<b>COMBINED</b>	<b>15,421.4</b>	<b>4,985.9</b>	<b>32.3</b>	<b>0.23</b>
<b>Internal</b>				
Ceilings	-	-	-	-
Floors	-	-	-	-
Partitions <sup>4</sup>	331.4	-	-	0.33

<sup>1</sup> Area-weighted U-value; <sup>2</sup> Windows/glazing include glass and frames; <sup>3</sup> Roofs incl. skylights; <sup>4</sup> Partitions incl. internal windows and doors.

TEMPERATURES & SETPOINTS		
	Cooling	Heating
	°F	°F
Supply Air (design)	55.0	80.0
Room Setpoint (design)	82.0	70.0
Room (actual)	82.0	70.0
Mean Radiant Temperature	85.8	64.1
Dry Resultant Temperature	83.9	67.1
RH (Design Max Setpoint) (%)	60.0	60.0

AIRFLOW		
	Cooling	Heating
	cfm	cfm
Supply (design)	3,541	7,882
Reheat Minimum (design)	3,541	3,541
Leakage at Design Flow	0	0
Ventilation (requirement)	3,541	3,541
Exhaust (requirement)	1,770	1,770
Infiltration	89	89

CHECKS	
Number of People	0.00
ft²/Person	-
Average Ceiling Height (ft)	35.37
Btu/h/ft² - Cooling (sensible)	38.16
Btu/h/ft² - Heating	42.30
ft²/ton - Cooling (sensible)	314.47
ft²/ton - Heating	283.71
cfm/ft² - Cooling	1.91
cfm/ft² - Heating	4.25
% Outside Air - Cooling	100.00
% Outside Air - Heating	44.92
Outdoor Air cfm/ft²	1.91
Outdoor Air cfm/person	-

# Room Loads Report

Zone: DH-1  
System: 05 a VAV - Reheat

# Long Center Option1 DH-1 Pool Area HVAC Methodology: ApacheHVAC

IES VIRTUAL ENVIRONMENT

VE 2023



COOLING ROOM PEAK					
Time of Peak (Mo/Hr:Mn)					6 / 10:30
Outside Air (DBT/WBT/RH) °F and %RH					88.0 / 74.9 / 54.4
Room	Room Sensible	Room Latent	Net Value	Per Floor Area	Percent of Total
<b>Envelope Gains/Losses</b>	Btu/h	Btu/h	Btu/h	Btu/h-ft²	%
External Walls	-131	-	-131	0.0	0.0
Roofs	0	-	0	0.0	0.0
Ground/Exposed Floors	-4,944	-	-4,944	-0.5	-1.2
External Doors	0	-	0	0.0	0.0
Windows Conduction	2,028	-	2,028	0.2	0.5
Skylights Conduction	0	-	0	0.0	0.0
Solar	47,625	-	47,625	4.5	11.9
Infiltration	912	1,949	2,861	0.3	0.7
Nat/Aux Vent	0	0	0	0.0	0.0
<b>Internal Building Gains/Losses</b>					
Internal Walls/Opening	-4,516	-	-4,516	-0.4	-1.1
Internal Floors	-1,831	-	-1,831	-0.2	-0.5
Internal Air & Furniture	0	-	0	0.0	0.0
Ceilings	0	-	0	0.0	0.0
<b>Sub Total</b>	<b>39,144</b>	<b>1,949</b>	<b>41,093</b>	<b>3.9</b>	
<b>Internal Gains</b>					
Lights	0	-	0	0.0	0.0
People	17,750	27,250	45,000	4.2	11.3
Misc, Computers, Equip	0	313,755	313,755	29.5	78.5
<b>Sub Total</b>	<b>17,750</b>	<b>341,005</b>	<b>358,755</b>	<b>33.7</b>	
<b>TOTAL</b>	<b>56,894</b>	<b>342,954</b>	<b>399,848</b>	<b>37.6</b>	<b>100</b>

COOLING SUMMARY	
Sensible cooling load (Btu/h):	56,894
Latent cooling load (Btu/h):	342,954
Sensible heat ratio:	0.14
Design Supply Airflow calculated per:	Sensible Loads
Design zone air temp for Supply Airflow calculation (°F):	82.0

HEATING ROOM PEAK					
Time of Peak (Mo/Hr:Mn)					Heating Design
Outside Air (DBT/WBT/RH) °F and %RH					42.1 / 35.4 / 49.6
Room	Room Value	Net Value	Per Floor Area	Percent of Total	
<b>Envelope Gains/Losses</b>	Btu/h	Btu/h	Btu/h-ft²	%	
External Walls	-1,019	-1,019	-0.1	3.1	
Roofs	0	0	0.0	0.0	
Ground/Exposed Floors	-7,020	-7,020	-0.7	21.4	
External Doors	0	0	0.0	0.0	
Windows Conduction	-4,359	-4,359	-0.4	13.3	
Skylights Conduction	0	0	0.0	0.0	
Solar	0	0	0.0	0.0	
Infiltration	-5,408	-5,408	-0.5	16.5	
Nat/Aux Vent	0	0	0.0	0.0	
<b>Internal Building Gains/Losses</b>					
Internal Walls/Opening	-702	-702	-0.1	2.1	
Internal Floors	-14,327	-14,327	-1.3	43.6	
Internal Air & Furniture	0	0	0.0	0.0	
Ceilings	0	0	0.0	0.0	
<b>Sub Total</b>	<b>-32,835</b>	<b>-32,835</b>	<b>-3.1</b>		
<b>Internal Gains</b>					
Lights	0	0	0.0	0.0	
People	0	0	0.0	0.0	
Misc, Computers, Equip	0	0	0.0	0.0	
<b>Sub Total</b>	<b>0</b>	<b>0</b>	<b>0.0</b>		
<b>TOTAL</b>	<b>-32,835</b>	<b>-32,835</b>	<b>-3.1</b>	<b>100</b>	

HEATING SUMMARY	
Sensible heating load (Btu/h):	32,835
Design zone air temp for Supply Airflow calculation (°F):	70.0

AREAS & THERMAL TRANSMITTANCE				
	Total Area	Glazing	Glazing	U-value <sup>1</sup>
	ft²	ft²	%	Btu/h-ft²-°F
<b>External</b>				
Wall (above grade)	944.8	526.2	55.7	0.20
Below Grade Walls	-	-	-	-
Windows <sup>2</sup>	526.2	526.2	100.0	0.30
Doors	-	-	-	-
Floors	5,126.4	-	-	0.05
Roofs <sup>3</sup>	-	-	-	-
<b>COMBINED</b>	<b>6,071.3</b>	<b>526.2</b>	<b>8.7</b>	<b>0.08</b>
<b>Internal</b>				
Ceilings	-	-	-	-
Floors	5,521.2	-	-	0.19
Partitions <sup>4</sup>	140.0	-	-	0.33

<sup>1</sup> Area-weighted U-value; <sup>2</sup> Windows/glazing include glass and frames; <sup>3</sup> Roofs incl. skylights; <sup>4</sup> Partitions incl. internal windows and doors.

TEMPERATURES & SETPOINTS		
	Cooling	Heating
	°F	°F
Supply Air (design)	55.0	80.0
Room Setpoint (design)	82.0	70.0
Room (actual)	82.0	70.0
Mean Radiant Temperature	84.3	67.5
Dry Resultant Temperature	83.2	68.7
RH (Design Max Setpoint) (%)	-	-

AIRFLOW		
	Cooling	Heating
	cfm	cfm
Supply (design)	7,083	7,083
Reheat Minimum (design)	7,083	7,083
Leakage at Design Flow	0	0
Ventilation (requirement)	7,083	7,083
Exhaust (requirement)	6,197	6,197
Infiltration	177	177

CHECKS	
Number of People	25.00
ft²/Person	425.90
Average Ceiling Height (ft)	9.98
Btu/h/ft² - Cooling (sensible)	5.34
Btu/h/ft² - Heating	3.08
ft²/ton - Cooling (sensible)	2,245.78
ft²/ton - Heating	3,891.30
cfm/ft² - Cooling	0.67
cfm/ft² - Heating	0.67
% Outside Air - Cooling	100.00
% Outside Air - Heating	100.00
Outdoor Air cfm/ft²	0.67
Outdoor Air cfm/person	283.30

# Room Loads Report

Zone: DH-1  
System: 05 a VAV - Reheat

Long Center Option1  
DH-1 Pool Area (upper 1)  
HVAC Methodology: ApacheHVAC

IES VIRTUAL ENVIRONMENT

VE 2023



COOLING ROOM PEAK					
Time of Peak (Mo/Hr:Mn)					6 / 10:30
Outside Air (DBT/WBT/RH) °F and %RH					88.0 / 74.9 / 54.4
Room	Room Sensible	Room Latent	Net Value	Per Floor Area	Percent of Total
<b>Envelope Gains/Losses</b>	Btu/h	Btu/h	Btu/h	Btu/h-ft²	%
External Walls	-166	-	-166	-	-0.7
Roofs	0	-	0	-	0.0
Ground/Exposed Floors	0	-	0	-	0.0
External Doors	0	-	0	-	0.0
Windows Conduction	1,851	-	1,851	-	8.1
Skylights Conduction	0	-	0	-	0.0
Solar	11,521	-	11,521	-	50.3
Infiltration	1,288	1,340	2,628	-	11.5
Nat/Aux Vent	0	0	0	-	0.0
<b>Internal Building Gains/Losses</b>					
Internal Walls/Openings	7,075	-	7,075	-	30.9
Internal Floors	0	-	0	-	0.0
Internal Air & Furniture	0	-	0	-	0.0
Ceilings	0	-	0	-	0.0
Sub Total	21,570	1,340	22,910	0.0	
<b>Internal Gains</b>					
Lights	0	-	0	-	0.0
People	0	0	0	-	0.0
Misc, Computers, Equip	0	0	0	-	0.0
Sub Total	0	0	0	0.0	
<b>TOTAL</b>	<b>21,570</b>	<b>1,340</b>	<b>22,910</b>	<b>0.0</b>	<b>100</b>

COOLING SUMMARY	
Sensible cooling load (Btu/h):	21,570
Latent cooling load (Btu/h):	1,340
Sensible heat ratio:	0.94
Design Supply Airflow calculated per:	Sensible Loads
Design zone air temp for Supply Airflow calculation (°F):	82.0

HEATING ROOM PEAK					
Time of Peak (Mo/Hr:Mn)					Heating Design
Outside Air (DBT/WBT/RH) °F and %RH					42.1 / 35.4 / 49.6
Room	Room Sensible	Net Value	Per Floor Area	Percent of Total	
<b>Envelope Gains/Losses</b>	Btu/h	Btu/h	Btu/h-ft²	%	
External Walls	-2,335	-2,335	-	-	
Roofs	0	0	-	-	
Ground/Exposed Floors	0	0	-	-	
External Doors	0	0	-	-	
Windows Conduction	-3,214	-3,214	-	-	
Skylights Conduction	0	0	-	-	
Solar	0	0	-	-	
Infiltration	-7,638	-7,638	-	-	
Nat/Aux Vent	0	0	-	-	
<b>Internal Building Gains/Losses</b>					
Internal Walls/Openings	-7,756	-7,756	-	-	
Internal Floors	0	0	-	-	
Internal Air & Furniture	0	0	-	-	
Ceilings	0	0	-	-	
Sub Total	-20,942	-20,942	0.0		
<b>Internal Gains</b>					
Lights	0	0	-	-	
People	0	0	-	-	
Misc, Computers, Equip	0	0	-	-	
Sub Total	0	0	0.0		
<b>TOTAL</b>	<b>-20,942</b>	<b>-20,942</b>	<b>0.0</b>	<b>0</b>	

HEATING SUMMARY	
Sensible heating load (Btu/h):	20,942
Design zone air temp for Supply Airflow calculation (°F):	70.0

AREAS & THERMAL TRANSMITTANCE				
	Total Area	Glazing	Glazing	U-value <sup>1</sup>
	ft²	ft²	%	Btu/h-ft²-°F
<b>External</b>				
Wall (above grade)	1,334.4	376.7	28.2	0.15
Below Grade Walls	-	-	-	-
Windows <sup>2</sup>	376.7	376.7	100.0	0.30
Doors	-	-	-	-
Floors	-	-	-	-
Roofs <sup>3</sup>	-	-	-	-
<b>COMBINED</b>	<b>1,334.4</b>	<b>376.7</b>	<b>28.2</b>	<b>0.15</b>
<b>Internal</b>				
Ceilings	-	-	-	-
Floors	-	-	-	-
Partitions <sup>4</sup>	3,206.4	-	-	0.33

<sup>1</sup> Area-weighted U-value; <sup>2</sup> Windows/glazing include glass and frames; <sup>3</sup> Roofs incl. skylights; <sup>4</sup> Partitions incl. internal windows and doors.

TEMPERATURES & SETPOINTS		
	Cooling	Heating
	°F	°F
Supply Air (design)	55.0	80.0
Room Setpoint (design)	82.0	70.0
Room (actual)	82.0	70.0
Mean Radiant Temperature	83.4	68.0
Dry Resultant Temperature	82.7	69.0
RH (Design Max Setpoint) (%)	-	-

AIRFLOW		
	Cooling	Heating
	cfm	cfm
Supply (design)	5,001	5,001
Reheat Minimum (design)	5,001	5,001
Leakage at Design Flow	0	0
Ventilation (requirement)	5,001	5,001
Exhaust (requirement)	3,751	3,751
Infiltration	250	250

CHECKS	
Number of People	0.00
ft²/Person	-
Average Ceiling Height (ft)	14.09
Btu/h-ft² - Cooling (sensible)	-
Btu/h-ft² - Heating	-
ft²/ton - Cooling (sensible)	-
ft²/ton - Heating	-
cfm/ft² - Cooling	-
cfm/ft² - Heating	-
% Outside Air - Cooling	100.00
% Outside Air - Heating	100.00
Outdoor Air cfm/ft²	-
Outdoor Air cfm/person	-

# Room Loads Report

Zone: DH-1  
System: 05 a VAV - Reheat

Long Center Option1  
DH-1 Pool Area (upper 2)  
HVAC Methodology: ApacheHVAC

IES VIRTUAL ENVIRONMENT

VE 2023



COOLING ROOM PEAK					
Time of Peak (Mo/Hr:Mn)					6 / 11:30
Outside Air (DBT/WBT/RH) °F and %RH					90.3 / 75.7 / 51.3
Room	Room Sensible	Room Latent	Net Value	Per Floor Area	Percent of Total
<b>Envelope Gains/Losses</b>	Btu/h	Btu/h	Btu/h	Btu/h-ft²	%
External Walls	55	-	55	-	0.2
Roofs	3,401	-	3,401	-	11.7
Ground/Exposed Floors	0	-	0	-	0.0
External Doors	0	-	0	-	0.0
Windows Conduction	2,022	-	2,022	-	7.0
Skylights Conduction	0	-	0	-	0.0
Solar	16,719	-	16,719	-	57.7
Infiltration	1,950	1,576	3,526	-	12.2
Nat/Aux Vent	0	0	0	-	0.0
<b>Internal Building Gains/Losses</b>					
Internal Walls/Openings	3,237	-	3,237	-	11.2
Internal Floors	0	-	0	-	0.0
Internal Air & Furniture	0	-	0	-	0.0
Ceilings	0	-	0	-	0.0
Sub Total	27,383	1,576	28,959	0.0	
<b>Internal Gains</b>					
Lights	0	-	0	-	0.0
People	0	0	0	-	0.0
Misc, Computers, Equip	0	0	0	-	0.0
Sub Total	0	0	0	0.0	
<b>TOTAL</b>	<b>27,383</b>	<b>1,576</b>	<b>28,959</b>	<b>0.0</b>	<b>100</b>

COOLING SUMMARY	
Sensible cooling load (Btu/h):	27,383
Latent cooling load (Btu/h):	1,576
Sensible heat ratio:	0.95
Design Supply Airflow calculated per:	Sensible Loads
Design zone air temp for Supply Airflow calculation (°F):	82.0

HEATING ROOM PEAK					
Time of Peak (Mo/Hr:Mn)					Heating Design
Outside Air (DBT/WBT/RH) °F and %RH					42.1 / 35.4 / 49.6
Room	Room Value	Net Value	Per Floor Area	Percent of Total	
<b>Envelope Gains/Losses</b>	Btu/h	Btu/h	Btu/h-ft²	%	
External Walls	-2,360	-2,360	-	-	
Roofs	-7,521	-7,521	-	-	
Ground/Exposed Floors	0	0	-	-	
External Doors	0	0	-	-	
Windows Conduction	-3,181	-3,181	-	-	
Skylights Conduction	0	0	-	-	
Solar	0	0	-	-	
Infiltration	-7,638	-7,638	-	-	
Nat/Aux Vent	0	0	-	-	
<b>Internal Building Gains/Losses</b>					
Internal Walls/Openings	-6,754	-6,754	-	-	
Internal Floors	0	0	-	-	
Internal Air & Furniture	0	0	-	-	
Ceilings	0	0	-	-	
Sub Total	-27,454	-27,454	0.0		
<b>Internal Gains</b>					
Lights	0	0	-	-	
People	0	0	-	-	
Misc, Computers, Equip	0	0	-	-	
Sub Total	0	0	0.0		
<b>TOTAL</b>	<b>-27,454</b>	<b>-27,454</b>	<b>0.0</b>	<b>0</b>	

HEATING SUMMARY	
Sensible heating load (Btu/h):	27,454
Design zone air temp for Supply Airflow calculation (°F):	70.0

AREAS & THERMAL TRANSMITTANCE				
	Total Area	Glazing	Glazing	U-value <sup>1</sup>
	ft²	ft²	%	Btu/h-ft²-°F
<b>External</b>				
Wall (above grade)	1,334.4	371.3	27.8	0.14
Below Grade Walls	-	-	-	-
Windows <sup>2</sup>	371.3	371.3	100.0	0.30
Doors	-	-	-	-
Floors	-	-	-	-
Roofs <sup>3</sup>	10,647.6	-	-	0.02
<b>COMBINED</b>	<b>11,982.0</b>	<b>371.3</b>	<b>3.1</b>	<b>0.04</b>
<b>Internal</b>				
Ceilings	-	-	-	-
Floors	-	-	-	-
Partitions <sup>4</sup>	349.2	-	-	0.33

<sup>1</sup> Area-weighted U-value; <sup>2</sup> Windows/glazing include glass and frames; <sup>3</sup> Roofs incl. skylights; <sup>4</sup> Partitions incl. internal windows and doors.

TEMPERATURES & SETPOINTS		
	Cooling	Heating
	°F	°F
Supply Air (design)	55.0	80.0
Room Setpoint (design)	82.0	70.0
Room (actual)	82.0	70.0
Mean Radiant Temperature	83.3	68.1
Dry Resultant Temperature	82.6	69.1
RH (Design Max Setpoint) (%)	-	-

AIRFLOW		
	Cooling	Heating
	cfm	cfm
Supply (design)	5,001	5,001
Reheat Minimum (design)	5,001	5,001
Leakage at Design Flow	0	0
Ventilation (requirement)	5,001	5,001
Exhaust (requirement)	3,751	3,751
Infiltration	250	250

CHECKS	
Number of People	0.00
ft²/Person	-
Average Ceiling Height (ft)	14.09
Btu/h/ft² - Cooling (sensible)	-
Btu/h/ft² - Heating	-
ft²/ton - Cooling (sensible)	-
ft²/ton - Heating	-
cfm/ft² - Cooling	-
cfm/ft² - Heating	-
% Outside Air - Cooling	100.00
% Outside Air - Heating	100.00
Outdoor Air cfm/ft²	-
Outdoor Air cfm/person	-

# Room Loads Report

Zone: Dh-2  
System: 05 a VAV - Reheat

# Long Center Option1

30 Vestibule

HVAC Methodology: ApacheHVAC

IES VIRTUAL ENVIRONMENT

VE 2023



COOLING ROOM PEAK					
Time of Peak (Mo/Hr:Mn)					8 / 17:30
Outside Air (DBT/WBT/RH) °F and %RH					91.6 / 77.7 / 53.8
Room	Room Sensible	Room Latent	Net Value	Per Floor Area	Percent of Total
<b>Envelope Gains/Losses</b>	Btu/h	Btu/h	Btu/h	Btu/h-ft²	%
External Walls	-1,967	-	-1,967	-7.8	-9.5
Roofs	-1,177	-	-1,177	-4.7	-5.7
Ground/Exposed Floors	-1,659	-	-1,659	-6.6	-8.0
External Doors	0	-	0	0.0	0.0
Windows Conduction	1,887	-	1,887	7.5	9.1
Skylights Conduction	0	-	0	0.0	0.0
Solar	25,899	-	25,899	103.0	125.5
Infiltration	178	227	405	1.6	2.0
Nat/Aux Vent	0	0	0	0.0	0.0
<b>Internal Building Gains/Losses</b>					
Internal Walls/Opening	-3,356	-	-3,356	-13.3	-16.3
Internal Floors	0	-	0	0.0	0.0
Internal Air & Furniture	0	-	0	0.0	0.0
Ceilings	0	-	0	0.0	0.0
<b>Sub Total</b>	<b>19,805</b>	<b>227</b>	<b>20,032</b>	<b>79.6</b>	
<b>Internal Gains</b>					
Lights	429	-	429	1.7	2.1
People	0	0	0	0.0	0.0
Misc, Computers, Equip	172	0	172	0.7	0.8
<b>Sub Total</b>	<b>601</b>	<b>0</b>	<b>601</b>	<b>2.4</b>	
<b>TOTAL</b>	<b>20,406</b>	<b>227</b>	<b>20,633</b>	<b>82.0</b>	<b>100</b>

COOLING SUMMARY	
Sensible cooling load (Btu/h):	20,406
Latent cooling load (Btu/h):	227
Sensible heat ratio:	0.99
Design Supply Airflow calculated per:	Sensible Loads
Design zone air temp for Supply Airflow calculation (°F):	82.0

HEATING ROOM PEAK					
Time of Peak (Mo/Hr:Mn)					Heating Design
Outside Air (DBT/WBT/RH) °F and %RH					42.1 / 35.4 / 49.6
Room	Room Sensible	Room Latent	Net Value	Per Floor Area	Percent of Total
<b>Envelope Gains/Losses</b>	Btu/h	Btu/h	Btu/h	Btu/h-ft²	%
External Walls	-2,572	-2,572	-10.2	35.5	
Roofs	-173	-173	-0.7	2.4	
Ground/Exposed Floors	-1,312	-1,312	-5.2	18.1	
External Doors	0	0	0.0	0.0	
Windows Conduction	-3,033	-3,033	-12.1	41.9	
Skylights Conduction	0	0	0.0	0.0	
Solar	0	0	0.0	0.0	
Infiltration	-489	-489	-1.9	6.7	
Nat/Aux Vent	0	0	0.0	0.0	
<b>Internal Building Gains/Losses</b>					
Internal Walls/Opening	332	332	1.3	-4.6	
Internal Floors	0	0	0.0	0.0	
Internal Air & Furniture	0	0	0.0	0.0	
Ceilings	0	0	0.0	0.0	
<b>Sub Total</b>	<b>-7,246</b>	<b>-7,246</b>	<b>-28.8</b>		
<b>Internal Gains</b>					
Lights	0	0	0.0	0.0	
People	0	0	0.0	0.0	
Misc, Computers, Equip	0	0	0.0	0.0	
<b>Sub Total</b>	<b>0</b>	<b>0</b>	<b>0.0</b>		
<b>TOTAL</b>	<b>-7,246</b>	<b>-7,246</b>	<b>-28.8</b>	<b>100</b>	

HEATING SUMMARY	
Sensible heating load (Btu/h):	7,246
Design zone air temp for Supply Airflow calculation (°F):	70.0

AREAS & THERMAL TRANSMITTANCE				
	Total Area	Glazing	Glazing	U-value <sup>1</sup>
	ft²	ft²	%	Btu/h-ft²-°F
<b>External</b>				
Wall (above grade)	1,462.0	366.6	25.1	0.14
Below Grade Walls	-	-	-	-
Windows <sup>2</sup>	366.6	366.6	100.0	0.30
Doors	-	-	-	-
Floors	251.6	-	-	0.19
Roofs <sup>3</sup>	251.4	-	-	0.02
<b>COMBINED</b>	<b>1,965.0</b>	<b>366.6</b>	<b>18.7</b>	<b>0.13</b>
<b>Internal</b>				
Ceilings	-	-	-	-
Floors	-	-	-	-
Partitions <sup>4</sup>	1,192.2	-	-	0.33

<sup>1</sup> Area-weighted U-value; <sup>2</sup> Windows/glazing include glass and frames; <sup>3</sup> Roofs incl. skylights; <sup>4</sup> Partitions incl. internal windows and doors.

TEMPERATURES & SETPOINTS		
	Cooling	Heating
	°F	°F
Supply Air (design)	55.0	90.0
Room Setpoint (design)	82.0	70.0
Room (actual)	82.0	70.0
Mean Radiant Temperature	89.1	66.8
Dry Resultant Temperature	85.5	68.4
RH (Design Max Setpoint) (%)	-	-

AIRFLOW		
	Cooling	Heating
	cfm	cfm
Supply (design)	760	760
Reheat Minimum (design)	760	760
Leakage at Design Flow	0	0
Ventilation (requirement)	19	19
Exhaust (requirement)	-	-
Infiltration	16	16

CHECKS	
Number of People	0.00
ft²/Person	-
Average Ceiling Height (ft)	38.15
Btu/h/ft² - Cooling (sensible)	81.11
Btu/h/ft² - Heating	28.80
ft²/ton - Cooling (sensible)	147.94
ft²/ton - Heating	416.62
cfm/ft² - Cooling	3.02
cfm/ft² - Heating	3.02
% Outside Air - Cooling	2.48
% Outside Air - Heating	2.48
Outdoor Air cfm/ft²	0.08
Outdoor Air cfm/person	-

# Room Loads Report

Zone: Dh-2  
System: 05 a VAV - Reheat

# Long Center Option1

31 Vestibule

HVAC Methodology: ApacheHVAC

IES VIRTUAL ENVIRONMENT

VE 2023



COOLING ROOM PEAK					
Time of Peak (Mo/Hr:Mn)					9 / 10:30
Outside Air (DBT/WBT/RH) °F and %RH					87.7 / 75.3 / 56.6
Room	Room Sensible	Room Latent	Net Value	Per Floor Area	Percent of Total
<b>Envelope Gains/Losses</b>	Btu/h	Btu/h	Btu/h	Btu/h-ft²	%
External Walls	-1,035	-	-1,035	-3.9	-3.3
Roofs	-2,538	-	-2,538	-9.6	-8.2
Ground/Exposed Floors	-4,055	-	-4,055	-15.3	-13.0
External Doors	0	-	0	0.0	0.0
Windows Conduction	1,210	-	1,210	4.6	3.9
Skylights Conduction	0	-	0	0.0	0.0
Solar	43,870	-	43,870	165.9	141.1
Infiltration	83	130	213	0.8	0.7
Nat/Aux Vent	0	0	0	0.0	0.0
<b>Internal Building Gains/Losses</b>					
Internal Walls/Opening	-7,202	-	-7,202	-27.2	-23.2
Internal Floors	0	-	0	0.0	0.0
Internal Air & Furniture	0	-	0	0.0	0.0
Ceilings	0	-	0	0.0	0.0
Sub Total	30,333	130	30,463	115.2	
<b>Internal Gains</b>					
Lights	451	-	451	1.7	1.5
People	0	0	0	0.0	0.0
Misc, Computers, Equip	181	0	181	0.7	0.6
Sub Total	632	0	632	2.4	
<b>TOTAL</b>	<b>30,964</b>	<b>130</b>	<b>31,094</b>	<b>117.6</b>	<b>100</b>

COOLING SUMMARY	
Sensible cooling load (Btu/h):	30,964
Latent cooling load (Btu/h):	130
Sensible heat ratio:	1.00
Design Supply Airflow calculated per:	Sensible Loads
Design zone air temp for Supply Airflow calculation (°F):	82.0

HEATING ROOM PEAK					
Time of Peak (Mo/Hr:Mn)					Heating Design
Outside Air (DBT/WBT/RH) °F and %RH					42.1 / 35.4 / 49.6
Room	Room Sensible	Room Latent	Net Value	Per Floor Area	Percent of Total
<b>Envelope Gains/Losses</b>	Btu/h	Btu/h	Btu/h	Btu/h-ft²	%
External Walls	-731	-731	-2.8	7.0	
Roofs	-174	-174	-0.7	1.7	
Ground/Exposed Floors	-1,311	-1,311	-5.0	12.5	
External Doors	0	0	0.0	0.0	
Windows Conduction	-8,772	-8,772	-33.2	83.7	
Skylights Conduction	0	0	0.0	0.0	
Solar	0	0	0.0	0.0	
Infiltration	-514	-514	-1.9	4.9	
Nat/Aux Vent	0	0	0.0	0.0	
<b>Internal Building Gains/Losses</b>					
Internal Walls/Opening	1,022	1,022	3.9	-9.8	
Internal Floors	0	0	0.0	0.0	
Internal Air & Furniture	0	0	0.0	0.0	
Ceilings	0	0	0.0	0.0	
Sub Total	-10,480	-10,480	-39.6		
<b>Internal Gains</b>					
Lights	0	0	0.0	0.0	
People	0	0	0.0	0.0	
Misc, Computers, Equip	0	0	0.0	0.0	
Sub Total	0	0	0.0		
<b>TOTAL</b>	<b>-10,480</b>	<b>-10,480</b>	<b>-39.6</b>	<b>100</b>	

HEATING SUMMARY	
Sensible heating load (Btu/h):	10,480
Design zone air temp for Supply Airflow calculation (°F):	70.0

AREAS & THERMAL TRANSMITTANCE				
	Total Area	Glazing	Glazing	U-value <sup>1</sup>
	ft²	ft²	%	Btu/h-ft²-°F
<b>External</b>				
Wall (above grade)	1,453.8	816.5	56.2	0.27
Below Grade Walls	-	-	-	-
Windows <sup>2</sup>	816.5	816.5	100.0	0.41
Doors	-	-	-	-
Floors	264.5	-	-	0.19
Roofs <sup>3</sup>	264.5	-	-	0.02
<b>COMBINED</b>	<b>1,982.8</b>	<b>816.5</b>	<b>41.2</b>	<b>0.23</b>
<b>Internal</b>				
Ceilings	-	-	-	-
Floors	-	-	-	-
Partitions <sup>4</sup>	1,061.3	-	-	0.33

<sup>1</sup> Area-weighted U-value; <sup>2</sup> Windows/glazing include glass and frames; <sup>3</sup> Roofs incl. skylights; <sup>4</sup> Partitions incl. internal windows and doors.

TEMPERATURES & SETPOINTS		
	Cooling	Heating
	°F	°F
Supply Air (design)	55.0	90.0
Room Setpoint (design)	82.0	70.0
Room (actual)	82.0	70.0
Mean Radiant Temperature	93.7	64.9
Dry Resultant Temperature	87.9	67.4
RH (Design Max Setpoint) (%)	-	-

AIRFLOW		
	Cooling	Heating
	cfm	cfm
Supply (design)	1,153	1,153
Reheat Minimum (design)	1,153	1,153
Leakage at Design Flow	0	0
Ventilation (requirement)	20	20
Exhaust (requirement)	-	-
Infiltration	17	17

CHECKS	
Number of People	0.00
ft²/Person	-
Average Ceiling Height (ft)	38.17
Btu/h-ft² - Cooling (sensible)	117.08
Btu/h-ft² - Heating	39.63
ft²/ton - Cooling (sensible)	102.49
ft²/ton - Heating	302.83
cfm/ft² - Cooling	4.36
cfm/ft² - Heating	4.36
% Outside Air - Cooling	1.72
% Outside Air - Heating	1.72
Outdoor Air cfm/ft²	0.07
Outdoor Air cfm/person	-

# Room Loads Report

Zone: Dh-2  
System: 05 a VAV - Reheat

# Long Center Option1 32 DH-2 Pool Area Circulation HVAC Methodology: ApacheHVAC

IES VIRTUAL ENVIRONMENT

VE 2023



COOLING ROOM PEAK					
Time of Peak (Mo/Hr:Mn)					6 / 8:30
Outside Air (DBT/WBT/RH) °F and %RH					82.6 / 72.9 / 63.1
Room	Room Sensible	Room Latent	Net Value	Per Floor Area	Percent of Total
<b>Envelope Gains/Losses</b>	Btu/h	Btu/h	Btu/h	Btu/h-ft²	%
External Walls	-473	-	-473	-0.4	-2.6
Roofs	924	-	924	0.8	5.2
Ground/Exposed Floors	0	-	0	0.0	0.0
External Doors	0	-	0	0.0	0.0
Windows Conduction	-9	-	-9	0.0	-0.1
Skylights Conduction	0	-	0	0.0	0.0
Solar	13,576	-	13,576	11.4	75.8
Infiltration	-60	258	198	0.2	1.1
Nat/Aux Vent	0	0	0	0.0	0.0
<b>Internal Building Gains/Losses</b>					
Internal Walls/Openings	849	-	849	0.7	4.7
Internal Floors	0	-	0	0.0	0.0
Internal Air & Furniture	8	-	8	0.0	0.0
Ceilings	10	-	10	0.0	0.1
Sub Total	14,826	258	15,084	12.7	
<b>Internal Gains</b>					
Lights	2,026	-	2,026	1.7	11.3
People	0	0	0	0.0	0.0
Misc, Computers, Equip	811	0	811	0.7	4.5
Sub Total	2,837	0	2,837	2.4	
<b>TOTAL</b>	<b>17,663</b>	<b>258</b>	<b>17,921</b>	<b>15.1</b>	<b>100</b>

COOLING SUMMARY	
Sensible cooling load (Btu/h):	17,663
Latent cooling load (Btu/h):	258
Sensible heat ratio:	0.99
Design Supply Airflow calculated per:	Sensible Loads
Design zone air temp for Supply Airflow calculation (°F):	82.0

HEATING ROOM PEAK					
Time of Peak (Mo/Hr:Mn)					Heating Design
Outside Air (DBT/WBT/RH) °F and %RH					42.1 / 35.4 / 49.6
Room	Room Sensible	Room Net Value	Per Floor Area	Percent of Total	
<b>Envelope Gains/Losses</b>	Btu/h	Btu/h	Btu/h-ft²	%	
External Walls	-8,861	-8,861	-7.5	51.3	
Roofs	-806	-806	-0.7	4.7	
Ground/Exposed Floors	-6,690	-6,690	-5.6	38.7	
External Doors	0	0	0.0	0.0	
Windows Conduction	-417	-417	-0.4	2.4	
Skylights Conduction	0	0	0.0	0.0	
Solar	0	0	0.0	0.0	
Infiltration	-2,261	-2,261	-1.9	13.1	
Nat/Aux Vent	0	0	0.0	0.0	
<b>Internal Building Gains/Losses</b>					
Internal Walls/Openings	1,752	1,752	1.5	-10.1	
Internal Floors	0	0	0.0	0.0	
Internal Air & Furniture	0	0	0.0	0.0	
Ceilings	0	0	0.0	0.0	
Sub Total	-17,283	-17,283	-14.6		
<b>Internal Gains</b>					
Lights	0	0	0.0	0.0	
People	0	0	0.0	0.0	
Misc, Computers, Equip	0	0	0.0	0.0	
Sub Total	0	0	0.0		
<b>TOTAL</b>	<b>-17,283</b>	<b>-17,283</b>	<b>-14.6</b>	<b>100</b>	

HEATING SUMMARY	
Sensible heating load (Btu/h):	17,283
Design zone air temp for Supply Airflow calculation (°F):	70.0

AREAS & THERMAL TRANSMITTANCE				
	Total Area	Glazing	Glazing	U-value <sup>1</sup>
	ft²	ft²	%	Btu/h-ft²-°F
<b>External</b>				
Wall (above grade)	3,735.4	28.7	0.8	0.09
Below Grade Walls	-	-	-	-
Windows <sup>2</sup>	28.7	28.7	100.0	0.53
Doors	-	-	-	-
Floors	1,187.8	-	-	0.19
Roofs <sup>3</sup>	1,143.6	-	-	0.02
<b>COMBINED</b>	<b>6,066.8</b>	<b>28.7</b>	<b>0.5</b>	<b>0.10</b>
<b>Internal</b>				
Ceilings	44.1	-	-	0.05
Floors	-	-	-	-
Partitions <sup>4</sup>	2,305.0	-	-	0.33

<sup>1</sup> Area-weighted U-value; <sup>2</sup> Windows/glazing include glass and frames; <sup>3</sup> Roofs incl. skylights; <sup>4</sup> Partitions incl. internal windows and doors.

TEMPERATURES & SETPOINTS		
	Cooling	Heating
	°F	°F
Supply Air (design)	55.0	90.0
Room Setpoint (design)	82.0	70.0
Room (actual)	82.0	70.0
Mean Radiant Temperature	83.5	68.0
Dry Resultant Temperature	82.7	69.0
RH (Design Max Setpoint) (%)	-	-

AIRFLOW		
	Cooling	Heating
	cfm	cfm
Supply (design)	2,221	2,221
Reheat Minimum (design)	2,221	2,221
Leakage at Design Flow	0	0
Ventilation (requirement)	2,221	2,221
Exhaust (requirement)	1,480	1,480
Infiltration	74	74

CHECKS	
Number of People	0.00
ft²/Person	-
Average Ceiling Height (ft)	37.39
Btu/h/ft² - Cooling (sensible)	14.87
Btu/h/ft² - Heating	14.55
ft²/ton - Cooling (sensible)	806.93
ft²/ton - Heating	824.71
cfm/ft² - Cooling	1.87
cfm/ft² - Heating	1.87
% Outside Air - Cooling	100.00
% Outside Air - Heating	100.00
Outdoor Air cfm/ft²	1.87
Outdoor Air cfm/person	-

# Room Loads Report

Zone: Dh-2  
System: 05 a VAV - Reheat

## Long Center Option1 DH-2 Pool Area HVAC Methodology: ApacheHVAC

IES VIRTUAL ENVIRONMENT

VE 2023



COOLING ROOM PEAK					
Time of Peak (Mo/Hr:Mn)					6 / 10:30
Outside Air (DBT/WBT/RH) °F and %RH					88.0 / 74.9 / 54.4
Room	Room Sensible	Room Latent	Net Value	Per Floor Area	Percent of Total
<b>Envelope Gains/Losses</b>	Btu/h	Btu/h	Btu/h	Btu/h-ft²	%
External Walls	-100	-	-100	0.0	0.0
Roofs	0	-	0	0.0	0.0
Ground/Exposed Floors	-3,852	-	-3,852	-0.3	-0.8
External Doors	0	-	0	0.0	0.0
Windows Conduction	2,251	-	2,251	0.2	0.5
Skylights Conduction	0	-	0	0.0	0.0
Solar	48,183	-	48,183	4.2	10.5
Infiltration	992	2,119	3,111	0.3	0.7
Nat/Aux Vent	0	0	0	0.0	0.0
<b>Internal Building Gains/Losses</b>					
Internal Walls/Openings	-12,140	-	-12,140	-1.0	-2.7
Internal Floors	-2,329	-	-2,329	-0.2	-0.5
Internal Air & Furniture	0	-	0	0.0	0.0
Ceilings	0	-	0	0.0	0.0
Sub Total	33,005	2,119	35,124	3.0	
<b>Internal Gains</b>					
Lights	35,560	-	35,560	3.1	7.8
People	17,750	27,250	45,000	3.9	9.8
Misc, Computers, Equip	0	341,222	341,222	29.5	74.7
Sub Total	53,310	368,472	421,783	36.4	
<b>TOTAL</b>	<b>86,315</b>	<b>370,592</b>	<b>456,907</b>	<b>39.5</b>	<b>100</b>

COOLING SUMMARY	
Sensible cooling load (Btu/h):	86,315
Latent cooling load (Btu/h):	370,592
Sensible heat ratio:	0.19
Design Supply Airflow calculated per:	Sensible Loads
Design zone air temp for Supply Airflow calculation (°F):	82.0

HEATING ROOM PEAK					
Time of Peak (Mo/Hr:Mn)					Heating Design
Outside Air (DBT/WBT/RH) °F and %RH					42.1 / 35.4 / 49.6
Room	Room Sensible	Room Latent	Net Value	Per Floor Area	Percent of Total
<b>Envelope Gains/Losses</b>	Btu/h	Btu/h	Btu/h	Btu/h-ft²	%
External Walls	-1,063	-1,063	-0.1	3.2	
Roofs	0	0	0.0	0.0	
Ground/Exposed Floors	-6,133	-6,133	-0.5	18.5	
External Doors	0	0	0.0	0.0	
Windows Conduction	-4,977	-4,977	-0.4	15.0	
Skylights Conduction	0	0	0.0	0.0	
Solar	0	0	0.0	0.0	
Infiltration	-5,882	-5,882	-0.5	17.7	
Nat/Aux Vent	0	0	0.0	0.0	
<b>Internal Building Gains/Losses</b>					
Internal Walls/Openings	3,761	3,761	0.3	-11.3	
Internal Floors	-18,913	-18,913	-1.6	57.0	
Internal Air & Furniture	0	0	0.0	0.0	
Ceilings	0	0	0.0	0.0	
Sub Total	-33,207	-33,207	-2.9		
<b>Internal Gains</b>					
Lights	0	0	0.0	0.0	
People	0	0	0.0	0.0	
Misc, Computers, Equip	0	0	0.0	0.0	
Sub Total	0	0	0.0		
<b>TOTAL</b>	<b>-33,207</b>	<b>-33,207</b>	<b>-2.9</b>	<b>100</b>	

HEATING SUMMARY	
Sensible heating load (Btu/h):	33,207
Design zone air temp for Supply Airflow calculation (°F):	70.0

AREAS & THERMAL TRANSMITTANCE				
	Total Area	Glazing	Glazing	U-value <sup>1</sup>
	ft²	ft²	%	Btu/h-ft²-°F
<b>External</b>				
Wall (above grade)	1,027.6	594.8	57.9	0.21
Below Grade Walls	-	-	-	-
Windows <sup>2</sup>	594.8	594.8	100.0	0.30
Doors	-	-	-	-
Floors	4,432.2	-	-	0.05
Roofs <sup>3</sup>	-	-	-	-
<b>COMBINED</b>	<b>5,459.8</b>	<b>594.8</b>	<b>10.9</b>	<b>0.08</b>
<b>Internal</b>				
Ceilings	-	-	-	-
Floors	7,147.5	-	-	0.19
Partitions <sup>4</sup>	344.5	-	-	0.33

<sup>1</sup> Area-weighted U-value; <sup>2</sup> Windows/glazing include glass and frames; <sup>3</sup> Roofs incl. skylights; <sup>4</sup> Partitions incl. internal windows and doors.

TEMPERATURES & SETPOINTS		
	Cooling	Heating
	°F	°F
Supply Air (design)	55.0	90.0
Room Setpoint (design)	82.0	70.0
Room (actual)	82.0	70.0
Mean Radiant Temperature	84.8	67.9
Dry Resultant Temperature	83.4	68.9
RH (Design Max Setpoint) (%)	-	-

AIRFLOW		
	Cooling	Heating
	cfm	cfm
Supply (design)	5,777	5,777
Reheat Minimum (design)	5,777	5,777
Leakage at Design Flow	0	0
Ventilation (requirement)	5,777	5,777
Exhaust (requirement)	4,814	4,814
Infiltration	193	193

CHECKS	
Number of People	25.00
ft²/Person	463.19
Average Ceiling Height (ft)	9.98
Btu/h/ft² - Cooling (sensible)	7.45
Btu/h/ft² - Heating	2.87
ft²/ton - Cooling (sensible)	1,609.87
ft²/ton - Heating	4,184.57
cfm/ft² - Cooling	0.50
cfm/ft² - Heating	0.50
% Outside Air - Cooling	100.00
% Outside Air - Heating	100.00
Outdoor Air cfm/ft²	0.50
Outdoor Air cfm/person	231.08

# Room Loads Report

Zone: Dh-2  
System: 05 a VAV - Reheat

# Long Center Option1 DH-2 Pool Area (upper 1) HVAC Methodology: ApacheHVAC

IES VIRTUAL ENVIRONMENT

VE 2023



COOLING ROOM PEAK					
Time of Peak (Mo/Hr:Mn)					8 / 10:30
Outside Air (DBT/WBT/RH) °F and %RH					88.2 / 76.5 / 58.6
Room	Room Sensible	Room Latent	Net Value	Per Floor Area	Percent of Total
<b>Envelope Gains/Losses</b>	Btu/h	Btu/h	Btu/h	Btu/h-ft <sup>2</sup>	%
External Walls	-87	-	-87	-	-0.3
Roofs	0	-	0	-	0.0
Ground/Exposed Floors	0	-	0	-	0.0
External Doors	0	-	0	-	0.0
Windows Conduction	2,193	-	2,193	-	8.4
Skylights Conduction	0	-	0	-	0.0
Solar	11,373	-	11,373	-	43.4
Infiltration	1,497	3,197	4,693	-	17.9
Nat/Aux Vent	0	0	0	-	0.0
<b>Internal Building Gains/Losses</b>					
Internal Walls/Opening	8,018	-	8,018	-	30.6
Internal Floors	0	-	0	-	0.0
Internal Air & Furniture	0	-	0	-	0.0
Ceilings	0	-	0	-	0.0
Sub Total	22,994	3,197	26,191	0.0	
<b>Internal Gains</b>					
Lights	0	-	0	-	0.0
People	0	0	0	-	0.0
Misc, Computers, Equip	0	0	0	-	0.0
Sub Total	0	0	0	0.0	
<b>TOTAL</b>	<b>22,994</b>	<b>3,197</b>	<b>26,191</b>	<b>0.0</b>	<b>100</b>

COOLING SUMMARY	
Sensible cooling load (Btu/h):	22,994
Latent cooling load (Btu/h):	3,197
Sensible heat ratio:	0.88
Design Supply Airflow calculated per:	Sensible Loads
Design zone air temp for Supply Airflow calculation (°F):	82.0

HEATING ROOM PEAK					
Time of Peak (Mo/Hr:Mn)					Heating Design
Outside Air (DBT/WBT/RH) °F and %RH					42.1 / 35.4 / 49.6
Room	Room Sensible	Room Latent	Net Value	Per Floor Area	Percent of Total
<b>Envelope Gains/Losses</b>	Btu/h	Btu/h	Btu/h	Btu/h-ft <sup>2</sup>	%
External Walls	-2,511	-2,511	-	-	-
Roofs	0	0	-	-	-
Ground/Exposed Floors	0	0	-	-	-
External Doors	0	0	-	-	-
Windows Conduction	-3,758	-3,758	-	-	-
Skylights Conduction	0	0	-	-	-
Solar	0	0	-	-	-
Infiltration	-8,306	-8,306	-	-	-
Nat/Aux Vent	0	0	-	-	-
<b>Internal Building Gains/Losses</b>					
Internal Walls/Opening	-4,826	-4,826	-	-	-
Internal Floors	0	0	-	-	-
Internal Air & Furniture	0	0	-	-	-
Ceilings	0	0	-	-	-
Sub Total	-19,401	-19,401	0.0		
<b>Internal Gains</b>					
Lights	0	0	-	-	-
People	0	0	-	-	-
Misc, Computers, Equip	0	0	-	-	-
Sub Total	0	0	0.0		
<b>TOTAL</b>	<b>-19,401</b>	<b>-19,401</b>	<b>0.0</b>	<b>0.0</b>	<b>0</b>

HEATING SUMMARY	
Sensible heating load (Btu/h):	19,401
Design zone air temp for Supply Airflow calculation (°F):	70.0

AREAS & THERMAL TRANSMITTANCE				
	Total Area	Glazing	Glazing	U-value <sup>1</sup>
	ft <sup>2</sup>	ft <sup>2</sup>	%	Btu/h-ft <sup>2</sup> -°F
<b>External</b>				
Wall (above grade)	1,451.2	434.7	30.0	0.15
Below Grade Walls	-	-	-	-
Windows <sup>2</sup>	434.7	434.7	100.0	0.30
Doors	-	-	-	-
Floors	-	-	-	-
Roofs <sup>3</sup>	-	-	-	-
<b>COMBINED</b>	<b>1,451.2</b>	<b>434.7</b>	<b>30.0</b>	<b>0.15</b>
<b>Internal</b>				
Ceilings	-	-	-	-
Floors	-	-	-	-
Partitions <sup>4</sup>	3,412.3	-	-	0.33

<sup>1</sup> Area-weighted U-value; <sup>2</sup> Windows/glazing include glass and frames; <sup>3</sup> Roofs incl. skylights; <sup>4</sup> Partitions incl. internal windows and doors.

TEMPERATURES & SETPOINTS		
	Cooling	Heating
	°F	°F
Supply Air (design)	55.0	90.0
Room Setpoint (design)	82.0	70.0
Room (actual)	82.0	70.0
Mean Radiant Temperature	83.4	68.6
Dry Resultant Temperature	82.7	69.3
RH (Design Max Setpoint) (%)	-	-

AIRFLOW		
	Cooling	Heating
	cfm	cfm
Supply (design)	5,439	5,439
Reheat Minimum (design)	5,439	5,439
Leakage at Design Flow	0	0
Ventilation (requirement)	5,439	5,439
Exhaust (requirement)	4,079	4,079
Infiltration	272	272

CHECKS	
Number of People	0.00
ft <sup>2</sup> /Person	-
Average Ceiling Height (ft)	14.09
Btu/h/ft <sup>2</sup> - Cooling (sensible)	-
Btu/h/ft <sup>2</sup> - Heating	-
ft <sup>2</sup> /ton - Cooling (sensible)	-
ft <sup>2</sup> /ton - Heating	-
cfm/ft <sup>2</sup> - Cooling	-
cfm/ft <sup>2</sup> - Heating	-
% Outside Air - Cooling	100.00
% Outside Air - Heating	100.00
Outdoor Air cfm/ft <sup>2</sup>	-
Outdoor Air cfm/person	-

# Room Loads Report

Zone: Dh-2  
System: 05 a VAV - Reheat

Long Center Option1  
DH-2 Pool Area (upper 2)  
HVAC Methodology: ApacheHVAC

IES VIRTUAL ENVIRONMENT

VE 2023



COOLING ROOM PEAK					
Time of Peak (Mo/Hr:Mn)					6 / 10:30
Outside Air (DBT/WBT/RH) °F and %RH					88.0 / 74.9 / 54.4
Room	Room Sensible	Room Latent	Net Value	Per Floor Area	Percent of Total
<b>Envelope Gains/Losses</b>	Btu/h	Btu/h	Btu/h	Btu/h-ft²	%
External Walls	11	-	11	-	0.0
Roofs	6,567	-	6,567	-	22.9
Ground/Exposed Floors	0	-	0	-	0.0
External Doors	0	-	0	-	0.0
Windows Conduction	2,131	-	2,131	-	7.4
Skylights Conduction	0	-	0	-	0.0
Solar	15,280	-	15,280	-	53.3
Infiltration	1,401	1,457	2,858	-	10.0
Nat/Aux Vent	0	0	0	-	0.0
<b>Internal Building Gains/Losses</b>					
Internal Walls/Openings	1,817	-	1,817	-	6.3
Internal Floors	0	-	0	-	0.0
Internal Air & Furniture	0	-	0	-	0.0
Ceilings	0	-	0	-	0.0
<b>Sub Total</b>	<b>27,207</b>	<b>1,457</b>	<b>28,664</b>	<b>0.0</b>	
<b>Internal Gains</b>					
Lights	0	-	0	-	0.0
People	0	0	0	-	0.0
Misc, Computers, Equip	0	0	0	-	0.0
<b>Sub Total</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0.0</b>	
<b>TOTAL</b>	<b>27,207</b>	<b>1,457</b>	<b>28,664</b>	<b>0.0</b>	<b>100</b>

COOLING SUMMARY	
Sensible cooling load (Btu/h):	27,207
Latent cooling load (Btu/h):	1,457
Sensible heat ratio:	0.95
Design Supply Airflow calculated per:	Sensible Loads
Design zone air temp for Supply Airflow calculation (°F):	82.0

HEATING ROOM PEAK					
Time of Peak (Mo/Hr:Mn)					Heating Design
Outside Air (DBT/WBT/RH) °F and %RH					42.1 / 35.4 / 49.6
Room	Room Value	Net Value	Per Floor Area	Percent of Total	
<b>Envelope Gains/Losses</b>	Btu/h	Btu/h	Btu/h-ft²	%	
External Walls	-2,540	-2,540	-	-	
Roofs	-8,271	-8,271	-	-	
Ground/Exposed Floors	0	0	-	-	
External Doors	0	0	-	-	
Windows Conduction	-3,693	-3,693	-	-	
Skylights Conduction	0	0	-	-	
Solar	0	0	-	-	
Infiltration	-8,306	-8,306	-	-	
Nat/Aux Vent	0	0	-	-	
<b>Internal Building Gains/Losses</b>					
Internal Walls/Openings	-2,542	-2,542	-	-	
Internal Floors	0	0	-	-	
Internal Air & Furniture	0	0	-	-	
Ceilings	0	0	-	-	
<b>Sub Total</b>	<b>-25,352</b>	<b>-25,352</b>	<b>0.0</b>		
<b>Internal Gains</b>					
Lights	0	0	-	-	
People	0	0	-	-	
Misc, Computers, Equip	0	0	-	-	
<b>Sub Total</b>	<b>0</b>	<b>0</b>	<b>0.0</b>		
<b>TOTAL</b>	<b>-25,352</b>	<b>-25,352</b>	<b>0.0</b>	<b>0</b>	

HEATING SUMMARY	
Sensible heating load (Btu/h):	25,352
Design zone air temp for Supply Airflow calculation (°F):	70.0

AREAS & THERMAL TRANSMITTANCE				
	Total Area	Glazing	Glazing	U-value <sup>1</sup>
	ft²	ft²	%	Btu/h-ft²-°F
<b>External</b>				
Wall (above grade)	1,451.2	426.3	29.4	0.15
Below Grade Walls	-	-	-	-
Windows <sup>2</sup>	426.3	426.3	100.0	0.30
Doors	-	-	-	-
Floors	-	-	-	-
Roofs <sup>3</sup>	11,579.7	-	-	0.02
<b>COMBINED</b>	<b>13,030.9</b>	<b>426.3</b>	<b>3.3</b>	<b>0.04</b>
<b>Internal</b>				
Ceilings	-	-	-	-
Floors	-	-	-	-
Partitions <sup>4</sup>	471.9	-	-	0.33

<sup>1</sup> Area-weighted U-value; <sup>2</sup> Windows/glazing include glass and frames; <sup>3</sup> Roofs incl. skylights; <sup>4</sup> Partitions incl. internal windows and doors.

TEMPERATURES & SETPOINTS		
	Cooling	Heating
	°F	°F
Supply Air (design)	55.0	90.0
Room Setpoint (design)	82.0	70.0
Room (actual)	82.0	70.0
Mean Radiant Temperature	83.2	68.7
Dry Resultant Temperature	82.6	69.3
RH (Design Max Setpoint) (%)	-	-

AIRFLOW		
	Cooling	Heating
	cfm	cfm
Supply (design)	5,439	5,439
Reheat Minimum (design)	5,439	5,439
Leakage at Design Flow	0	0
Ventilation (requirement)	5,439	5,439
Exhaust (requirement)	4,079	4,079
Infiltration	272	272

CHECKS	
Number of People	0.00
ft²/Person	-
Average Ceiling Height (ft)	14.09
Btu/h-ft² - Cooling (sensible)	-
Btu/h-ft² - Heating	-
ft²/ton - Cooling (sensible)	-
ft²/ton - Heating	-
cfm/ft² - Cooling	-
cfm/ft² - Heating	-
% Outside Air - Cooling	100.00
% Outside Air - Heating	100.00
Outdoor Air cfm/ft²	-
Outdoor Air cfm/person	-



9942 Currie Davis Dr., Ste. H  
Tampa, FL 33619  
813.995.0300  
emeraldme.com  
FL EB # 0027845





## **APPENDIX D**




<b>Project:</b>	Long Center Natatorium - Option2
<b>Address:</b>	1501 Belcher Rd. Clearwater FL 33765
<b>Climate File:</b>	USA_FL_St.Petersburg-Clearwater.Intl.AP.722116_TMY3.epw
<b>Simulation:</b>	Natorium Option2_1206.aps

<b>Design Team:</b>	Wannemacher Jensen Architects
<b>Energy Analyst:</b>	REAL Building Consultants LLC
<b>Owner:</b>	City of Clearwater
<b>Conditioned Area (ft²):</b>	34959.4935

Annual Energy Consumption (kBtu/ft²/year) & CO2 KgCO2/ft²/yr				
Energy End Use	Site Energy	Source Energy	CO2 Emissions	
Heating Fossil Fuel	0.0	0.0	0.0	
Heating Electricity	45.8	144.3	8.1	
Space Cooling	23.2	73.1	4.1	
Fans Interior	10.5	33.0	1.8	
Heat Rejection	1.5	4.7	0.3	
Pumps	0.0	0.0	0.0	
DHW Fossil Fuel	0.0	0.0	0.0	
DHW Electricity	0.0	0.0	0.0	
Interior Lighting	4.8	15.0	0.8	
Exterior Lighting	0.0	0.0	0.0	
Receptacle	1.9	6.1	0.3	
Data Center	0.0	0.0	0.0	
Cooking Fossil Fuel	0.0	0.0	0.0	
Cooking Electricity	0.0	0.0	0.0	
Elevators & Escalators	0.0	0.0	0.0	
Refrigeration	0.0	0.0	0.0	
Process	0.0	0.0	0.0	
<b>TOTAL (ex renewables)</b>	<b>87</b>	<b>276</b>	<b>15</b>	



Annual Fuel Costs and Peak Demands				
Fuels	Cost (£)	Peak Day	Peak Time	Peak Demand
Electricity	53,900.00	24-Jan	8:00	446.6 kW
Fossil Fuel	0.00	01-Jan	0:00	0.0 kBtu/h
<b>Total</b>	<b>53,900.00</b>	<b>01-Jan</b>	<b>0:00</b>	





# Virtual Environment 2023

Copyright © 2023 Integrated Environmental Solutions Limited.

Option#2 Energy Consumption HVAC					
Month	Space Heating (MBtu)	Space Cooling (MBtu)	Heat Rejection (MBtu)	Interior Central Fans (MBtu)	Total HVAC Energy
Jan 01-31	271.63	0.17	0.01	46.76	318.57
Feb 01-28	160.31	7.70	0.49	34.56	203.06
Mar 01-31	136.45	19.14	1.22	33.17	189.98
Apr 01-30	86.62	43.11	2.75	26.64	159.11
May 01-31	130.46	101.32	6.47	27.45	265.69
Jun 01-30	132.97	118.73	7.58	26.65	285.93
Jul 01-31	148.18	147.34	9.41	28.68	333.60
Aug 01-31	140.20	133.98	8.55	27.55	310.27
Sep 01-30	134.34	123.41	7.88	26.95	292.57
Oct 01-31	108.49	84.81	5.41	27.80	226.51
Nov 01-30	53.22	26.84	1.71	26.05	107.83
Dec 01-31	98.67	5.02	0.32	33.96	137.96
Summed total	1,601.52	811.55	51.80	366.19	2,831.07

Option#2 Electricity (\$0.105/kWh) blended rate		
Month	Net electricity usage [kWh]	Total net charges [\$]
January	99,295.70	\$ 10,426.05
February	64,772.67	\$ 6,801.13
March	61,360.73	\$ 6,442.88
April	52,340.30	\$ 5,495.73
May	83,683.48	\$ 8,786.77
June	89,373.98	\$ 9,384.27
July	103,702.98	\$ 10,888.81
August	96,613.71	\$ 10,144.44
September	91,453.55	\$ 9,602.62
October	72,317.91	\$ 7,593.38
November	37,059.60	\$ 3,891.26
December	46,366.75	\$ 4,868.51
Total year	898,341.38	\$ 94,325.85



Use global inputs for oversizing (yes/no): **no**  
 Cooling (Sensible) Load Oversizing Factor: 10%  
 Cooling (Latent) Load Oversizing Factor: 10%  
 Heating Load Oversizing Factor: 10%

Date: **2023-12-06**

Loads reported below are non-coincident room- and zone-level loads

Zone group	Zone	Room	Template	Floor area (ft <sup>2</sup> )	Volume (ft <sup>3</sup> )	Cooling occupied setpoint (°F)	Sensible cooling load (without oversizing)		Cooling design load oversizing factor	Cooling design load with oversizing (kBtu/h)	Cooling supply air temperature (°F)	Cooling design airflow (sensible cooling maximum)			Max RH setpoint (%)	Latent cooling load without oversizing (kBtu/h)	Design latent cooling load with oversizing (kBtu/h)	Cooling design load oversizing factor from cooling load	
							Month/time	(kBtu/h)				(Btu/h.ft <sup>2</sup> )	(cfm)	(ACH)					(cfm/ft <sup>2</sup> )
DH-1	DH-1	29 DH-1 Pool area North Circulation	SPACE: Corridor - All Other Corridors	1,853.3	53,109.4	82.0	Jun 15:30	74.80	40.36	1.10	82.28	55.0	2,785.7	3.15	1.50	60.0	3.13	3.44	1.1
		DH-1 Pool Area	SPACE: Gymnasium/ Fitness center - Exercise area	10,647.6	106,238.4	82.0	Jun 17:30	62.96	5.91	1.10	69.26	55.0	2,344.8	1.32	0.22	55.0	344.65	379.11	1.1
		DH-1 Pool Area (upper 1)	SPACE: Corridor - All Other Corridors	10,647.6	150,037.4	82.0	Jun 17:30	26.05	2.45	1.10	28.65	55.0	970.1	0.39	0.09	60.0	9.86	10.84	1.1
DH-2	DH-2	DH-1 Pool Area (upper 2)	SPACE: Corridor - All Other Corridors	10,647.6	150,037.4	82.0	Jun 17:30	34.95	3.28	1.10	38.44	55.0	1,301.5	0.52	0.12	60.0	10.62	11.68	1.1
		23 Spectator Area	SPACE: Audience Seating Area - Exercise Center	9,175.0	191,146.9	82.0	Sep 17:30	53.81	5.86	1.10	59.19	55.0	2,003.7	0.63	0.22	60.0	14.00	15.40	1.1
		30 Vestibule	SPACE: Corridor - All Other Corridors	251.6	9,596.6	82.0	Jul 7:30	3.30	13.13	1.00	3.30	55.0	111.8	0.70	0.44	60.0	0.70	0.70	1.1
		31 Vestibule	SPACE: Corridor - All Other Corridors	264.5	10,094.0	82.0	Sep 11:30	15.42	58.29	1.00	15.42	55.0	521.9	3.10	1.97	60.0	0.74	0.74	1.1
		32 DH-2 Pool Area Circulation	SPACE: Corridor - All Other Corridors	1,187.8	44,412.8	82.0	Jun 17:30	21.39	18.01	1.00	21.39	55.0	724.1	0.98	0.61	60.0	3.25	3.25	1.1
		DH-2 Pool Area	SPACE: Gymnasium/ Fitness center - Exercise area	11,579.7	115,538.8	82.0	Aug 17:30	80.45	6.95	1.00	80.45	55.0	2,723.8	1.41	0.24	55.0	377.47	377.47	1.1
		DH-2 Pool Area (upper 1)	SPACE: Corridor - All Other Corridors	11,579.7	163,172.2	82.0	Aug 16:30	22.24	1.92	1.00	22.24	55.0	753.0	0.28	0.07	60.0	11.95	11.95	1.1
		DH-2 Pool Area (upper 2)	SPACE: Corridor - All Other Corridors	11,579.7	163,172.2	82.0	Jun 17:30	27.90	2.41	1.00	27.90	55.0	944.4	0.35	0.08	60.0	11.50	11.50	1.1

Zone group	Zone	Room	Template	Floor area (ft <sup>2</sup> )	Volume (ft <sup>3</sup> )	Heating occupied setpoint (°F)	Heating load (without oversizing)		Heating design load oversizing factor	Heating design load with oversizing (kBtu/h)	Heating supply air temperature (°F)	Heating design airflow (maximum)		Min RH setpoint (%)	Humidification load (kBtu/h)
							(kBtu/h)	(Btu/h.ft <sup>2</sup> )				(cfm)	(cfm/ft <sup>2</sup> )		
DH-1	DH-1	29 DH-1 Pool area North Circulation	SPACE: Corridor - All Other Corridors	1,853.3	53,109.4	70.00	79.57	42.93	1.10	87.53	90.0	4,000.4	2.16	0.0	0.00
		DH-1 Pool Area	SPACE: Gymnasium/ Fitness center - Exercise area	10,647.6	106,238.4	70.00	34.54	3.24	1.10	37.99	90.0	1,736.2	0.16	0.0	0.00
		DH-1 Pool Area (upper 1)	SPACE: Corridor - All Other Corridors	10,647.6	150,037.4	70.00	22.45	2.11	1.10	24.70	90.0	1,128.7	0.11	0.0	0.00
DH-2	DH-2	DH-1 Pool Area (upper 2)	SPACE: Corridor - All Other Corridors	10,647.6	150,037.4	70.00	30.45	2.86	1.10	33.50	90.0	1,530.9	0.14	0.0	0.00
		23 Spectator Area	SPACE: Audience Seating Area - Exercise Center	9,175.0	191,146.9	70.00	44.60	4.86	1.10	49.06	90.0	2,242.0	0.24	0.0	0.00
		30 Vestibule	SPACE: Corridor - All Other Corridors	251.6	9,596.6	70.00	5.43	21.60	1.00	5.43	90.0	246.4	0.99	0.0	0.00
		31 Vestibule	SPACE: Corridor - All Other Corridors	264.5	10,094.0	70.00	8.66	32.74	1.00	8.66	90.0	395.7	1.50	0.0	0.00
		32 DH-2 Pool Area Circulation	SPACE: Corridor - All Other Corridors	1,187.8	44,412.8	70.00	18.25	15.37	1.00	18.25	90.0	834.1	0.70	0.0	0.00
		DH-2 Pool Area	SPACE: Gymnasium/ Fitness center - Exercise area	11,579.7	115,538.8	70.00	33.53	2.90	1.00	33.53	90.0	1,532.2	0.13	0.0	0.00
		DH-2 Pool Area (upper 1)	SPACE: Corridor - All Other Corridors	11,579.7	163,172.2	70.00	20.86	1.80	1.00	20.86	90.0	953.6	0.08	0.0	0.00
		DH-2 Pool Area (upper 2)	SPACE: Corridor - All Other Corridors	11,579.7	163,172.2	70.00	27.58	2.38	1.00	27.58	90.0	1,260.5	0.11	0.0	0.00

Zone group	Zone	Room	Template	Floor area (ft <sup>2</sup> )	Volume (ft <sup>3</sup> )	Design occupancy (People)	Required minimum ventilation airflow			
							(cfm)	(cfm/person)	(cfm/ft <sup>2</sup> )	(ACH)
DH-1	DH-1	29 DH-1 Pool area North Circulation	SPACE: Corridor - All Other Corridors	1,853.3	53,109.4	0.0	111.2	0.0	0.06	0.13
		DH-1 Pool Area	SPACE: Gymnasium/ Fitness center - Exercise area	10,647.6	106,238.4	25.0	1,138.9	45.6	0.11	0.64
		DH-1 Pool Area (upper 1)	SPACE: Corridor - All Other Corridors	10,647.6	150,037.4	0.0	0.0	0.0	0.00	0.00
DH-2	DH-2	DH-1 Pool Area (upper 2)	SPACE: Corridor - All Other Corridors	10,647.6	150,037.4	0.0	0.0	0.0	0.00	0.00
		23 Spectator Area	SPACE: Audience Seating Area - Exercise Center	9,175.0	191,146.9	10.0	625.5	62.6	0.07	0.20
		30 Vestibule	SPACE: Corridor - All Other Corridors	251.6	9,596.6	0.0	15.1	0.0	0.06	0.09
		31 Vestibule	SPACE: Corridor - All Other Corridors	264.5	10,094.0	0.0	15.9	0.0	0.06	0.09
		32 DH-2 Pool Area Circulation	SPACE: Corridor - All Other Corridors	1,187.8	44,412.8	0.0	71.3	0.0	0.06	0.10
		DH-2 Pool Area	SPACE: Gymnasium/ Fitness center - Exercise area	11,579.7	115,538.8	25.0	1,194.8	47.8	0.10	0.62
		DH-2 Pool Area (upper 1)	SPACE: Corridor - All Other Corridors	11,579.7	163,172.2	0.0	0.0	0.0	0.00	0.00
		DH-2 Pool Area (upper 2)	SPACE: Corridor - All Other Corridors	11,579.7	163,172.2	0.0	0.0	0.0	0.00	0.00



<b>Project and Climate</b>				2
<b>Zone Conditioning Loads Reports</b>				
DH-1	05 a VAV - Reheat [DX cool -...	DH-1		3
DH-2	05 a VAV - Reheat [DX cool -...	Dh-2		4
<b>Room Conditioning Loads Reports</b>				
DH-1	DH-1	29 DH -1 Pool area North...		5
		DH-1 Pool Area		6
		DH-1 Pool Area (upper 1)		7
		DH-1 Pool Area (upper 2)		8
DH-2	Dh-2	30 Vestibule		9
		31 Vestibule		10
		32 DH-2 Pool Area...		11
		DH-2 Pool Area		12
		DH-2 Pool Area (upper 1)		13
		DH-2 Pool Area (upper 2)		14



**Model Data**

Project file	Long Center Option2.mit
Source HVAC file	Natatorium_Option2_HVAC.asp
HVAC file snapshot	Vista\Long Center Option2rev1 rooms loads.asp
Model floor area	34,959.5 ft <sup>2</sup>
Building conditioned floor area	34,959.5 ft <sup>2</sup>
Building conditioned volume	1,156,556.0 ft <sup>3</sup>
Number of conditioned rooms	11
Load analysis methodology	ASHRAE Heat Balance Method
Calculated	2023/12/06 10:06
Version No.	2023.2.1.0

**Location Data**

Location	St Pete-Clearwater, Florida
Latitude	27.91 N
Longitude	82.69 W
Altitude	9.8 ft
Time Zone	5.0 hours behind GMT

**Design Weather Data**

Source	ASHRAE design weather database
Monthly percentile:	
For heating loads design weather	99.60 %
For cooling loads design weather	0.40 %
Barometric pressure	29.9109 inHg
Air density	0.0749 lb/ft <sup>3</sup>
Air specific heat	0.2434 Btu/lb·°F
Density-specific heat product	0.0591 Btu/ft <sup>3</sup> ·°F
Summer ground reflectance	0.2
Winter ground reflectance	0.2
Carbon dioxide (ambient)	400.00 ppm

**Cooling Calculation Data**


Results file	Long Center Option2rev1 rooms loads.clg
Calculated	2023/12/06 10:06
Profile Month	May - Sep
Max outdoor temp. dry bulb	93.7 °F
Max outdoor temp. wet bulb	78.4 °F

**Heating Calculation Data**

Results file	Long Center Option2rev1 rooms loads.htg
Calculated	2023/12/06 10:06
Profile Month	Jan
Outdoor winter design temp	42.1 °F

**Project Loads Summary**

	kBtu/h	Btu/h-ft <sup>2</sup>
Cooling loads:		
Coincident peak space load	404.28	11.56
Heating loads:		
Coincident peak space load	325.92	9.32



# Zone Loads Report

System: 05 a VAV - Reheat

# Long Center Option2

## DH-1

IES VIRTUAL ENVIRONMENT  
VE 2023



COOLING ZONE PEAK					
Time of Peak (Mo/Hr:Mn)					6 / 16:30
Outside Air (DBT/WBT/RH) °F and %RH					92.8 / 76.7 / 48.0
Zone	Zone Sensible	Zone Latent	Net Value	Per Floor Area	Percent of Total
<b>Envelope Gains/Losses</b>	Btu/h	Btu/h	Btu/h	Btu/h-ft²	%
External Walls	8,161	-	8,161	0.7	1.5
Roofs	1,004	-	1,004	0.1	0.2
Ground/Exposed Floors	-7,333	-	-7,333	-0.6	-1.4
External Doors	0	-	0	0.0	0.0
Windows Conduction	42,829	-	42,829	3.4	7.9
Skylights Conduction	0	-	0	0.0	0.0
Solar	122,109	-	122,109	9.8	22.6
Infiltration	9,454	7,198	16,652	1.3	3.1
Nat/Aux Vent	0	0	0	0.0	0.0
<b>Internal Building Gains/Losses</b>					
Internal Walls/Openings	-2,435	-	-2,435	-0.2	-0.5
Internal Floors	-3,242	-	-3,242	-0.3	-0.6
Internal Air & Furniture	0	-	0	0.0	0.0
Ceilings	0	-	0	0.0	0.0
Sub Total	170,549	7,198	177,747	14.2	
<b>Internal Gains</b>					
Lights	3,162	-	3,162	0.3	0.6
People	17,750	27,250	45,000	3.6	8.3
Misc, Computers, Equip	1,265	313,755	315,020	25.2	58.2
Sub Total	22,177	341,005	363,182	29.1	
<b>TOTAL</b>	<b>192,726</b>	<b>348,203</b>	<b>540,929</b>	<b>43.3</b>	<b>100</b>

COOLING SUMMARY	
Sensible cooling load (Btu/h):	192,726
Latent cooling load (Btu/h):	348,203
Sensible heat ratio:	0.36
Design Supply Airflow calculated per:	Sensible Loads
Design zone air temp for Supply Airflow calculation (°F):	82.0

HEATING ZONE PEAK					
Time of Peak (Mo/Hr:Mn)					Heating Design
Outside Air (DBT/WBT/RH) °F and %RH					42.1 / 35.4 / 49.6
Zone	Net Value	Per Floor Area	Percent of Total		
<b>Envelope Gains/Losses</b>	Btu/h	Btu/h	Btu/h-ft²	%	
External Walls	-20,668	-20,668	-1.7	12.4	
Roofs	-8,630	-8,630	-0.7	5.2	
Ground/Exposed Floors	-16,223	-16,223	-1.3	9.7	
External Doors	0	0	0.0	0.0	
Windows Conduction	-84,847	-84,847	-6.8	50.8	
Skylights Conduction	0	0	0.0	0.0	
Solar	0	0	0.0	0.0	
Infiltration	-23,387	-23,387	-1.9	14.0	
Nat/Aux Vent	0	0	0.0	0.0	
<b>Internal Building Gains/Losses</b>					
Internal Walls/Openings	1,070	1,070	0.1	-0.6	
Internal Floors	-14,326	-14,326	-1.1	8.6	
Internal Air & Furniture	0	0	0.0	0.0	
Ceilings	0	0	0.0	0.0	
Sub Total	-167,010	-167,010	-13.4		
<b>Internal Gains</b>					
Lights	0	0	0.0	0.0	
People	0	0	0.0	0.0	
Misc, Computers, Equip	0	0	0.0	0.0	
Sub Total	0	0	0.0		
<b>TOTAL</b>	<b>-167,010</b>	<b>-167,010</b>	<b>-13.4</b>	<b>100</b>	

HEATING SUMMARY	
Sensible heating load (Btu/h):	167,010
Design zone air temp for Supply Airflow calculation (°F):	70.0

AREAS & THERMAL TRANSMITTANCE				
	Total Area	Glazing	Glazing	U-value <sup>1</sup>
	ft²	ft²	%	Btu/h-ft²-°F
<b>External</b>				
Wall (above grade)	15,437.1	6,450.5	41.8	0.26
Below Grade Walls	-	-	-	-
Windows <sup>2</sup>	6,450.5	6,450.5	100.0	0.51
Doors	-	-	-	-
Floors	6,979.8	-	-	0.09
Roofs <sup>3</sup>	12,392.2	-	-	0.02
<b>COMBINED</b>	<b>34,809.1</b>	<b>6,450.5</b>	<b>18.5</b>	<b>0.14</b>
<b>Internal</b>				
Ceilings	-	-	-	-
Floors	5,521.2	-	-	0.19
Partitions <sup>4</sup>	8,912.8	-	-	0.33

<sup>1</sup> Area-weighted U-value; <sup>2</sup> Windows/glazing include glass and frames; <sup>3</sup> Roofs incl. skylights; <sup>4</sup> Partitions incl. internal windows and doors.

TEMPERATURES & SETPOINTS		
	Cooling	Heating
	°F	°F
Supply Air (design)	55.0	80.0
Master Room Setpoint (design)	82.0	70.0
Master Room (actual)	82.0	70.0
Mean Radiant Temperature	180.0	163.4
Dry Resultant Temperature	179.0	164.7
RH (Design Max Setpoint) (%)	-	-

AIRFLOW		
	Cooling	Heating
	cfm	cfm
Supply (design)	20,626	25,086
Reheat Minimum (design)	20,626	20,626
Leakage at Design Flow	0	0
Ventilation (requirement)	20,626	20,626
Exhaust (requirement)	15,469	15,469
Infiltration	766	766

CHECKS	
Number of People	25.00
ft²/Person	500.04
Average Ceiling Height (ft)	18.38
Btu/h/ft² - Cooling (sensible)	15.42
Btu/h/ft² - Heating	13.36
ft²/ton - Cooling (sensible)	778.36
ft²/ton - Heating	898.22
cfm/ft² - Cooling	1.65
cfm/ft² - Heating	2.01
% Outside Air - Cooling	100.00
% Outside Air - Heating	82.22
Outdoor Air cfm/ft²	1.65
Outdoor Air cfm/person	825.03

# Zone Loads Report

System: 05 a VAV - Reheat

# Long Center Option2

## Dh-2



COOLING ZONE PEAK					
Time of Peak (Mo/Hr:Mn)					8 / 17:30
Outside Air (DBT/WBT/RH) °F and %RH					91.6 / 77.7 / 53.8
Zone	Zone Sensible	Zone Latent	Net Value	Per Floor Area	Percent of Total
<b>Envelope Gains/Losses</b>	Btu/h	Btu/h	Btu/h	Btu/h-ft²	%
External Walls	10,304	-	10,304	0.5	1.9
Roofs	8,006	-	8,006	0.4	1.5
Ground/Exposed Floors	-1,809	-	-1,809	-0.1	-0.3
External Doors	0	-	0	0.0	0.0
Windows Conduction	9,570	-	9,570	0.4	1.8
Skylights Conduction	0	-	0	0.0	0.0
Solar	67,010	-	67,010	3.0	12.4
Infiltration	9,369	13,055	22,425	1.0	4.1
Nat/Aux Vent	0	0	0	0.0	0.0
<b>Internal Building Gains/Losses</b>					
Internal Walls/Openings	683	-	683	0.0	0.1
Internal Floors	-756	-	-756	0.0	-0.1
Internal Air & Furniture	0	-	0	0.0	0.0
Ceilings	0	-	0	0.0	0.0
Sub Total	102,378	13,055	115,433	5.1	
<b>Internal Gains</b>					
Lights	38,467	-	38,467	1.7	7.1
People	17,750	27,250	45,000	2.0	8.3
Misc, Computers, Equip	1,163	341,222	342,385	15.2	63.3
Sub Total	57,380	368,472	425,852	19.0	
<b>TOTAL</b>	<b>159,758</b>	<b>381,528</b>	<b>541,285</b>	<b>24.1</b>	<b>100</b>

COOLING SUMMARY	
Sensible cooling load (Btu/h):	159,758
Latent cooling load (Btu/h):	381,528
Sensible heat ratio:	0.30
Design Supply Airflow calculated per:	Sensible Loads
Design zone air temp for Supply Airflow calculation (°F):	82.0

HEATING ZONE PEAK					
Time of Peak (Mo/Hr:Mn)					Heating Design
Outside Air (DBT/WBT/RH) °F and %RH					42.1 / 35.4 / 49.6
Zone	Net Value	Per Floor Area	Percent of Total		
<b>Envelope Gains/Losses</b>	Btu/h	Btu/h	Btu/h-ft²	%	
External Walls	-20,288	-20,288	-0.9	17.7	
Roofs	-9,431	-9,431	-0.4	8.3	
Ground/Exposed Floors	-15,510	-15,510	-0.7	13.6	
External Doors	0	0	0.0	0.0	
Windows Conduction	-24,461	-24,461	-1.1	21.4	
Skylights Conduction	0	0	0.0	0.0	
Solar	0	0	0.0	0.0	
Infiltration	-25,758	-25,758	-1.1	22.5	
Nat/Aux Vent	0	0	0.0	0.0	
<b>Internal Building Gains/Losses</b>					
Internal Walls/Openings	117	117	0.0	-0.1	
Internal Floors	-18,985	-18,985	-0.8	16.6	
Internal Air & Furniture	0	0	0.0	0.0	
Ceilings	0	0	0.0	0.0	
Sub Total	-114,315	-114,315	-5.1		
<b>Internal Gains</b>					
Lights	0	0	0.0	0.0	
People	0	0	0.0	0.0	
Misc, Computers, Equip	0	0	0.0	0.0	
Sub Total	0	0	0.0		
<b>TOTAL</b>	<b>-114,315</b>	<b>-114,315</b>	<b>-5.1</b>	<b>100</b>	

HEATING SUMMARY	
Sensible heating load (Btu/h):	114,315
Design zone air temp for Supply Airflow calculation (°F):	70.0

AREAS & THERMAL TRANSMITTANCE				
	Total Area	Glazing	Glazing	U-value <sup>1</sup>
	ft²	ft²	%	Btu/h-ft²-°F
<b>External</b>				
Wall (above grade)	16,317.1	1,903.5	11.7	0.13
Below Grade Walls	-	-	-	-
Windows <sup>2</sup>	1,903.5	1,903.5	100.0	0.46
Doors	-	-	-	-
Floors	15,266.9	-	-	0.07
Roofs <sup>3</sup>	22,414.2	-	-	0.02
<b>COMBINED</b>	<b>53,998.2</b>	<b>1,903.5</b>	<b>3.5</b>	<b>0.07</b>
<b>Internal</b>				
Ceilings	22.0	-	-	0.05
Floors	7,169.6	-	-	0.19
Partitions <sup>4</sup>	11,907.3	-	-	0.33

<sup>1</sup> Area-weighted U-value; <sup>2</sup> Windows/glazing include glass and frames; <sup>3</sup> Roofs incl. skylights; <sup>4</sup> Partitions incl. internal windows and doors.

TEMPERATURES & SETPOINTS		
	Cooling	Heating
	°F	°F
Supply Air (design)	55.0	90.0
Master Room Setpoint (design)	82.0	70.0
Master Room (actual)	82.0	70.0
Mean Radiant Temperature	229.4	218.4
Dry Resultant Temperature	228.8	219.0
RH (Design Max Setpoint) (%)	60.0	60.0

AIRFLOW		
	Cooling	Heating
	cfm	cfm
Supply (design)	22,175	22,186
Reheat Minimum (design)	21,773	21,773
Leakage at Design Flow	0	0
Ventilation (requirement)	21,580	21,580
Exhaust (requirement)	13,490	13,490
Infiltration	843	843

CHECKS	
Number of People	25.00
ft²/Person	531.34
Average Ceiling Height (ft)	24.67
Btu/h/ft² - Cooling (sensible)	12.03
Btu/h/ft² - Heating	8.61
ft²/ton - Cooling (sensible)	997.77
ft²/ton - Heating	1,394.42
cfm/ft² - Cooling	1.67
cfm/ft² - Heating	1.67
% Outside Air - Cooling	97.32
% Outside Air - Heating	97.27
Outdoor Air cfm/ft²	1.62
Outdoor Air cfm/person	863.21

# Room Loads Report

Zone: DH-1  
System: 05 a VAV - Reheat

# Long Center Option2 29 DH -1 Pool area North Circulation HVAC Methodology: ApacheHVAC

IES VIRTUAL ENVIRONMENT

VE 2023



COOLING ROOM PEAK					
Time of Peak (Mo/Hr:Mn)					6 / 15:30
Outside Air (DBT/WBT/RH) °F and %RH					93.7 / 77.0 / 47.0
Room	Room Sensible	Room Latent	Net Value	Per Floor Area	Percent of Total
<b>Envelope Gains/Losses</b>	Btu/h	Btu/h	Btu/h	Btu/h-ft²	%
External Walls	2,816	-	2,816	1.5	3.7
Roofs	-2,009	-	-2,009	-1.1	-2.7
Ground/Exposed Floors	-2,820	-	-2,820	-1.5	-3.7
External Doors	0	-	0	0.0	0.0
Windows Conduction	39,780	-	39,780	21.5	52.7
Skylights Conduction	0	-	0	0.0	0.0
Solar	42,910	-	42,910	23.2	56.8
Infiltration	1,137	735	1,872	1.0	2.5
Nat/Aux Vent	0	0	0	0.0	0.0
<b>Internal Building Gains/Losses</b>					
Internal Walls/Opening	-11,428	-	-11,428	-6.2	-15.1
Internal Floors	0	-	0	0.0	0.0
Internal Air & Furniture	0	-	0	0.0	0.0
Ceilings	0	-	0	0.0	0.0
<b>Sub Total</b>	<b>70,387</b>	<b>735</b>	<b>71,122</b>	<b>38.4</b>	
<b>Internal Gains</b>					
Lights	3,162	-	3,162	1.7	4.2
People	0	0	0	0.0	0.0
Misc, Computers, Equip	1,265	0	1,265	0.7	1.7
<b>Sub Total</b>	<b>4,427</b>	<b>0</b>	<b>4,427</b>	<b>2.4</b>	
<b>TOTAL</b>	<b>74,814</b>	<b>735</b>	<b>75,549</b>	<b>40.8</b>	<b>100</b>

COOLING SUMMARY	
Sensible cooling load (Btu/h):	74,814
Latent cooling load (Btu/h):	735
Sensible heat ratio:	0.99
Design Supply Airflow calculated per:	Sensible Loads
Design zone air temp for Supply Airflow calculation (°F):	82.0

HEATING ROOM PEAK					
Time of Peak (Mo/Hr:Mn)					Heating Design
Outside Air (DBT/WBT/RH) °F and %RH					42.1 / 35.4 / 49.6
Room	Room Value	Net Value	Per Floor Area	Percent of Total	
<b>Envelope Gains/Losses</b>	Btu/h	Btu/h	Btu/h-ft²	%	
External Walls	-14,960	-14,960	-8.1	18.8	
Roofs	-1,113	-1,113	-0.6	1.4	
Ground/Exposed Floors	-9,198	-9,198	-5.0	11.6	
External Doors	0	0	0.0	0.0	
Windows Conduction	-68,796	-68,796	-37.1	86.5	
Skylights Conduction	0	0	0.0	0.0	
Solar	0	0	0.0	0.0	
Infiltration	-2,704	-2,704	-1.5	3.4	
Nat/Aux Vent	0	0	0.0	0.0	
<b>Internal Building Gains/Losses</b>					
Internal Walls/Opening	17,198	17,198	9.3	-21.6	
Internal Floors	0	0	0.0	0.0	
Internal Air & Furniture	0	0	0.0	0.0	
Ceilings	0	0	0.0	0.0	
<b>Sub Total</b>	<b>-79,571</b>	<b>-79,571</b>	<b>-42.9</b>		
<b>Internal Gains</b>					
Lights	0	0	0.0	0.0	
People	0	0	0.0	0.0	
Misc, Computers, Equip	0	0	0.0	0.0	
<b>Sub Total</b>	<b>0</b>	<b>0</b>	<b>0.0</b>		
<b>TOTAL</b>	<b>-79,571</b>	<b>-79,571</b>	<b>-42.9</b>	<b>100</b>	

HEATING SUMMARY	
Sensible heating load (Btu/h):	79,571
Design zone air temp for Supply Airflow calculation (°F):	70.0

AREAS & THERMAL TRANSMITTANCE				
	Total Area	Glazing	Glazing	U-value <sup>1</sup>
	ft²	ft²	%	Btu/h-ft²-°F
<b>External</b>				
Wall (above grade)	11,823.4	5,125.7	43.4	0.28
Below Grade Walls	-	-	-	-
Windows <sup>2</sup>	5,125.7	5,125.7	100.0	0.53
Doors	-	-	-	-
Floors	1,853.3	-	-	0.19
Roofs <sup>3</sup>	1,744.7	-	-	0.02
<b>COMBINED</b>	<b>15,421.4</b>	<b>5,125.7</b>	<b>33.2</b>	<b>0.24</b>
<b>Internal</b>				
Ceilings	-	-	-	-
Floors	-	-	-	-
Partitions <sup>4</sup>	331.4	-	-	0.33

<sup>1</sup> Area-weighted U-value; <sup>2</sup> Windows/glazing include glass and frames; <sup>3</sup> Roofs incl. skylights; <sup>4</sup> Partitions incl. internal windows and doors.

TEMPERATURES & SETPOINTS		
	Cooling	Heating
	°F	°F
Supply Air (design)	55.0	80.0
Room Setpoint (design)	82.0	70.0
Room (actual)	82.0	70.0
Mean Radiant Temperature	86.1	64.0
Dry Resultant Temperature	84.0	67.0
RH (Design Max Setpoint) (%)	60.0	60.0

AIRFLOW		
	Cooling	Heating
	cfm	cfm
Supply (design)	3,541	8,001
Reheat Minimum (design)	3,541	3,541
Leakage at Design Flow	0	0
Ventilation (requirement)	3,541	3,541
Exhaust (requirement)	1,770	1,770
Infiltration	89	89

CHECKS	
Number of People	0.00
ft²/Person	-
Average Ceiling Height (ft)	35.37
Btu/h-ft² - Cooling (sensible)	40.37
Btu/h-ft² - Heating	42.93
ft²/ton - Cooling (sensible)	297.27
ft²/ton - Heating	279.50
cfm/ft² - Cooling	1.91
cfm/ft² - Heating	4.32
% Outside Air - Cooling	100.00
% Outside Air - Heating	44.25
Outdoor Air cfm/ft²	1.91
Outdoor Air cfm/person	-

# Room Loads Report

Zone: DH-1  
System: 05 a VAV - Reheat

## Long Center Option2 DH-1 Pool Area HVAC Methodology: ApacheHVAC

IES VIRTUAL ENVIRONMENT

VE 2023



COOLING ROOM PEAK					
Time of Peak (Mo/Hr:Mn)					6 / 17:30
Outside Air (DBT/WBT/RH) °F and %RH					91.6 / 76.2 / 49.5
Room	Room Sensible	Room Latent	Net Value	Per Floor Area	Percent of Total
<b>Envelope Gains/Losses</b>	Btu/h	Btu/h	Btu/h	Btu/h-ft²	%
External Walls	773	-	773	0.1	0.2
Roofs	0	-	0	0.0	0.0
Ground/Exposed Floors	-5,262	-	-5,262	-0.5	-1.3
External Doors	0	-	0	0.0	0.0
Windows Conduction	1,762	-	1,762	0.2	0.4
Skylights Conduction	0	-	0	0.0	0.0
Solar	53,747	-	53,747	5.0	13.2
Infiltration	1,981	2,349	4,330	0.4	1.1
Nat/Aux Vent	0	0	0	0.0	0.0
<b>Internal Building Gains/Losses</b>					
Internal Walls/Openings	-4,784	-	-4,784	-0.4	-1.2
Internal Floors	-3,010	-	-3,010	-0.3	-0.7
Internal Air & Furniture	0	-	0	0.0	0.0
Ceilings	0	-	0	0.0	0.0
Sub Total	45,206	2,349	47,555	4.5	
<b>Internal Gains</b>					
Lights	0	-	0	0.0	0.0
People	17,750	27,250	45,000	4.2	11.1
Misc, Computers, Equip	0	313,755	313,755	29.5	77.2
Sub Total	17,750	341,005	358,755	33.7	
<b>TOTAL</b>	<b>62,956</b>	<b>343,354</b>	<b>406,310</b>	<b>38.2</b>	<b>100</b>

COOLING SUMMARY	
Sensible cooling load (Btu/h):	62,956
Latent cooling load (Btu/h):	343,354
Sensible heat ratio:	0.15
Design Supply Airflow calculated per:	Sensible Loads
Design zone air temp for Supply Airflow calculation (°F):	82.0

HEATING ROOM PEAK					
Time of Peak (Mo/Hr:Mn)					Heating Design
Outside Air (DBT/WBT/RH) °F and %RH					42.1 / 35.4 / 49.6
Room	Room Sensible	Room Latent	Net Value	Per Floor Area	Percent of Total
<b>Envelope Gains/Losses</b>	Btu/h	Btu/h	Btu/h	Btu/h-ft²	%
External Walls	-1,520	-1,520	-0.1	4.4	
Roofs	0	0	0.0	0.0	
Ground/Exposed Floors	-7,025	-7,025	-0.7	20.3	
External Doors	0	0	0.0	0.0	
Windows Conduction	-4,411	-4,411	-0.4	12.8	
Skylights Conduction	0	0	0.0	0.0	
Solar	0	0	0.0	0.0	
Infiltration	-5,408	-5,408	-0.5	15.7	
Nat/Aux Vent	0	0	0.0	0.0	
<b>Internal Building Gains/Losses</b>					
Internal Walls/Openings	-1,846	-1,846	-0.2	5.3	
Internal Floors	-14,326	-14,326	-1.3	41.5	
Internal Air & Furniture	0	0	0.0	0.0	
Ceilings	0	0	0.0	0.0	
Sub Total	-34,536	-34,536	-3.2		
<b>Internal Gains</b>					
Lights	0	0	0.0	0.0	
People	0	0	0.0	0.0	
Misc, Computers, Equip	0	0	0.0	0.0	
Sub Total	0	0	0.0		
<b>TOTAL</b>	<b>-34,536</b>	<b>-34,536</b>	<b>-3.2</b>	<b>100</b>	

HEATING SUMMARY	
Sensible heating load (Btu/h):	34,536
Design zone air temp for Supply Airflow calculation (°F):	70.0

AREAS & THERMAL TRANSMITTANCE				
	Total Area	Glazing	Glazing	U-value <sup>1</sup>
	ft²	ft²	%	Btu/h-ft²-°F
<b>External</b>				
Wall (above grade)	944.8	330.4	35.0	0.22
Below Grade Walls	-	-	-	-
Windows <sup>2</sup>	330.4	330.4	100.0	0.47
Doors	-	-	-	-
Floors	5,126.4	-	-	0.05
Roofs <sup>3</sup>	-	-	-	-
<b>COMBINED</b>	<b>6,071.3</b>	<b>330.4</b>	<b>5.4</b>	<b>0.08</b>
<b>Internal</b>				
Ceilings	-	-	-	-
Floors	5,521.2	-	-	0.19
Partitions <sup>4</sup>	2,270.4	-	-	0.33

<sup>1</sup> Area-weighted U-value; <sup>2</sup> Windows/glazing include glass and frames; <sup>3</sup> Roofs incl. skylights; <sup>4</sup> Partitions incl. internal windows and doors.

TEMPERATURES & SETPOINTS		
	Cooling	Heating
	°F	°F
Supply Air (design)	55.0	80.0
Room Setpoint (design)	82.0	70.0
Room (actual)	82.0	70.0
Mean Radiant Temperature	84.5	67.5
Dry Resultant Temperature	83.2	68.7
RH (Design Max Setpoint) (%)	-	-

AIRFLOW		
	Cooling	Heating
	cfm	cfm
Supply (design)	7,083	7,083
Reheat Minimum (design)	7,083	7,083
Leakage at Design Flow	0	0
Ventilation (requirement)	7,083	7,083
Exhaust (requirement)	6,197	6,197
Infiltration	177	177

CHECKS	
Number of People	25.00
ft²/Person	425.90
Average Ceiling Height (ft)	9.98
Btu/h/ft² - Cooling (sensible)	5.91
Btu/h/ft² - Heating	3.24
ft²/ton - Cooling (sensible)	2,029.53
ft²/ton - Heating	3,699.60
cfm/ft² - Cooling	0.67
cfm/ft² - Heating	0.67
% Outside Air - Cooling	100.00
% Outside Air - Heating	100.00
Outdoor Air cfm/ft²	0.67
Outdoor Air cfm/person	283.30

# Room Loads Report

Zone: DH-1  
System: 05 a VAV - Reheat

Long Center Option2  
DH-1 Pool Area (upper 1)  
HVAC Methodology: ApacheHVAC

IES VIRTUAL ENVIRONMENT

VE 2023



COOLING ROOM PEAK					
Time of Peak (Mo/Hr:Mn)					6 / 17:30
Outside Air (DBT/WBT/RH) °F and %RH					91.6 / 76.2 / 49.5
Room	Room Sensible	Room Latent	Net Value	Per Floor Area	Percent of Total
<b>Envelope Gains/Losses</b>	Btu/h	Btu/h	Btu/h	Btu/h-ft <sup>2</sup>	%
External Walls	1,234	-	1,234	-	4.4
Roofs	0	-	0	-	0.0
Ground/Exposed Floors	0	-	0	-	0.0
External Doors	0	-	0	-	0.0
Windows Conduction	2,546	-	2,546	-	9.1
Skylights Conduction	0	-	0	-	0.0
Solar	11,957	-	11,957	-	42.8
Infiltration	2,798	1,905	4,703	-	16.8
Nat/Aux Vent	0	0	0	-	0.0
<b>Internal Building Gains/Losses</b>					
Internal Walls/Openings	7,503	-	7,503	-	26.9
Internal Floors	0	-	0	-	0.0
Internal Air & Furniture	0	-	0	-	0.0
Ceilings	0	-	0	-	0.0
Sub Total	26,038	1,905	27,942	0.0	
<b>Internal Gains</b>					
Lights	0	-	0	-	0.0
People	0	0	0	-	0.0
Misc, Computers, Equip	0	0	0	-	0.0
Sub Total	0	0	0	0.0	
<b>TOTAL</b>	26,038	1,905	27,942	0.0	100

COOLING SUMMARY	
Sensible cooling load (Btu/h):	26,038
Latent cooling load (Btu/h):	1,905
Sensible heat ratio:	0.93
Design Supply Airflow calculated per:	Sensible Loads
Design zone air temp for Supply Airflow calculation (°F):	82.0

HEATING ROOM PEAK					
Time of Peak (Mo/Hr:Mn)					Heating Design
Outside Air (DBT/WBT/RH) °F and %RH					42.1 / 35.4 / 49.6
Room	Room Net Value	Per Floor Area	Percent of Total		
<b>Envelope Gains/Losses</b>	Btu/h	Btu/h-ft <sup>2</sup>	%		
External Walls	-2,107	-2,107	-	-	
Roofs	0	0	-	-	
Ground/Exposed Floors	0	0	-	-	
External Doors	0	0	-	-	
Windows Conduction	-6,022	-6,022	-	-	
Skylights Conduction	0	0	-	-	
Solar	0	0	-	-	
Infiltration	-7,638	-7,638	-	-	
Nat/Aux Vent	0	0	-	-	
<b>Internal Building Gains/Losses</b>					
Internal Walls/Openings	-6,684	-6,684	-	-	
Internal Floors	0	0	-	-	
Internal Air & Furniture	0	0	-	-	
Ceilings	0	0	-	-	
Sub Total	-22,452	-22,452	0.0		
<b>Internal Gains</b>					
Lights	0	0	-	-	
People	0	0	-	-	
Misc, Computers, Equip	0	0	-	-	
Sub Total	0	0	0.0		
<b>TOTAL</b>	-22,452	-22,452	0.0	0	

HEATING SUMMARY	
Sensible heating load (Btu/h):	22,452
Design zone air temp for Supply Airflow calculation (°F):	70.0

AREAS & THERMAL TRANSMITTANCE				
	Total Area	Glazing	Glazing	U-value <sup>1</sup>
	ft <sup>2</sup>	ft <sup>2</sup>	%	Btu/h-ft <sup>2</sup> -°F
<b>External</b>				
Wall (above grade)	1,334.4	489.6	36.7	0.21
Below Grade Walls	-	-	-	-
Windows <sup>2</sup>	489.6	489.6	100.0	0.43
Doors	-	-	-	-
Floors	-	-	-	-
Roofs <sup>3</sup>	-	-	-	-
<b>COMBINED</b>	1,334.4	489.6	36.7	0.21
<b>Internal</b>				
Ceilings	-	-	-	-
Floors	-	-	-	-
Partitions <sup>4</sup>	3,206.4	-	-	0.33

<sup>1</sup> Area-weighted U-value; <sup>2</sup> Windows/glazing include glass and frames; <sup>3</sup> Roofs incl. skylights; <sup>4</sup> Partitions incl. internal windows and doors.

TEMPERATURES & SETPOINTS		
	Cooling	Heating
	°F	°F
Supply Air (design)	55.0	80.0
Room Setpoint (design)	82.0	70.0
Room (actual)	82.0	70.0
Mean Radiant Temperature	83.6	67.9
Dry Resultant Temperature	82.8	68.9
RH (Design Max Setpoint) (%)	-	-

AIRFLOW		
	Cooling	Heating
	cfm	cfm
Supply (design)	5,001	5,001
Reheat Minimum (design)	5,001	5,001
Leakage at Design Flow	0	0
Ventilation (requirement)	5,001	5,001
Exhaust (requirement)	3,751	3,751
Infiltration	250	250

CHECKS	
Number of People	0.00
ft <sup>2</sup> /Person	-
Average Ceiling Height (ft)	14.09
Btu/h/ft <sup>2</sup> - Cooling (sensible)	-
Btu/h/ft <sup>2</sup> - Heating	-
ft <sup>2</sup> /ton - Cooling (sensible)	-
ft <sup>2</sup> /ton - Heating	-
cfm/ft <sup>2</sup> - Cooling	-
cfm/ft <sup>2</sup> - Heating	-
% Outside Air - Cooling	100.00
% Outside Air - Heating	100.00
Outdoor Air cfm/ft <sup>2</sup>	-
Outdoor Air cfm/person	-

# Room Loads Report

Zone: DH-1  
System: 05 a VAV - Reheat

# Long Center Option2 DH-1 Pool Area (upper 2) HVAC Methodology: ApacheHVAC

IES VIRTUAL ENVIRONMENT

VE 2023



COOLING ROOM PEAK					
Time of Peak (Mo/Hr:Mn)					6 / 17:30
Outside Air (DBT/WBT/RH) °F and %RH					91.6 / 76.2 / 49.5
Room	Room Sensible	Room Latent	Net Value	Per Floor Area	Percent of Total
<b>Envelope Gains/Losses</b>	Btu/h	Btu/h	Btu/h	Btu/h-ft²	%
External Walls	1,255	-	1,255	-	3.4
Roofs	3,830	-	3,830	-	10.4
Ground/Exposed Floors	0	-	0	-	0.0
External Doors	0	-	0	-	0.0
Windows Conduction	2,453	-	2,453	-	6.7
Skylights Conduction	0	-	0	-	0.0
Solar	21,162	-	21,162	-	57.4
Infiltration	2,798	1,905	4,703	-	12.8
Nat/Aux Vent	0	0	0	-	0.0
<b>Internal Building Gains/Losses</b>					
Internal Walls/Opening	3,439	-	3,439	-	9.3
Internal Floors	0	-	0	-	0.0
Internal Air & Furniture	0	-	0	-	0.0
Ceilings	0	-	0	-	0.0
Sub Total	34,936	1,905	36,841	0.0	
<b>Internal Gains</b>					
Lights	0	-	0	-	0.0
People	0	0	0	-	0.0
Misc, Computers, Equip	0	0	0	-	0.0
Sub Total	0	0	0	0.0	
<b>TOTAL</b>	<b>34,936</b>	<b>1,905</b>	<b>36,841</b>	<b>0.0</b>	<b>100</b>

COOLING SUMMARY	
Sensible cooling load (Btu/h):	34,936
Latent cooling load (Btu/h):	1,905
Sensible heat ratio:	0.95
Design Supply Airflow calculated per:	Sensible Loads
Design zone air temp for Supply Airflow calculation (°F):	82.0

HEATING ROOM PEAK					
Time of Peak (Mo/Hr:Mn)					Heating Design
Outside Air (DBT/WBT/RH) °F and %RH					42.1 / 35.4 / 49.6
Room	Room Value	Net Value	Per Floor Area	Percent of Total	
<b>Envelope Gains/Losses</b>	Btu/h	Btu/h	Btu/h-ft²	%	
External Walls	-2,080	-2,080	-	-	
Roofs	-7,518	-7,518	-	-	
Ground/Exposed Floors	0	0	-	-	
External Doors	0	0	-	-	
Windows Conduction	-5,617	-5,617	-	-	
Skylights Conduction	0	0	-	-	
Solar	0	0	-	-	
Infiltration	-7,638	-7,638	-	-	
Nat/Aux Vent	0	0	-	-	
<b>Internal Building Gains/Losses</b>					
Internal Walls/Opening	-7,598	-7,598	-	-	
Internal Floors	0	0	-	-	
Internal Air & Furniture	0	0	-	-	
Ceilings	0	0	-	-	
Sub Total	-30,451	-30,451	0.0		
<b>Internal Gains</b>					
Lights	0	0	-	-	
People	0	0	-	-	
Misc, Computers, Equip	0	0	-	-	
Sub Total	0	0	0.0		
<b>TOTAL</b>	<b>-30,451</b>	<b>-30,451</b>	<b>0.0</b>	<b>0</b>	

HEATING SUMMARY	
Sensible heating load (Btu/h):	30,451
Design zone air temp for Supply Airflow calculation (°F):	70.0

AREAS & THERMAL TRANSMITTANCE				
	Total Area	Glazing	Glazing	U-value <sup>1</sup>
	ft²	ft²	%	Btu/h-ft²-°F
<b>External</b>				
Wall (above grade)	1,334.4	504.9	37.8	0.20
Below Grade Walls	-	-	-	-
Windows <sup>2</sup>	504.9	504.9	100.0	0.39
Doors	-	-	-	-
Floors	-	-	-	-
Roofs <sup>3</sup>	10,647.6	-	-	0.02
<b>COMBINED</b>	<b>11,982.0</b>	<b>504.9</b>	<b>4.2</b>	<b>0.04</b>
<b>Internal</b>				
Ceilings	-	-	-	-
Floors	-	-	-	-
Partitions <sup>4</sup>	3,436.0	-	-	0.33

<sup>1</sup> Area-weighted U-value; <sup>2</sup> Windows/glazing include glass and frames; <sup>3</sup> Roofs incl. skylights; <sup>4</sup> Partitions incl. internal windows and doors.

TEMPERATURES & SETPOINTS		
	Cooling	Heating
	°F	°F
Supply Air (design)	55.0	80.0
Room Setpoint (design)	82.0	70.0
Room (actual)	82.0	70.0
Mean Radiant Temperature	83.5	68.1
Dry Resultant Temperature	82.8	69.0
RH (Design Max Setpoint) (%)	-	-

AIRFLOW		
	Cooling	Heating
	cfm	cfm
Supply (design)	5,001	5,001
Reheat Minimum (design)	5,001	5,001
Leakage at Design Flow	0	0
Ventilation (requirement)	5,001	5,001
Exhaust (requirement)	3,751	3,751
Infiltration	250	250

CHECKS	
Number of People	0.00
ft²/Person	-
Average Ceiling Height (ft)	14.09
Btu/h-ft² - Cooling (sensible)	-
Btu/h-ft² - Heating	-
ft²/ton - Cooling (sensible)	-
ft²/ton - Heating	-
cfm/ft² - Cooling	-
cfm/ft² - Heating	-
% Outside Air - Cooling	100.00
% Outside Air - Heating	100.00
Outdoor Air cfm/ft²	-
Outdoor Air cfm/person	-

# Room Loads Report

Zone: Dh-2  
System: 05 a VAV - Reheat

# Long Center Option2

30 Vestibule

HVAC Methodology: ApacheHVAC

IES VIRTUAL ENVIRONMENT

VE 2023



COOLING ROOM PEAK					
Time of Peak (Mo/Hr:Mn)					7 / 7:30
Outside Air (DBT/WBT/RH) °F and %RH					80.6 / 72.6 / 68.4
Room	Room Sensible	Room Latent	Net Value	Per Floor Area	Percent of Total
<b>Envelope Gains/Losses</b>	Btu/h	Btu/h	Btu/h	Btu/h-ft <sup>2</sup>	%
External Walls	1,354	-	1,354	5.4	40.1
Roofs	457	-	457	1.8	13.5
Ground/Exposed Floors	368	-	368	1.5	10.9
External Doors	0	-	0	0.0	0.0
Windows Conduction	0	-	0	0.0	0.0
Skylights Conduction	0	-	0	0.0	0.0
Solar	0	-	0	0.0	0.0
Infiltration	-34	77	43	0.2	1.3
Nat/Aux Vent	0	0	0	0.0	0.0
<b>Internal Building Gains/Losses</b>					
Internal Walls/Openings	461	-	461	1.8	13.6
Internal Floors	0	-	0	0.0	0.0
Internal Air & Furniture	96	-	96	0.4	2.8
Ceilings	0	-	0	0.0	0.0
<b>Sub Total</b>	<b>2,702</b>	<b>77</b>	<b>2,779</b>	<b>11.0</b>	
<b>Internal Gains</b>					
Lights	429	-	429	1.7	12.7
People	0	0	0	0.0	0.0
Misc, Computers, Equip	172	0	172	0.7	5.1
<b>Sub Total</b>	<b>601</b>	<b>0</b>	<b>601</b>	<b>2.4</b>	
<b>TOTAL</b>	<b>3,303</b>	<b>77</b>	<b>3,380</b>	<b>13.4</b>	<b>100</b>

COOLING SUMMARY	
Sensible cooling load (Btu/h):	3,303
Latent cooling load (Btu/h):	77
Sensible heat ratio:	0.98
Design Supply Airflow calculated per:	Sensible Loads
Design zone air temp for Supply Airflow calculation (°F):	82.0

HEATING ROOM PEAK					
Time of Peak (Mo/Hr:Mn)					Heating Design
Outside Air (DBT/WBT/RH) °F and %RH					42.1 / 35.4 / 49.6
Room	Room Net Value	Room Per Floor Area	Room Percent of Total	Room Percent of Total	Room Percent of Total
<b>Envelope Gains/Losses</b>	Btu/h	Btu/h	Btu/h-ft <sup>2</sup>	%	%
External Walls	-3,536	-3,536	-14.1	65.1	
Roofs	-176	-176	-0.7	3.2	
Ground/Exposed Floors	-1,339	-1,339	-5.3	24.6	
External Doors	0	0	0.0	0.0	
Windows Conduction	0	0	0.0	0.0	
Skylights Conduction	0	0	0.0	0.0	
Solar	0	0	0.0	0.0	
Infiltration	-489	-489	-1.9	9.0	
Nat/Aux Vent	0	0	0.0	0.0	
<b>Internal Building Gains/Losses</b>					
Internal Walls/Openings	106	106	0.4	-1.9	
Internal Floors	0	0	0.0	0.0	
Internal Air & Furniture	0	0	0.0	0.0	
Ceilings	0	0	0.0	0.0	
<b>Sub Total</b>	<b>-5,434</b>	<b>-5,434</b>	<b>-21.6</b>		
<b>Internal Gains</b>					
Lights	0	0	0.0	0.0	
People	0	0	0.0	0.0	
Misc, Computers, Equip	0	0	0.0	0.0	
<b>Sub Total</b>	<b>0</b>	<b>0</b>	<b>0.0</b>		
<b>TOTAL</b>	<b>-5,434</b>	<b>-5,434</b>	<b>-21.6</b>		<b>100</b>

HEATING SUMMARY	
Sensible heating load (Btu/h):	5,434
Design zone air temp for Supply Airflow calculation (°F):	70.0

AREAS & THERMAL TRANSMITTANCE				
	Total Area	Glazing	Glazing	U-value <sup>1</sup>
	ft <sup>2</sup>	ft <sup>2</sup>	%	Btu/h-ft <sup>2</sup> -°F
<b>External</b>				
Wall (above grade)	1,462.0	-	-	0.09
Below Grade Walls	-	-	-	-
Windows <sup>2</sup>	-	-	-	-
Doors	-	-	-	-
Floors	251.6	-	-	0.19
Roofs <sup>3</sup>	251.4	-	-	0.02
<b>COMBINED</b>	<b>1,965.0</b>	<b>-</b>	<b>-</b>	<b>0.09</b>
<b>Internal</b>				
Ceilings	-	-	-	-
Floors	-	-	-	-
Partitions <sup>4</sup>	1,192.2	-	-	0.33

<sup>1</sup> Area-weighted U-value; <sup>2</sup> Windows/glazing include glass and frames; <sup>3</sup> Roofs incl. skylights; <sup>4</sup> Partitions incl. internal windows and doors.

TEMPERATURES & SETPOINTS		
	Cooling	Heating
	°F	°F
Supply Air (design)	55.0	90.0
Room Setpoint (design)	82.0	70.0
Room (actual)	82.1	70.0
Mean Radiant Temperature	83.1	67.7
Dry Resultant Temperature	82.6	68.8
RH (Design Max Setpoint) (%)	60.0	60.0

AIRFLOW		
	Cooling	Heating
	cfm	cfm
Supply (design)	112	248
Reheat Minimum (design)	75	75
Leakage at Design Flow	0	0
Ventilation (requirement)	19	19
Exhaust (requirement)	-	-
Infiltration	16	16

CHECKS	
Number of People	0.00
ft <sup>2</sup> /Person	-
Average Ceiling Height (ft)	38.15
Btu/h/ft <sup>2</sup> - Cooling (sensible)	13.13
Btu/h/ft <sup>2</sup> - Heating	21.60
ft <sup>2</sup> /ton - Cooling (sensible)	914.07
ft <sup>2</sup> /ton - Heating	555.54
cfm/ft <sup>2</sup> - Cooling	0.44
cfm/ft <sup>2</sup> - Heating	0.99
% Outside Air - Cooling	16.87
% Outside Air - Heating	7.60
Outdoor Air cfm/ft <sup>2</sup>	0.08
Outdoor Air cfm/person	-

# Room Loads Report

Zone: Dh-2  
System: 05 a VAV - Reheat

# Long Center Option2

31 Vestibule

HVAC Methodology: ApacheHVAC

IES VIRTUAL ENVIRONMENT

VE 2023



COOLING ROOM PEAK					
Time of Peak (Mo/Hr:Mn)					9 / 11:30
Outside Air (DBT/WBT/RH) °F and %RH					89.8 / 76.1 / 53.4
Room	Room Sensible	Room Latent	Net Value	Per Floor Area	Percent of Total
<b>Envelope Gains/Losses</b>	Btu/h	Btu/h	Btu/h	Btu/h-ft <sup>2</sup>	%
External Walls	-614	-	-614	-2.3	-3.9
Roofs	-807	-	-807	-3.1	-5.2
Ground/Exposed Floors	-2,037	-	-2,037	-7.7	-13.1
External Doors	0	-	0	0.0	0.0
Windows Conduction	1,750	-	1,750	6.6	11.3
Skylights Conduction	0	-	0	0.0	0.0
Solar	18,742	-	18,742	70.9	120.5
Infiltration	124	142	266	1.0	1.7
Nat/Aux Vent	0	0	0	0.0	0.0
<b>Internal Building Gains/Losses</b>					
Internal Walls/Opening	-2,375	-	-2,375	-9.0	-15.3
Internal Floors	0	-	0	0.0	0.0
Internal Air & Furniture	0	-	0	0.0	0.0
Ceilings	0	-	0	0.0	0.0
<b>Sub Total</b>	<b>14,784</b>	<b>142</b>	<b>14,926</b>	<b>56.4</b>	
<b>Internal Gains</b>					
Lights	451	-	451	1.7	2.9
People	0	0	0	0.0	0.0
Misc, Computers, Equip	181	0	181	0.7	1.2
<b>Sub Total</b>	<b>632</b>	<b>0</b>	<b>632</b>	<b>2.4</b>	
<b>TOTAL</b>	<b>15,415</b>	<b>142</b>	<b>15,558</b>	<b>58.8</b>	<b>100</b>

COOLING SUMMARY	
Sensible cooling load (Btu/h):	15,415
Latent cooling load (Btu/h):	142
Sensible heat ratio:	0.99
Design Supply Airflow calculated per:	Sensible Loads
Design zone air temp for Supply Airflow calculation (°F):	82.0

HEATING ROOM PEAK					
Time of Peak (Mo/Hr:Mn)					Heating Design
Outside Air (DBT/WBT/RH) °F and %RH					42.1 / 35.4 / 49.6
Room	Room Sensible	Net Value	Per Floor Area	Percent of Total	
<b>Envelope Gains/Losses</b>	Btu/h	Btu/h	Btu/h-ft <sup>2</sup>	%	
External Walls	-1,732	-1,732	-6.5	20.0	
Roofs	-178	-178	-0.7	2.1	
Ground/Exposed Floors	-1,344	-1,344	-5.1	15.5	
External Doors	0	0	0.0	0.0	
Windows Conduction	-5,607	-5,607	-21.2	64.8	
Skylights Conduction	0	0	0.0	0.0	
Solar	0	0	0.0	0.0	
Infiltration	-514	-514	-1.9	5.9	
Nat/Aux Vent	0	0	0.0	0.0	
<b>Internal Building Gains/Losses</b>					
Internal Walls/Opening	716	716	2.7	-8.3	
Internal Floors	0	0	0.0	0.0	
Internal Air & Furniture	0	0	0.0	0.0	
Ceilings	0	0	0.0	0.0	
<b>Sub Total</b>	<b>-8,658</b>	<b>-8,658</b>	<b>-32.7</b>		
<b>Internal Gains</b>					
Lights	0	0	0.0	0.0	
People	0	0	0.0	0.0	
Misc, Computers, Equip	0	0	0.0	0.0	
<b>Sub Total</b>	<b>0</b>	<b>0</b>	<b>0.0</b>		
<b>TOTAL</b>	<b>-8,658</b>	<b>-8,658</b>	<b>-32.7</b>	<b>100</b>	

HEATING SUMMARY	
Sensible heating load (Btu/h):	8,658
Design zone air temp for Supply Airflow calculation (°F):	70.0

AREAS & THERMAL TRANSMITTANCE				
	Total Area	Glazing	Glazing	U-value <sup>1</sup>
	ft <sup>2</sup>	ft <sup>2</sup>	%	Btu/h-ft <sup>2</sup> -°F
<b>External</b>				
Wall (above grade)	1,453.8	402.8	27.7	0.21
Below Grade Walls	-	-	-	-
Windows <sup>2</sup>	402.8	402.8	100.0	0.53
Doors	-	-	-	-
Floors	264.5	-	-	0.19
Roofs <sup>3</sup>	264.5	-	-	0.02
<b>COMBINED</b>	<b>1,982.8</b>	<b>402.8</b>	<b>20.3</b>	<b>0.18</b>
<b>Internal</b>				
Ceilings	-	-	-	-
Floors	-	-	-	-
Partitions <sup>4</sup>	1,061.3	-	-	0.33

<sup>1</sup> Area-weighted U-value; <sup>2</sup> Windows/glazing include glass and frames; <sup>3</sup> Roofs incl. skylights; <sup>4</sup> Partitions incl. internal windows and doors.

TEMPERATURES & SETPOINTS		
	Cooling	Heating
	°F	°F
Supply Air (design)	55.0	90.0
Room Setpoint (design)	82.0	70.0
Room (actual)	82.0	70.0
Mean Radiant Temperature	87.7	65.8
Dry Resultant Temperature	84.9	67.9
RH (Design Max Setpoint) (%)	60.0	60.0

AIRFLOW		
	Cooling	Heating
	cfm	cfm
Supply (design)	522	396
Reheat Minimum (design)	157	157
Leakage at Design Flow	0	0
Ventilation (requirement)	20	20
Exhaust (requirement)	-	-
Infiltration	17	17

CHECKS	
Number of People	0.00
ft <sup>2</sup> /Person	-
Average Ceiling Height (ft)	38.17
Btu/h/ft <sup>2</sup> - Cooling (sensible)	58.29
Btu/h/ft <sup>2</sup> - Heating	32.74
ft <sup>2</sup> /ton - Cooling (sensible)	205.88
ft <sup>2</sup> /ton - Heating	366.55
cfm/ft <sup>2</sup> - Cooling	1.97
cfm/ft <sup>2</sup> - Heating	1.50
% Outside Air - Cooling	3.80
% Outside Air - Heating	5.01
Outdoor Air cfm/ft <sup>2</sup>	0.07
Outdoor Air cfm/person	-

# Room Loads Report

Zone: Dh-2  
System: 05 a VAV - Reheat

# Long Center Option2 32 DH-2 Pool Area Circulation HVAC Methodology: ApacheHVAC

IES VIRTUAL ENVIRONMENT

VE 2023



COOLING ROOM PEAK					
Time of Peak (Mo/Hr:Mn)					6 / 17:30
Outside Air (DBT/WBT/RH) °F and %RH					91.6 / 76.2 / 49.5
Room	Room Sensible	Room Latent	Net Value	Per Floor Area	Percent of Total
<b>Envelope Gains/Losses</b>	Btu/h	Btu/h	Btu/h	Btu/h-ft²	%
External Walls	2,686	-	2,686	2.3	12.1
Roofs	283	-	283	0.2	1.3
Ground/Exposed Floors	-487	-	-487	-0.4	-2.2
External Doors	0	-	0	0.0	0.0
Windows Conduction	948	-	948	0.8	4.3
Skylights Conduction	0	-	0	0.0	0.0
Solar	17,285	-	17,285	14.6	78.0
Infiltration	828	564	1,392	1.2	6.3
Nat/Aux Vent	0	0	0	0.0	0.0
<b>Internal Building Gains/Losses</b>					
Internal Walls/Openings	-2,771	-	-2,771	-2.3	-12.5
Internal Floors	0	-	0	0.0	0.0
Internal Air & Furniture	0	-	0	0.0	0.0
Ceilings	-3	-	-3	0.0	0.0
<b>Sub Total</b>	<b>18,769</b>	<b>564</b>	<b>19,333</b>	<b>16.3</b>	
<b>Internal Gains</b>					
Lights	2,026	-	2,026	1.7	9.1
People	0	0	0	0.0	0.0
Misc, Computers, Equip	811	0	811	0.7	3.7
<b>Sub Total</b>	<b>2,837</b>	<b>0</b>	<b>2,837</b>	<b>2.4</b>	
<b>TOTAL</b>	<b>21,606</b>	<b>564</b>	<b>22,170</b>	<b>18.7</b>	<b>100</b>

COOLING SUMMARY	
Sensible cooling load (Btu/h):	21,606
Latent cooling load (Btu/h):	564
Sensible heat ratio:	0.97
Design Supply Airflow calculated per:	Sensible Loads
Design zone air temp for Supply Airflow calculation (°F):	82.0

HEATING ROOM PEAK					
Time of Peak (Mo/Hr:Mn)					Heating Design
Outside Air (DBT/WBT/RH) °F and %RH					42.1 / 35.4 / 49.6
Room	Room Value	Net Value	Per Floor Area	Percent of Total	
<b>Envelope Gains/Losses</b>	Btu/h	Btu/h	Btu/h-ft²	%	
External Walls	-8,486	-8,486	-7.1	46.5	
Roofs	-804	-804	-0.7	4.4	
Ground/Exposed Floors	-6,677	-6,677	-5.6	36.6	
External Doors	0	0	0.0	0.0	
Windows Conduction	-2,639	-2,639	-2.2	14.5	
Skylights Conduction	0	0	0.0	0.0	
Solar	0	0	0.0	0.0	
Infiltration	-2,261	-2,261	-1.9	12.4	
Nat/Aux Vent	0	0	0.0	0.0	
<b>Internal Building Gains/Losses</b>					
Internal Walls/Openings	2,618	2,618	2.2	-14.3	
Internal Floors	0	0	0.0	0.0	
Internal Air & Furniture	0	0	0.0	0.0	
Ceilings	0	0	0.0	0.0	
<b>Sub Total</b>	<b>-18,249</b>	<b>-18,249</b>	<b>-15.4</b>		
<b>Internal Gains</b>					
Lights	0	0	0.0	0.0	
People	0	0	0.0	0.0	
Misc, Computers, Equip	0	0	0.0	0.0	
<b>Sub Total</b>	<b>0</b>	<b>0</b>	<b>0.0</b>		
<b>TOTAL</b>	<b>-18,249</b>	<b>-18,249</b>	<b>-15.4</b>	<b>100</b>	

HEATING SUMMARY	
Sensible heating load (Btu/h):	18,249
Design zone air temp for Supply Airflow calculation (°F):	70.0

AREAS & THERMAL TRANSMITTANCE				
	Total Area	Glazing	Glazing	U-value <sup>1</sup>
	ft²	ft²	%	Btu/h-ft²-°F
<b>External</b>				
Wall (above grade)	3,735.4	176.7	4.7	0.11
Below Grade Walls	-	-	-	-
Windows <sup>2</sup>	176.7	176.7	100.0	0.53
Doors	-	-	-	-
Floors	1,187.8	-	-	0.19
Roofs <sup>3</sup>	1,143.6	-	-	0.02
<b>COMBINED</b>	<b>6,066.8</b>	<b>176.7</b>	<b>2.9</b>	<b>0.11</b>
<b>Internal</b>				
Ceilings	44.1	-	-	0.05
Floors	-	-	-	-
Partitions <sup>4</sup>	2,305.0	-	-	0.33

<sup>1</sup> Area-weighted U-value; <sup>2</sup> Windows/glazing include glass and frames; <sup>3</sup> Roofs incl. skylights; <sup>4</sup> Partitions incl. internal windows and doors.

TEMPERATURES & SETPOINTS		
	Cooling	Heating
	°F	°F
Supply Air (design)	55.0	90.0
Room Setpoint (design)	82.0	70.0
Room (actual)	82.0	70.0
Mean Radiant Temperature	83.7	67.9
Dry Resultant Temperature	82.8	69.0
RH (Design Max Setpoint) (%)	60.0	60.0

AIRFLOW		
	Cooling	Heating
	cfm	cfm
Supply (design)	2,961	2,961
Reheat Minimum (design)	2,961	2,961
Leakage at Design Flow	0	0
Ventilation (requirement)	2,961	2,961
Exhaust (requirement)	1,480	1,480
Infiltration	74	74

CHECKS	
Number of People	0.00
ft²/Person	-
Average Ceiling Height (ft)	37.39
Btu/h/ft² - Cooling (sensible)	18.19
Btu/h/ft² - Heating	15.36
ft²/ton - Cooling (sensible)	659.67
ft²/ton - Heating	781.03
cfm/ft² - Cooling	2.49
cfm/ft² - Heating	2.49
% Outside Air - Cooling	100.00
% Outside Air - Heating	100.00
Outdoor Air cfm/ft²	2.49
Outdoor Air cfm/person	-

# Room Loads Report

Zone: Dh-2  
System: 05 a VAV - Reheat

# Long Center Option2 DH-2 Pool Area HVAC Methodology: ApacheHVAC

IES VIRTUAL ENVIRONMENT

VE 2023



COOLING ROOM PEAK					
Time of Peak (Mo/Hr:Mn)					8 / 17:30
Outside Air (DBT/WBT/RH) °F and %RH					91.6 / 77.7 / 53.8
Room	Room Sensible	Room Latent	Net Value	Per Floor Area	Percent of Total
<b>Envelope Gains/Losses</b>	Btu/h	Btu/h	Btu/h	Btu/h-ft²	%
External Walls	870	-	870	0.1	0.2
Roofs	0	-	0	0.0	0.0
Ground/Exposed Floors	-1,550	-	-1,550	-0.1	-0.3
External Doors	0	-	0	0.0	0.0
Windows Conduction	1,528	-	1,528	0.1	0.3
Skylights Conduction	0	-	0	0.0	0.0
Solar	33,794	-	33,794	2.9	7.5
Infiltration	2,139	3,820	5,960	0.5	1.3
Nat/Aux Vent	0	0	0	0.0	0.0
<b>Internal Building Gains/Losses</b>					
Internal Walls/Opening	-8,883	-	-8,883	-0.8	-2.0
Internal Floors	-756	-	-756	-0.1	-0.2
Internal Air & Furniture	0	-	0	0.0	0.0
Ceilings	0	-	0	0.0	0.0
Sub Total	27,143	3,820	30,963	2.7	
<b>Internal Gains</b>					
Lights	35,560	-	35,560	3.1	7.9
People	17,750	27,250	45,000	3.9	9.9
Misc, Computers, Equip	0	341,222	341,222	29.5	75.4
Sub Total	53,310	368,472	421,783	36.4	
<b>TOTAL</b>	<b>80,453</b>	<b>372,293</b>	<b>452,746</b>	<b>39.1</b>	<b>100</b>

COOLING SUMMARY	
Sensible cooling load (Btu/h):	80,453
Latent cooling load (Btu/h):	372,293
Sensible heat ratio:	0.18
Design Supply Airflow calculated per:	Sensible Loads
Design zone air temp for Supply Airflow calculation (°F):	82.0

HEATING ROOM PEAK					
Time of Peak (Mo/Hr:Mn)					Heating Design
Outside Air (DBT/WBT/RH) °F and %RH					42.1 / 35.4 / 49.6
Room	Room Value	Net Value	Per Floor Area	Percent of Total	
<b>Envelope Gains/Losses</b>	Btu/h	Btu/h	Btu/h-ft²	%	
External Walls	-1,610	-1,610	-0.1	4.8	
Roofs	0	0	0.0	0.0	
Ground/Exposed Floors	-6,150	-6,150	-0.5	18.3	
External Doors	0	0	0.0	0.0	
Windows Conduction	-3,582	-3,582	-0.3	10.7	
Skylights Conduction	0	0	0.0	0.0	
Solar	0	0	0.0	0.0	
Infiltration	-5,882	-5,882	-0.5	17.5	
Nat/Aux Vent	0	0	0.0	0.0	
<b>Internal Building Gains/Losses</b>					
Internal Walls/Opening	2,683	2,683	0.2	-8.0	
Internal Floors	-18,985	-18,985	-1.6	56.6	
Internal Air & Furniture	0	0	0.0	0.0	
Ceilings	0	0	0.0	0.0	
Sub Total	-33,527	-33,527	-2.9		
<b>Internal Gains</b>					
Lights	0	0	0.0	0.0	
People	0	0	0.0	0.0	
Misc, Computers, Equip	0	0	0.0	0.0	
Sub Total	0	0	0.0		
<b>TOTAL</b>	<b>-33,527</b>	<b>-33,527</b>	<b>-2.9</b>	<b>100</b>	

HEATING SUMMARY	
Sensible heating load (Btu/h):	33,527
Design zone air temp for Supply Airflow calculation (°F):	70.0

AREAS & THERMAL TRANSMITTANCE				
	Total Area	Glazing	Glazing	U-value <sup>1</sup>
	ft²	ft²	%	Btu/h-ft²-°F
<b>External</b>				
Wall (above grade)	1,027.6	363.7	35.4	0.18
Below Grade Walls	-	-	-	-
Windows <sup>2</sup>	363.7	363.7	100.0	0.34
Doors	-	-	-	-
Floors	4,432.2	-	-	0.05
Roofs <sup>3</sup>	-	-	-	-
<b>COMBINED</b>	<b>5,459.8</b>	<b>363.7</b>	<b>6.7</b>	<b>0.08</b>
<b>Internal</b>				
Ceilings	-	-	-	-
Floors	7,147.5	-	-	0.19
Partitions <sup>4</sup>	2,474.9	-	-	0.33

<sup>1</sup> Area-weighted U-value; <sup>2</sup> Windows/glazing include glass and frames; <sup>3</sup> Roofs incl. skylights; <sup>4</sup> Partitions incl. internal windows and doors.

TEMPERATURES & SETPOINTS		
	Cooling	Heating
	°F	°F
Supply Air (design)	55.0	90.0
Room Setpoint (design)	82.0	70.0
Room (actual)	82.0	70.0
Mean Radiant Temperature	84.4	68.0
Dry Resultant Temperature	83.2	69.0
RH (Design Max Setpoint) (%)	60.0	60.0

AIRFLOW		
	Cooling	Heating
	cfm	cfm
Supply (design)	7,703	7,703
Reheat Minimum (design)	7,703	7,703
Leakage at Design Flow	0	0
Ventilation (requirement)	7,703	7,703
Exhaust (requirement)	3,851	3,851
Infiltration	193	193

CHECKS	
Number of People	25.00
ft²/Person	463.19
Average Ceiling Height (ft)	9.98
Btu/h/ft² - Cooling (sensible)	6.95
Btu/h/ft² - Heating	2.90
ft²/ton - Cooling (sensible)	1,727.17
ft²/ton - Heating	4,144.61
cfm/ft² - Cooling	0.67
cfm/ft² - Heating	0.67
% Outside Air - Cooling	100.00
% Outside Air - Heating	100.00
Outdoor Air cfm/ft²	0.67
Outdoor Air cfm/person	308.10

# Room Loads Report

Zone: Dh-2  
System: 05 a VAV - Reheat

# Long Center Option2 DH-2 Pool Area (upper 1) HVAC Methodology: ApacheHVAC

IES VIRTUAL ENVIRONMENT

VE 2023



COOLING ROOM PEAK					
Time of Peak (Mo/Hr:Mn)					8 / 16:30
Outside Air (DBT/WBT/RH) °F and %RH					92.7 / 78.1 / 52.3
Room	Room Sensible	Room Latent	Net Value	Per Floor Area	Percent of Total
<b>Envelope Gains/Losses</b>	Btu/h	Btu/h	Btu/h	Btu/h-ft <sup>2</sup>	%
External Walls	1,140	-	1,140	-	4.3
Roofs	0	-	0	-	0.0
Ground/Exposed Floors	0	-	0	-	0.0
External Doors	0	-	0	-	0.0
Windows Conduction	3,001	-	3,001	-	11.4
Skylights Conduction	0	-	0	-	0.0
Solar	7,375	-	7,375	-	28.1
Infiltration	3,314	3,997	7,311	-	27.8
Nat/Aux Vent	0	0	0	-	0.0
<b>Internal Building Gains/Losses</b>					
Internal Walls/Opening	7,429	-	7,429	-	28.3
Internal Floors	0	-	0	-	0.0
Internal Air & Furniture	0	-	0	-	0.0
Ceilings	0	-	0	-	0.0
<b>Sub Total</b>	<b>22,259</b>	<b>3,997</b>	<b>26,257</b>	<b>0.0</b>	
<b>Internal Gains</b>					
Lights	0	-	0	-	0.0
People	0	0	0	-	0.0
Misc, Computers, Equip	0	0	0	-	0.0
<b>Sub Total</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0.0</b>	
<b>TOTAL</b>	<b>22,259</b>	<b>3,997</b>	<b>26,257</b>	<b>0.0</b>	<b>100</b>

COOLING SUMMARY	
Sensible cooling load (Btu/h):	22,259
Latent cooling load (Btu/h):	3,997
Sensible heat ratio:	0.85
Design Supply Airflow calculated per:	Sensible Loads
Design zone air temp for Supply Airflow calculation (°F):	82.0

HEATING ROOM PEAK					
Time of Peak (Mo/Hr:Mn)					Heating Design
Outside Air (DBT/WBT/RH) °F and %RH					42.1 / 35.4 / 49.6
Room	Room Value	Net Value	Per Floor Area	Percent of Total	
<b>Envelope Gains/Losses</b>	Btu/h	Btu/h	Btu/h-ft <sup>2</sup>	%	
External Walls	-2,438	-2,438	-	-	
Roofs	0	0	-	-	
Ground/Exposed Floors	0	0	-	-	
External Doors	0	0	-	-	
Windows Conduction	-6,748	-6,748	-	-	
Skylights Conduction	0	0	-	-	
Solar	0	0	-	-	
Infiltration	-8,306	-8,306	-	-	
Nat/Aux Vent	0	0	-	-	
<b>Internal Building Gains/Losses</b>					
Internal Walls/Opening	-3,373	-3,373	-	-	
Internal Floors	0	0	-	-	
Internal Air & Furniture	0	0	-	-	
Ceilings	0	0	-	-	
<b>Sub Total</b>	<b>-20,866</b>	<b>-20,866</b>	<b>0.0</b>		
<b>Internal Gains</b>					
Lights	0	0	-	-	
People	0	0	-	-	
Misc, Computers, Equip	0	0	-	-	
<b>Sub Total</b>	<b>0</b>	<b>0</b>	<b>0.0</b>		
<b>TOTAL</b>	<b>-20,866</b>	<b>-20,866</b>	<b>0.0</b>	<b>0</b>	

HEATING SUMMARY	
Sensible heating load (Btu/h):	20,866
Design zone air temp for Supply Airflow calculation (°F):	70.0

AREAS & THERMAL TRANSMITTANCE				
	Total Area	Glazing	Glazing	U-value <sup>1</sup>
	ft <sup>2</sup>	ft <sup>2</sup>	%	Btu/h-ft <sup>2</sup> -°F
<b>External</b>				
Wall (above grade)	1,451.2	487.7	33.6	0.22
Below Grade Walls	-	-	-	-
Windows <sup>2</sup>	487.7	487.7	100.0	0.48
Doors	-	-	-	-
Floors	-	-	-	-
Roofs <sup>3</sup>	-	-	-	-
<b>COMBINED</b>	<b>1,451.2</b>	<b>487.7</b>	<b>33.6</b>	<b>0.22</b>
<b>Internal</b>				
Ceilings	-	-	-	-
Floors	-	-	-	-
Partitions <sup>4</sup>	3,412.3	-	-	0.33

<sup>1</sup> Area-weighted U-value; <sup>2</sup> Windows/glazing include glass and frames; <sup>3</sup> Roofs incl. skylights; <sup>4</sup> Partitions incl. internal windows and doors.

TEMPERATURES & SETPOINTS		
	Cooling	Heating
	°F	°F
Supply Air (design)	55.0	90.0
Room Setpoint (design)	82.0	70.0
Room (actual)	82.0	70.0
Mean Radiant Temperature	83.2	68.5
Dry Resultant Temperature	82.6	69.2
RH (Design Max Setpoint) (%)	60.0	60.0

AIRFLOW		
	Cooling	Heating
	cfm	cfm
Supply (design)	5,439	5,439
Reheat Minimum (design)	5,439	5,439
Leakage at Design Flow	0	0
Ventilation (requirement)	5,439	5,439
Exhaust (requirement)	4,079	4,079
Infiltration	272	272

CHECKS	
Number of People	0.00
ft <sup>2</sup> /Person	-
Average Ceiling Height (ft)	14.09
Btu/h/ft <sup>2</sup> - Cooling (sensible)	-
Btu/h/ft <sup>2</sup> - Heating	-
ft <sup>2</sup> /ton - Cooling (sensible)	-
ft <sup>2</sup> /ton - Heating	-
cfm/ft <sup>2</sup> - Cooling	-
cfm/ft <sup>2</sup> - Heating	-
% Outside Air - Cooling	100.00
% Outside Air - Heating	100.00
Outdoor Air cfm/ft <sup>2</sup>	-
Outdoor Air cfm/person	-

# Room Loads Report

Zone: Dh-2  
System: 05 a VAV - Reheat

# Long Center Option2 DH-2 Pool Area (upper 2) HVAC Methodology: ApacheHVAC

IES VIRTUAL ENVIRONMENT

VE 2023



COOLING ROOM PEAK					
Time of Peak (Mo/Hr:Mn)					6 / 17:30
Outside Air (DBT/WBT/RH) °F and %RH					91.6 / 76.2 / 49.5
Room	Room Sensible	Room Latent	Net Value	Per Floor Area	Percent of Total
<b>Envelope Gains/Losses</b>	Btu/h	Btu/h	Btu/h	Btu/h-ft²	%
External Walls	1,456	-	1,456	-	4.9
Roofs	7,488	-	7,488	-	25.0
Ground/Exposed Floors	0	-	0	-	0.0
External Doors	0	-	0	-	0.0
Windows Conduction	2,535	-	2,535	-	8.5
Skylights Conduction	0	-	0	-	0.0
Solar	10,649	-	10,649	-	35.5
Infiltration	3,043	2,072	5,114	-	17.1
Nat/Aux Vent	0	0	0	-	0.0
<b>Internal Building Gains/Losses</b>					
Internal Walls/Openings	2,729	-	2,729	-	9.1
Internal Floors	0	-	0	-	0.0
Internal Air & Furniture	0	-	0	-	0.0
Ceilings	0	-	0	-	0.0
<b>Sub Total</b>	<b>27,899</b>	<b>2,072</b>	<b>29,971</b>	<b>0.0</b>	
<b>Internal Gains</b>					
Lights	0	-	0	-	0.0
People	0	0	0	-	0.0
Misc, Computers, Equip	0	0	0	-	0.0
<b>Sub Total</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0.0</b>	
<b>TOTAL</b>	<b>27,899</b>	<b>2,072</b>	<b>29,971</b>	<b>0.0</b>	<b>100</b>

COOLING SUMMARY	
Sensible cooling load (Btu/h):	27,899
Latent cooling load (Btu/h):	2,072
Sensible heat ratio:	0.93
Design Supply Airflow calculated per:	Sensible Loads
Design zone air temp for Supply Airflow calculation (°F):	82.0

HEATING ROOM PEAK					
Time of Peak (Mo/Hr:Mn)					Heating Design
Outside Air (DBT/WBT/RH) °F and %RH					42.1 / 35.4 / 49.6
Room	Room Value	Net Value	Per Floor Area	Percent of Total	
<b>Envelope Gains/Losses</b>	Btu/h	Btu/h	Btu/h-ft²	%	
External Walls	-2,486	-2,486	-	-	
Roofs	-8,273	-8,273	-	-	
Ground/Exposed Floors	0	0	-	-	
External Doors	0	0	-	-	
Windows Conduction	-5,883	-5,883	-	-	
Skylights Conduction	0	0	-	-	
Solar	0	0	-	-	
Infiltration	-8,306	-8,306	-	-	
Nat/Aux Vent	0	0	-	-	
<b>Internal Building Gains/Losses</b>					
Internal Walls/Openings	-2,632	-2,632	-	-	
Internal Floors	0	0	-	-	
Internal Air & Furniture	0	0	-	-	
Ceilings	0	0	-	-	
<b>Sub Total</b>	<b>-27,580</b>	<b>-27,580</b>	<b>0.0</b>		
<b>Internal Gains</b>					
Lights	0	0	-	-	
People	0	0	-	-	
Misc, Computers, Equip	0	0	-	-	
<b>Sub Total</b>	<b>0</b>	<b>0</b>	<b>0.0</b>		
<b>TOTAL</b>	<b>-27,580</b>	<b>-27,580</b>	<b>0.0</b>	<b>0</b>	

HEATING SUMMARY	
Sensible heating load (Btu/h):	27,580
Design zone air temp for Supply Airflow calculation (°F):	70.0

AREAS & THERMAL TRANSMITTANCE				
	Total Area	Glazing	Glazing	U-value <sup>1</sup>
	ft²	ft²	%	Btu/h-ft²-°F
<b>External</b>				
Wall (above grade)	1,451.2	472.7	32.6	0.20
Below Grade Walls	-	-	-	-
Windows <sup>2</sup>	472.7	472.7	100.0	0.43
Doors	-	-	-	-
Floors	-	-	-	-
Roofs <sup>3</sup>	11,579.7	-	-	0.02
<b>COMBINED</b>	<b>13,030.9</b>	<b>472.7</b>	<b>3.6</b>	<b>0.04</b>
<b>Internal</b>				
Ceilings	-	-	-	-
Floors	-	-	-	-
Partitions <sup>4</sup>	3,558.8	-	-	0.33

<sup>1</sup> Area-weighted U-value; <sup>2</sup> Windows/glazing include glass and frames; <sup>3</sup> Roofs incl. skylights; <sup>4</sup> Partitions incl. internal windows and doors.

TEMPERATURES & SETPOINTS		
	Cooling	Heating
	°F	°F
Supply Air (design)	55.0	90.0
Room Setpoint (design)	82.0	70.0
Room (actual)	82.0	70.0
Mean Radiant Temperature	83.1	68.7
Dry Resultant Temperature	82.5	69.3
RH (Design Max Setpoint) (%)	60.0	60.0

AIRFLOW		
	Cooling	Heating
	cfm	cfm
Supply (design)	5,439	5,439
Reheat Minimum (design)	5,439	5,439
Leakage at Design Flow	0	0
Ventilation (requirement)	5,439	5,439
Exhaust (requirement)	4,079	4,079
Infiltration	272	272

CHECKS	
Number of People	0.00
ft²/Person	-
Average Ceiling Height (ft)	14.09
Btu/h-ft² - Cooling (sensible)	-
Btu/h-ft² - Heating	-
ft²/ton - Cooling (sensible)	-
ft²/ton - Heating	-
cfm/ft² - Cooling	-
cfm/ft² - Heating	-
% Outside Air - Cooling	100.00
% Outside Air - Heating	100.00
Outdoor Air cfm/ft²	-
Outdoor Air cfm/person	-

