



REMEMBER: Work zone area conditions may have changed for this job! Everyone is responsible for verifying the above safety information is correct prior to any work being performed each day.

CONSTRUCTION NOTES:
ALL NEW CONDUIT INSTALLED BY DIRECTIONAL BORING.
ALL CABLE INSTALLED IN CONDUIT UNLESS STATED OTHERWISE

RELATED WO'S:
REMOVE: 35762842

911 ADDRESS:
320 CLEVELAND ST
CLEARWATER, FL 33755

DUKE ENERGY
PROJECT MANAGER
STEPHEN ANDERSON
PHONE: 320-420-2463

DUKE ENERGY
ENGINEER
MARK MICHAEL
PHONE: 727-418-5307

CONTRACT PARTNER
THOMAS WHEELER
PHONE: 407-243-3713

SCOPE OF WORK:
PULL C8 THROUGH THE SOUTH WINDOW IN MANHOLE 137 TO MANHOLE 65.
PULL C9 THROUGH THE SOUTH WINDOW IN MANHOLE 137 TO MANHOLE 65.
PULL C8 THROUGH THE SOUTH WINDOW IN MANHOLE 65 TO MANHOLE 94.
PULL C9 THROUGH THE SOUTH WINDOW IN MANHOLE 65 TO MANHOLE 94.
MANHOLE 94 WILL NEED TO BE CORE DRILLED OUT OF THE SOUTH WINDOW.
THEN BORE BOTH SPANS TO NEW PULLBOX OFF OF OSCEOLA AVE.
FROM THERE PULL CABLE THROUGH CUSTOMER INSTALLED CONDUIT TO
NEW PULLBOX AND THEN TO EXISTING SWITCHGEARS.

Work Order Number	35664457
Customer/Contact	
Contact Phone	
Job Site Address	320 CLEVELAND ST
City	CLEARWATER
County	PINELLAS
State, Zip	FL, 33755
Designer	DANIEL MCLEOD
Designer Phone	407-374-5399
Circuit ID	C8/C9
Primary Voltage	12.47/7.2KV
Permit Required	Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>
Permit Type/No.	CITY OF CLEARWATER
Permit Type/No. 2	
Permit Type/No. 3	
Permit Type/No. 4	

