



Legislation Details (With Text)

| | | | | | |
|-----------------------|---|----------------------|--------------|--------------|--|
| File #: | ID#18-5322 | Version: | 1 | Name: | East Water Reclamation Facility Influent Pump Station Rehabilitation |
| Type: | Action Item | Status: | Passed | | |
| File created: | 10/23/2018 | In control: | Public Works | | |
| On agenda: | 11/15/2018 | Final action: | 11/15/2018 | | |
| Title: | Approve Engineer of Record (EOR) Supplement Work Order 2 to King Engineering Associates, Inc. in the amount of \$110,130 for the East Water Reclamation Facility Influent Pump Station Rehabilitation (13-0016-UT) and authorize the appropriate officials to execute same. (consent) | | | | |
| Sponsors: | | | | | |
| Indexes: | **, 2. Economic & Housing Opportunity, 4. Environmental Stewardship | | | | |
| Code sections: | | | | | |
| Attachments: | 1. 2018-09 East Influent Pump Station SWO 2.pdf, 2. 13-0016-UT_East WRF IPS Rehab Map | | | | |

| Date | Ver. | Action By | Action | Result |
|------------|------|----------------------|--------|--------|
| 11/15/2018 | 1 | City Council | | |
| 11/13/2018 | 1 | Council Work Session | | |

SUBJECT/RECOMMENDATION:

Approve Engineer of Record (EOR) Supplement Work Order 2 to King Engineering Associates, Inc. in the amount of \$110,130 for the East Water Reclamation Facility Influent Pump Station Rehabilitation (13-0016-UT) and authorize the appropriate officials to execute same. (consent)

SUMMARY:

On June 14, 2013, the City Manager approved the initial work order to EOR King Engineering Associates, Inc. to provide a preliminary design for the rehabilitation of the East WRF Influent Pump Station in the amount of \$35,632.

On December 24, 2015, the City Manager approved supplemental work order one to provide design of a new influent sewer structure upstream of the Influent Pump Station as required for the temporary by-pass of the Influent Pump Station during its rehabilitation in the amount of \$23,203.

Supplemental 2 provides for the completion of the rehabilitation design and bidding services including lining of the existing main from the proposed sewer by-pass structure to the wet well, a corrosion resistant coating for the wet well, an improved Fats/Oils/Grease breakup spray water system, odor control improvements and a new headworks gantry crane for servicing the bar screens for a new work order value of \$168,965.

APPROPRIATION CODE AND AMOUNT:

3277327-561300-96664

Funds are available in capital improvement project 96664, WPC Repair and Replacement, to fund this work order.